Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 140601-E84967B
ISSUE DATE: June 14, 2001 Page 1 of 1

Issued to: Square D. Company
3700 6th Street S.W.
Cedar Rapids, IA. 52404 USA

Report Reference: E84967, May 15, 1990

This is to Certify that representative samples of: Molded Case Circuit Breakers, Type HOMT Series 1

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are two and four pole circuit breakers, rated from 15A through 30A.
Current Interrupting Rating is as follows:
10,000A, 120/240 Vac, 1 phase, 50/60 Hz.
Uses wires rated as follows:
60 or 75 Deg. C for 15-20A and 75 Deg. C only for 30A
Note: May be marked "Listed HACR Type."

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: (UL) with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: Lawrence R. Smith
Lawrence R. Smith, Staff Eng. Assoc.
Underwriters Laboratories Inc.

Review Engineer: Michael S. Mayes /SM
Michael S. Mayes, Staff Eng. Assoc.
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service