Certificate of Compliance

Certificate Number(s):

UL-US-L164353-14519-81802991-13

Report Reference:

E164353-19920818

Issue Date:

2026-02-16

Issued to:

Schneider Electric Industries S A, DBA Telemecanique
1101 Shiloh Glenn Dr, Suite 100, Morrisville, NC, 27560, US

This certificate confirms that representative samples of:
NKCR - Auxiliary Devices

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 60947-1, Edition 6, Issue Date 2022-05-31
UL 60947-4-1, 4th Ed., Issue Date: 2022-05-31

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

Public

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-L164353-14519-81802991-13
Report reference: E164353-19920818
Issue Date: 2026-02-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Base provided adapters

Model(s): LA7D

Thermal overload relays

Model(s): LRD33, LR2D33, LR3D33, LRD43, LR2D43, LR3D43 *followed by two digit numbers may be followed by 6 or by A66*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

Certificate of Compliance

Certificate Number(s):

UL-CA-L164353-34519-81802991-10

Report Reference:

E164353-19920818

Issue Date:

2026-02-16

Issued to:

Schneider Electric Industries S A, DBA Telemecanique
1101 Shiloh Glenn Dr, Suite 100, Morrisville, NC, 27560, US

This certificate confirms that representative samples of:
NKCR7 - Auxiliary Devices Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 60947-1:22, 3rd Ed., Issue Date: 2022-5-31
CSA C22.2 No. 60947-4-1:22, Edition 3, Issue Date 2022-05-31

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

UL Solutions

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.
Form-ULID-019496 – ver 1.0

Public

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-L164353-34519-81802991-10
Report reference: E164353-19920818
Issue Date: 2026-02-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Base provided adapters

Model(s): LA7D

Thermal overload relays

Model(s): LRD33, LR2D33, LR3D33, LRD43, LR2D43, LR3D43 *followed by two digit numbers may be followed by 6 or by A66*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.