Changes to the List of Materials

September 9, 2026

1. Page k-2
    a. Added additional Sediver catalog numbers:
        i. N100/146 DC
        ii. N14/146 DC

August 26, 2026

1. Page aw-1
    a. Added Line Hardware.
2. Pages d-2, aj-1, eb-1, ek-1
    a. Updated Line Hardware catalog numbers.

June 30, 2026

1. Page p-11
    a. Added TE Connectivity
        i. AMPACT BAT

June 18, 2026

1. Page k(3.2)
    a. Added IUSA.

June 10, 2026

1. Pages an-1.2, Uan-1.1, Uan-2
    a. Added Rymel.

June 3, 2026

1. Page Uja-1
    a. Added Gillespie Precast

2. Page p(2)
    a. Added Power Connector Specialties.

March 25, 2026

1. Page k(3.2), ea(4.1)
    a. Added Newell (Gamma-Corona)

March 10, 2026

1. Page U hy-1.2
    a. Added Richards Manufacturing Co.

December 12, 2025

1. Pages sd-1.1, se-1.1
    a. Added Pfiffner
        i. JOF 72, EOF 72

August 25, 2025

1. Page av-2
    a. Added Copperweld.

July 15, 2025

1. Page rp-1.4
    a. Added Power Line Sentry
        i. Catalog number CT-D02.

June 24, 2025

1. Page U hv(1)
    a. Added TELE-FONIKA Kable S.A.

June 20, 2025

1. Pages w-1, eq(2.1), fm-1.1
    a. Added Fiberglass Line Hardware.

May 30, 2025

1. Pages Ugu-1.1, Ugu-2.1
    a. Added API

May 28, 2025

1. Page ea(4.1)
    a. Added MacLean
        i. H0 Series, H7 Series.

May 8, 2025

1. Page av(2)
    a. Added Copperweld

April 22, 2025

1. Pages a(3), ea(4.1)
    a. Added Preformed Line Products

April 21, 2025

1. Pages rp-1.4
    a. Added Preformed Line Products.

February 13, 2025

1. Pages sj-1, sj(1)
    a. Hubbell
        i. Moved BP3 and BPF switches from Conditional page sj(1) to Full Listing page sj-1
        ii. Deleted page sj(1)

February 11, 2025

1. Page rp(1.5)
    a. Added Power Grid Pros.

February 4, 2025

1. page U ja-2
    a. Added APS
        i. FGBP Series

January 23, 2025

1. Pages d-1, d-2
    a. Line Hardware, Inc.

i. Added SWC Series, SWF Series
ii. Moved CSW Series to Technical List

December 17, 2024
1. Pages at-3, rp(1)
    a. Added Central Moloney, Inc.

December 13, 2024
1. Page U he-1
    a. Revised company name “Electrical Equipment” to “Federal Pacific.

October 31, 2024
1. Page av-1
    a. Added Alubar

October 11, 2024
1. Pages z-3, z-5.1, z-6, z(5)
    a. Added Street & Area Lighting (Salco)

June 11, 2024
1. Page k-2
    a. Revised k(1) from Conditional to k-2 Full listings.
    b. Added Hubbell Power Systems.

May 10, 2024
1. Pages x-1, z-5.2, z-6
    a. Added Grip-Tite

April 2, 2024
1. Page be(4.3)
    a. Added Togami Electric Mfg. Co., Ltd.
        i. Single-phase and Three-phase.

March 22, 2024
1. Pages c-1; n-1
    a. Moved Threaded Fasteners, Inc. from Conditional to Full Acceptance.

December 13, 2023
1. Pages u-1; aa, ab
    a. Corrections to Allied Bolt catalog numbers.

December 5, 2023
1. Page af-1.1
    a. Added IUSA
        i. Type C (porcelain), Type C (polymer).

November 1, 2023
1. Page rp(1.4)
    a. Added Celeco®

August 9, 2023
1. Pages bz-1, bz-2

a. Revised Maysteel Trinetics to Hubbell Trinetics.
b. Added VS models.

July 5, 2023

1. Page rp(1.3)
    a. Revised Midsun Group, Inc.
        i. Changed “E/Bushing Full Cover**” to “E/Silicone Wildlife Covers**”.

July 3, 2023

1. Page rp(1.3)
    a. Added Midsun Group, Inc.
        i. E/Flex Barrier*, E/Anti-Nesting Barrier*, E/Bushing Full Cover**

March 27, 2023

1. Page z-5.1
    a. Updated Hubbell catalog numbers.

March 5, 2023

1. Page g(1.3)
    a. Revised Wagner listings to include both 8’ and 10’ arms.

March 1, 2023

1. Page g(1.3)
    a. Added Wagners
        i. Catalog numbers: WGN-S1000, WGN-S3000

November 29, 2022

1. Page be(2.3)
    a. Added Siemens
        i. CMR multi-phase recloser.

August 19, 2022

1. Page U hv(1)
    a. Added LS Cable and System U.S.A., Inc.
        i. (VI) Dow Endurance™ HFDC 4202 EC

July 26, 2022

1. Added page U hv-4
    a. Cable, Underground, 600 Volt Cable (Alternative Cable Constructions)

May 24, 2022

1. Pages U he-1 and U he-2
    a. Added Howard Industries.

April 13, 2022

1. Page eq(2.1)
    a. Added Fiberglass Line Hardware
        i. catalog numbers FLH0-1-15C1 and FLHR-1-15V.

March 25, 2022

1. Section ai – Ground Rods
    a. Revised page numbering for consistency: page ai(1) changed to ai-4; page ai(3) changed to ai-5.

March 24, 2022

1. Page rp(1)
    a. Added Kaddas
        i. Catalog numbers KE1501, KE1182-03, KE1203, KE1077 Rev A, KE1079 Rev B, KE1198, KE1166-01.

February 18, 2022

1. Pages Uhb-1.2 and Uhb-2.2
    a. Moved Richards from page Uhb-1.2 (200A rated) to Uhb-2.2 (600A rated).
    b. Removed page Uhb-1.2.

February 15, 2022

1. Page p-11
    a. Added Richards
        i. Catalog numbers ABWC Series.
2. Pages Uhb-1.2 and Uhb-2
    a. Moved Richards CSH Series from page Uhb-1.2 (200A) to Uhb-2 (600A).

December 2, 2021

1. Pages p-11, ap-1, ap-2
    a. Added AFL.

August 3, 2021

1. Page be(2.3)
    a. Added Siemens
        i. CMR

May 6, 2021

1. Page Ugn-2
    a. Added Aluma-Form
        i. ENC Series

April 27, 2021

1. Page Ugk-2.2
    a. Added Prysmian
        i. PCT Series (15, 25, 35kV)

February 9, 2021

1. Page be(4.3)
    a. Added Southern States single-phase SSR type recloser.

February 4, 2021

1. Pages rp(1), rp(1.2)
    a. Revised “Cantega” to “Hubbell Power Systems”.
    b. Added trademark to Reliaguard.

December 10, 2020

1. Page ap-2
    a. Modified page number from “1.1” to “2”.

November 18, 2020

1. Pages an-3 and an(3.1)
    a. Moved Virginia Transformer from page an(3.1) Conditional to page an-3 Full Acceptance.

November 6, 2020
1. Page ae-1
    a. Added Celeco
        i. Catalog Numbers: HSCEL, RPCEL

October 26, 2020
1. Page Uhb-1.1
    a. Added TE Connectivity
        i. Catalog Numbers: 25 kV, used with loadbreak connectors (without test point) - ELB-25-200 series without jacket seal, ELB-25-200-ES series with jacket seal

October 23, 2020
1. Page p(1)
    a. Added TE Connectivity (Raychem)
        i. Catalog number: TIL Series

September 30, 2020
1. Pages a(3), ea(4), ea(5) – Added new Hendrix insulator models.
    a. Catalog Numbers: HPI-15VTC, HPI-15VTP, HPI-25VTC-02, HPI-35VTC-02, HPI-35VTP-02, HPI-LP-14FS/FA, HPI-LP-16F, HPI-CLP-15, HPI-CLP-17, HPI-CLP-20

July 7, 2020
1. Page cm-2 – Added Aluma-Form, Inc.

June 25, 2020
1. Page an(1.1) - Added additional kVA ratings for Prolec GE.
2. Page an(1.2) – Added Prolec GE for non-porcelain bushings.

May 21, 2020
1. Added Hubbell Power Systems
    a. Page gj(3)

April 20, 2020
1. Pages sd-1.1, se-1.1
    a. Added lnstrument Transformer Equipment Corp (ITEC)

April 15, 2020
1. Pages cg-4
    a. Revised “Bridges Electric” to “Siemens”.
    b. Added note to Siemens:
        i. applies to both polymer and porcelain insulators

March 27, 2020
1. Pages z(2)
    a. Added Watson Anchor.

March 23, 2020
1. Page Uhb-1.2

a. Added Richards Manufacturing CS8 Series cold-shrinkable connector and CHS Series deadbreak elbow.

2. Page Ufz-1
    a. Added Durham Company 9112212 250 Splice-n-Tap

March 13, 2020

1. Page av-1 Conductor, ACSR
    a. Added WTEC

February 11, 2020

1. Added Centelsa
    a. Page av-1 – Conductor, ACSR
    b. Page Uhv-2 – Cable, underground, 600V

February 10, 2020

1. Revised all references of "U-1" to "7 CFR 1728.204".
    a. Pages U hv-1, U hv-1.1, U hv(1).

February 7, 2020

1. Added SAE
    a. Page dh-2 – Pole Ground, Alternative Materials
        i. CD-2W-12, CD-2WC-12, CD-4C-12, CD-2C-12, CD-1/0C-12, CD-2/0C-12, CC25, CC55, CF7000

January 6, 2020

1. Added ConduGround
    a. Page cj(1) - Pole Ground Wire, alternative conductor
    b. Page sr(2) - Conductor for Substation Grounding, alternative conductor

December 26, 2019

1. Revised Malton to American Padmount Systems (APS) listings
    a. Page Ugn-1
        i. Remove MEV Series
    b. Pages U gu-2.1, U ja-2

2. Revise Malton to ABB
    a. Pages U he-1, U he-2, U he-3.2,

September 24, 2019

1. af – Cutout, distribution, open
    a. Added Peak Demand Inc.
        i. Catalog numbers: FCP series (porcelain) and FCS series (polymer).

September 9, 2019

1. w-1 Guy Strain Insulators, fiberglass
    a. Added Preformed Line Products
        i. GSF16 Series and GSF21 Series

August 16, 2019

1. be(4.3) – Recloser, vacuum interrupter with solid dielectric
    a. Added Southern States

2. go-1 – Fault Indicators, overhead
    a. Added Smart Grid Solutions
        i. FI-5A
3. Ugo-1 – Fault Indicators, underground
    a. Added Smart Grid Solutions
        i. FI-3C

July 18, 2019

1. ae-1 – Surge (lightning) Arrester, Distribution Class
    a. Added Celeco
        i. Model PSAMOV-HDDC

June 27, 2019

1. U go – Fault Indicators
    a. Updated catalog number for Horstmann.
    b. Added new Horstmann model 41-2001.

June 19, 2019

1. Uhv(1) Cable, underground
    a. Added General Cable insulation:
        i. (EAM) General Cable EI-4000-LF

May 15, 2019

1. ea(2) – Insulator, post type (Composite/Polymer)
    a. Added new model from K-Line Insulators
        i. KL 28SKG109 (24.9/14.4kV)

2. sb-2 – Switch, disconnect (single-pole, hook operated distribution class)
    a. Added new model from Royal Switchgear
        i. BISL – 15kV thru 25kV

May 14, 2019

1. z(5) – Power Installed Screw Anchors
    a. Added Oklahoma Design Technologies, LLC
        i. STAD Series and CSTAD Series

May 8, 2019

1. z(5) – Power Installed Screw Anchors
    a. Added Cantsink
        i. 1.5RCS Series
2. Uan(1) – Transformers, Distribution, Pad-Mounted, Dead-Front
    a. Added Power Partners
        i. Single-phase 5-167 kVA
3. Uhy-1.1 – Splice, Underground, Permanent
    a. Added new units from TE Connectivity-Energy
        i. Catalog numbers CSJU-1511, CSJU-S-1511, CSJU-2511, CSJU-S-2511

April 24, 2019

1. Uhv(1) – Cable Underground
    a. Added LS Cable
        i. VII insulation without flat strap neutral

April 19, 2019

1. be(2.2) Recloser, vacuum interrupter
    a. Added Eaton
        i. Model NOVA-NXT.
2. Revised all “Cooper Power Systems” to “Eaton”.

April 10, 2019

3. Uhb-1.1 – Cable Accessories
    a. Added TE Connectivity-Energy
        i. Models ELB-15-200 and ELB-15-200-ES.

November 28, 2018

1. y(3) - Conzinal 95% Zinc - 5% Aluminum+ Mischmetal Alloy (AL-ZN-MM) Coated Steel Wire Strands
    a. Added Conex Cable LLC

November 2, 2018

1. y(2) - Zinc - 5% Aluminum - Mischmetal alloy (Zn-5Al-MM) – Coated, Steel Wire Strands
    a. Revised existing listing for Bekaert.
        i. Added additional wire sizes.
            1. (S-M): 1/4", 3/8", & 7/16".
            2. (HS): 9/32”.
            3. (EHS): 9/32”.
        ii. Revised Note to “Class A” coating.

October 23, 2018

1. sj(1) – Switches, oil circuit recloser by-pass
    a. Added Hubbell (Chance)
        i. Type: BPF – 15kV, 27kV
2. sb-2 – Switch, disconnect (single-pole, hook operated distribution class)
    a. Added Hubbell (Chance)
        i. Type: M3C – 15kV, 27kV

August 31, 2018

1. cj-1 Pole Ground Wire
    a. Added sizes for Copperweld Bimetallics, LLC
        i. No 4 AWG Stranded (7x0680”), No. 4 AWG, No. 2 AWG Stranded (7x0860”), No. 2 AWG, 7 No. 10 AWG, 2/0 (19x0860” & 7x1379”)
    b. Revised notes referring to Copperweld Bimetallics, LLC

2. sr-1 Steel Conductor for Substation Grounding, Copper-Clad or Galvanized
    a. Moved from Conditonal [sr(1)] to Full listing [sr-1] Copperweld Bimetallics, LLC
        i. 7 no 8 AWG, 2/0 (19x0860” & 7x1379”), 7 no 7 AWG, 7 no 6 AWG, 7 no 5 AWG, 7 no 4 AWG, 4/0 (19x1055”), 19 no 9 AWG, 19 no 8 AWG, 19 no 7 AWG, 19 no 6 AWG, 19 no 5 AWG
    b. Updated notes referring to Copperweld Bimetallics, LLC.

July 31, 2018

1. af(1) - Cutouts, Distribution, Open with Linkbreak Attachment
    a. Added Hubbell C-Polymer 27kv and 35kV.

July 20, 2018

1. Uhv-1
    a. Removed all listings for Crosslinked Polyethylene (XLP).

i. Plain XLP is no longer an acceptable insulation per RUS standards, 7 CFR 1728F.204 (formerly the U-1 spec).

July 18, 2018

1. Uhv(1) Cable, underground
    a. Added General Cable new tree retardant insulation compound LG XL8080TR (VII).
    b. Added LS Cable & Systems (VIII).

June 12, 2018

1. c-1 Machine Bolts; o-1 Oval Eye Bolts
    a. Added Action Manufacturing

May 21, 2018

1. a-2 Insualtors, Pin type, polymber
    a. Added Aluma-Form
        i. Catalog numbers INS-15-PC-1, 55-3; INS-15-PF-1 55-4; INS-25-PJ-2

May 8, 2018

1. Page rp(1.2) Wildlife Guards
    a. Added Reliaguard

March 20, 2018

1. Page g(1.3) Crossarms, fiberglass
    a. Added new Shakespeare models
        i. Without centermount: MTN, HTN, TTN
        ii. With centermount: STB, MTB, HTB, TTB

March 19, 2018

1. Page sd-1 Current Transformers, Outdoor Type
    a. Added new models for Arteche
        i. Catalog numbers for 0.6kV: IRH-1
        ii. Catalog numbers for 15kV: ME-015, MK-15, MI-015, KM-15, KCB-17
        iii. Catalog numbers for 25kV: ME-025, MK-25, MI-025, KM-25, KCB-24
        iv. Catalog numbers for 34.5kV: CRK-36, CE-034, ME-036, MK-36, KM-36
        v. Catalog numbers for 69kV: CRH-72, CRK-72, CE-069
2. Page se-1 Voltage Transformers, Outdoor Type
    a. Added new models for Arteche
        i. Catalog numbers for 15kV: URJ-17, ME-015, MK-15, MI-015, KM-15, KCB-17
        ii. Catalog numbers for 25kV: URJ-24, VRJ-24, URN-24, VRN-24, ME-025, MK-25, MI-025, KM-25, KCB-24
        iii. Catalog numbers for 34.5kV: ME-036, MK-36, KM-36
        iv. Catalog numbers for 69kV: URU-72, VRU-72

March 9, 2018

1. Page al(1) Ground Wire Staples
    a. Added Fasco
        i. Catalog numbers: EF40-315, EF40-315CU

March 8, 2018

1. Page U gu-1.1 Pedestal, Power (Above-Grade)
    a. Added Nordic Fiberglass additional sizes.
        i. Catalog numbers: PSPX-101830-MG, PHH-152315-MG

February 2, 2018

1. Page n-1 – Bolt, double arming

a. Added Action Manufacturing

December 4, 2017

1. Page z-6 Anchors, Power-Installed Screw, Distribution
    a. Added new units to Hubbell (Chance)
        i. Catalog numbers: C1025006, C1025007, C1025010.

November 17, 2017

2. Page ap-1.1 Clamp, hot line, ACSR with armor rods
    a. Added Aluma-Form
        i. Catalog numbers: AF-BC20, AF-1540, AF-1530

November 2, 2017

1. Page U hv(1) U hv - Cable, Underground, 15 kV and 25 kV Cable
    a. Revised company name “Superior Essex” to “LS Cable & System U.S.A., Inc.”

September 12, 2017

1. Added Page sj(1) Switches, oil circuit recloser by-pass
    a. Added Hubbell (Chance)
        i. Catalog number: BP3 – 600A, 900A

September 8, 2017

1. Page cj-1 Pole Ground Wire
    a. Revised “CommScope BiMetals” to “AFL Copperclad”
        i. Added sizes No. 4 and No. 2
2. Page sr-1 Steel Conductor for Substation Grounding, Copper-Clad or Galvanized
    a. Revised “CommScope BiMetals” to “AFL Copperclad”
        i. Added sizes 19 No. 9 AWG and 19 No. 8 AWG

July 21, 2017

3. Page U he-3.1 Padmounted Switchgear (200 and 600 amp)
    a. Added Elastimold
        i. Type MVS, single-phase and three phase, 200 and 600 amp, 15-38 kV
        ii. Type MVI, single-phase and three phase, 200 and 600 amp, 15-38 kV

July 19, 2017

4. Page ah-1 Tie, insulator, formed type
    a. Added “Alloy Side, Spool and Top Ties” to Preformed Line Products
5. Added Page ea-3 Insulators, post type
    a. Added Eprecsa USA, LLC
        i. catalog numbers: 13PD, 22PD, 33PD

July 7, 2017

6. Page ah-1 Tie, insulator, formed type
    a. Added 3 new products to Preformed Line Products
        i. EZST-series, TT-series and UT-series

June 20, 2017

1. Page sd-1 Current Transformers, outdoor type
    a. Revised company name to “Arteche” from “Arteche USA”.
    b. Added CRF-17 and CRH-36, which were omitted from the original listing.
2. Page se-1 Voltage Transformers, outdoor type

a. Revised company name to “Arteche” from “Arteche USA”.

May 1, 2017

1. Page bx-1.1 Splice, automatic, Distribution
    a. Added 2 new splices to Aluma-Form, Inc. listing.
        i. Cat. #: ASC1020
            1. AAC (1/0 & 2/0), AAAC (1/0 & 2/0), and ACSR (1/0 & 2/0)
        ii. Cat. # ASC3040
            1. AAC (3/0 & 4/0), AAAC (3/0 & 4/0), and ACSR (3/0 & 4/0)

April 26, 2017

1. Pages ah-1 and ah(1) Tie, insulator, formed type
    a. Moved Preformed Line Products “EZ-WRAP” ties from Conditional listing on page ah(1) to Full listing on page ah-1.

April 25, 2017

1. Page Uan-1 Transformers, Distribution, Pad-Mounted, Dead-Front
    a. Added Magnetron S.A.S.
        i. Pad mounted 5-167 kVA transformer series.

LIST OF MATERIALS
Acceptable for Use on Systems of USDA Rural Development Electrification Borrowers

United States Department of Agriculture
Rural Development Utilities Programs
Electric Programs

Informational Publication 202-1
Current as of September 9, 2026

DISCLAIMER

Every effort has been made to ensure the accuracy of this document. However, in case of discrepancies, records of Technical Standards Committee "A" are the authoritative source.

PREFACE

This list supersedes all preceding issues including revisions. Revised sheets reflecting changes in the list will be issued quarterly and should be inserted in order to keep your copy up to date.

The items shown in this publication include material and equipment for transmission and distribution facilities. Items not listed include office equipment, tools and work equipment, items of electric general plant and consumer owned wiring facilities. The listings apply only to new items of material and equipment and not to used items.

In addition to items accepted on a general basis, this list also includes items accepted on a conditional basis. As one of the conditions in the acceptance of an item on a conditional basis, contractors are required to obtain the borrower's concurrence prior to its use.

The inclusion of an item in this list does not indicate that item's manufacturer or its principals have not been debarred, suspended, proposed for debarment, declared ineligible or voluntarily excluded pursuant to Executive Order 12549, Debarment or Suspension, or any rules or regulations issued thereunder, including 7 CFR Part 3017 ("Debarment Regulations"). Therefore, borrowers must comply with the requirements imposed by the Debarment Regulations before entering into any "covered transaction", as defined by 7 CFR Part 3017, involving any item on this list.

The acceptance of an additional item or the deletion of an existing item is a function of the Technical Standards Committees. Any manufacturer desiring to have a new item placed on the list, or any user believing an existing item should be removed from the list, is invited to submit the matter to the Committees. Any communication calling attention to an error or omission in the list, such as a wrong catalog number, an obsolete item, etc., will be appreciated. All communications should be addressed to Technical Standards Committee "A" (Electric), USDA Rural Development Utilities Programs, Stop 1569, Washington, D. C. 20250-1569.

INDEX – PART I

-A-

Air break switches ..... cg
Anchor rod x
Anchor rod bonding clamps ..... ck
Anchor shackle ..... bo
Anchors ..... z
Angle suspension bracket ..... cr
Angle thimble eye bolt ..... ba
Anodes ..... U si
Arm assemblies, narrow profile ..... eq
Armor grip suspension assembly ..... m
Armor grip suspension assembly with socket eye ..... ei
Armor rods ..... bv
Arms, laminated upswept ..... fq
Arresters, surge ..... ae
Automatic and formed type deadends ..... by
Automatic splices ..... bx

-B-

Ball hook ..... eh
Ball, oval eye ..... fp
Ball, Y-clevis ..... ft
Bolt, angle eye (thimble type) ..... ba
  carriage i
  clevis ..... ef
  double arming ..... n
  double upset ..... q
  oval eye ..... o
  eye double arming ..... dy
  machine c
  shoulder eye ..... o
  single upset ..... bs
  thimble eye, angle ..... ba
  straight eye (thimble eye) ..... ao
Brace, crossarm, steel ..... h
  crossarm, fiber reinforced plastic ..... cu
  crossarm, wood ..... cu
  sidearm diagonal ..... ac
  sidearm vertical ..... bb
  special crossarm ..... em
Bracket, angle suspension ..... cr
    cutout and arrester extension ..... fm
    cutout extension ..... fn
    extension ..... fj
    insulated ..... da
    narrow profile ..... eq
    offset neutral ..... ec
    oil circuit recloser ..... fk
    pole top pin ..... cs
    post insulator ..... eb
    swinging angle ..... fu
    transformer ..... dm
    transformer secondary insulated ..... fo

Capacitor hangers ..... fd
Capacitor oil switch ..... bz
Capacitor, shunt ..... fc
Carriage bolt i
Chain link (end link) ..... br
Clamp, anchor rod bonding ..... ck
deadend l
deadend with socket eye ..... ej
ground rod ..... aj
ground wire ..... dp
guy ..... u
hot line ..... ap
loop deadend ..... bn
suspension ..... m
suspension with socket eye ..... ei
Clevis bolt ..... ef
Clevis type wireholder ..... bt
Clevis, conduit, insulated ..... dr
secondary swinging ..... s
service deadend ..... bh
service swinging ..... as
thimble ci
Clip, ground wire ..... al
guy ..... dz
Combination cutout and arrester ..... ax
Combination power fuse and disconnect switch ..... sl
Compression deadends ..... cp
Compression splices ..... cy
Conductor ..... av
Conduit clevis, insulated ..... dr
Conduit wireholder ..... ds
Connector, grounding, transformer ..... bu
hot line ..... fi
Connectors ..... p
Cross brace assembly vx
Crossarm assemblies and arm spacers ..... gj
Crossarm assembly, “Z” type (wishbone) ..... gz
Crossarm assembly, H frame (small angle – 161 & 230 kV) ..... gw
Crossarm assembly, H frame (tangent – 161 & 230 kV) ..... gy
Crossarm brace, sidearm diagonal ..... ac
Crossarm brace, sidearm vertical ..... bb
Crossarm brace, special ..... em
Crossarm brace, steel ..... h
Crossarm brace, wood ..... cu
Crossarm pin, steel ..... f
Crossarm reinforcing plate ..... eg
Crossarm saddle ..... fg
Crossarms ..... g
Current limiting backup fuses ..... ag
Current transformers ..... sd
Cutout and arrester extension bracket ..... fm
Cutout and arrester, combination ..... ax
Cutout extension bracket ..... fn
Cutouts and fuses ..... af

-D-

Deadend clamp l
Deadend clamp with socket eye ..... ej
Deadend for guy strand ..... u
Deadend for steel strand l
Deadend, automatic & formed type ..... by
compression ..... cp
secondary ..... cq
service ..... dt
Disconnect switch, hook operated ..... sb
Double arming bolt ..... n
Double arming eye bolt ..... dy
Double arming plate ..... ct
Double upset bolt ..... q

-E-

Elliptical eye screw ..... dq
End link (chain link) ..... br
Extension link ..... du
Extension link (fiberglass) ..... eu
Eye bolt, double arming ..... dy
oval ..... o
Eye nut ..... aa
Eye screw, elliptical ..... dq

-F-

Fault Indicators ..... go
Fiber reinforced plastic crossarm braces ..... cu
Fuses and cutouts ..... af
Fuses, current limiting, backup ..... ag
power, substation ..... af

-G-

Gain, pole ..... bi
Grid gain ..... bi
Ground rod clamp ..... aj
Ground rods ..... ai
Ground wire clamp ..... dp
Ground wire clip ..... al
Ground wire staple ..... al
Ground wire support, overhead ..... ed
Ground wire, pole ..... cj
Ground, pole ..... dh
Grounding conductor, substation, coated steel ..... sr
Grounding connector, transformer ..... bu
Guy attachment (Distribution) v
Guy attachment (Transmission) ..... fv
Guy clamp ..... u
Guy clip ..... dz
Guy deadend ..... u
Guy hook ..... bj
Guy marker ..... at
Guy plate ..... bk

Guy strain insulator ..... w
Guy wire ..... y
Guy wire clip ..... dz
Guying plate ..... fv

-H-

H frame crossarm assembly (small angle – 161 & 230 kV) ..... gw
H frame crossarm assembly (tangent – 161 & 230 kV) ..... gy
Hangers, capacitor ..... fd
Hook, ball ..... eh
guy ..... bj
Hook operated disconnect switch ..... sb
Hot line clamp ..... ap
Hot line connector ..... fi

-I-

Insulated bracket ..... da
Insulator and stud, post type ..... ea
Insulator, guy strain ..... w
pin type ..... a
polymer distribution deadend ..... k
spool ..... cm
suspension ..... k

-K-

Keys, pole ..... z

-L-

Laminated upswept arms ..... fq
Lag screw ..... j
Link, chain (end link) ..... br
extension ..... du
extension (fiberglass) ..... eu
Locknuts ..... ek
Loop deadend clamp ..... bn

-M-

Machine bolt c
Marker, guy ..... at
Meter sockets ..... gb
Meters, watthour ..... ga

-N-

Narrow profile brackets and arm assemblies ..... eq
Neutral bracket, offset ..... ec
Numbers, pole and letters ..... az
Nut, eye ..... aa
thimble eye ..... ab

-O-

Offset neutral bracket ..... ec
Oil circuit recloser bracket ..... fk
Oil circuit reclosers ..... be
Oval eye ball ..... fp
Oval eye bolt ..... o
Oval tube splice cx
Overhead ground wire support ..... ed

-P-

Pin type insulator ..... a
Pin, crossarm ..... f
  pole top, steel ..... b
Pipe spacer ..... dl
Plastic wire guard ..... er
Plate, crossarm reinforcing ..... eg
  double arming ..... ct
  guy ..... bk
  pole bearing ..... fs
  pole eye v
Pole bearing plate ..... fs
Pole eye plate v
Pole gain ..... bi
Pole ground ..... dh
Pole ground wire ..... cj
Pole keys ..... z
Pole numbers and letters ..... az
Pole top pin bracket ..... cs
Pole top pin, steel ..... b
Post insulator bracket ..... eb
Post type insulator and stud ..... ea
Power fuses, substation ..... af
Primary metering rack ..... fl

-R-

Rack, primary metering ..... fl
Reclosers, automatic circuit ..... be
Regulator by-pass switch ..... sk
Regulators, voltage ..... sc
Rod, anchor x
Rods, armor ..... bv
  ground ..... ai

-S-

Saddle crossarm ..... fg
Screw, elliptical eye ..... dq
  lag ..... j
Secondary swinging clevis ..... s
Sectional ground rods ..... ai
Sectionalizer ..... el
Service deadend ..... dt
Service deadend clevis ..... bh
Service swinging clevis ..... as

Shackle, anchor ..... bo
Shoulder eye bolt ..... o
Shunt capacitors ..... fc
Sidearm diagonal crossarm brace ..... ac
Sidearm vertical crossarm brace ..... bb
Single upset bolt ..... bs
Sockets, meter ..... gb
Spacer, pipe ..... dl
Special crossarm braces ..... em
Splice cover, plastic ..... es
Splice for steel strand ..... cz
Splice, automatic ..... bx
    compression ..... cy
    formed type ..... ex
    oval tube cx
Spool Insulator ..... cm
Spring washer ..... aw
Staple, ground wire ..... al
Steel strand ..... y
Structure assembly (small angle – 161 & 230 kV) ..... gw
Structure assembly (tangent – 161 & 230 kV) ..... gy
Substation grounding conductor, coated steel ..... sr
Support, overhead ground wire ..... ed
Surge arresters ..... ae
Suspension clamp ..... m
Suspension clamp with socket eye ..... ei
Suspension insulator ..... k
Swinging angle bracket ..... fu
Switch, capacitor oil ..... bz
    combination power fuse and disconnect ..... sl
    hook operated disconnect ..... sb
    pole top air break ..... cg
    recloser, by-pass ..... sj
    regulator by-pass ..... sk

-T-

Thimble clevises ci
Thimble eye bolt, angle ..... ba
Thimble eye bolt, straight ..... ao
Thimble eye nut ..... ab
Tie, insulator, formed type ..... ah
Transformer bracket ..... dm
Transformer grounding connector ..... bu
Transformer secondary bracket, insulated ..... fo
Transformers, current ..... sd
        pole and power ..... an
        voltage ..... se

-V-

Vacuum circuit reclosers ..... be
Voltage regulators ..... sc
Voltage transformers ..... se

-W-

Washer, spring ..... aw
Washers ..... d
Watthour meters ..... ga
Wildlife guards ..... rp
Wire guard, plastic ..... er
Wire, guy ..... y
Wireholder ..... ar
Wireholder, clevis type ..... bt
conduit ..... ds
Wood crossarm brace ..... cu

-Y-

Y-clevis ball ..... ft

-Z-

“Z” type (wishbone) crossarm assembly ..... gz

INDEX – PART II

Underground Distribution Equipment

Anodes ..... U si
Arrester, surge ..... U ae
Boot, insulated ..... U gq
Bracket, combination ..... U hj
    pothead mounting ..... U hd
Cable ..... U hv
Cable accessories ..... U hb
Cable route marker ..... U hx
Cable support ..... U hc
Combination cutout and arrester ..... U ax
Connector block, secondary ..... U gp
    transformer ..... U fz
Connector, secondary tap ..... U fw
Cutout and arrester, combination ..... U ax
Enclosure, equipment ..... U gn
Fault indicator ..... U go
Heat shrink tubing ..... U hr
Jacketed cable restoration kits ..... U hf
Pad, equipment ..... U ja
Pedestal, power ..... U gu
Recloser, pad-mounted ..... U be
Regulator, voltage, pad-mounted ..... U sc
Safety signs ..... U hw
Secondary tap connector ..... U fw
Secondary tap or splice cover ..... U hr
Shield, cable riser ..... U gc
    splice ..... U jb
Splice shield ..... U jb
Splice, secondary ..... U gp
    underground ..... U hy
Stake, power pedestal ..... U gv
Switch, air, group-operated ..... U cg
Switchgear, padmounted ..... U he
Terminations, elbow ..... U hp
    multipoint ..... U hq
    outdoor and indoor ..... U gk
Terminator sealing kit ..... U hf
Transformer connector block ..... U fz
Transformer pad ..... U ja
Transformer, current ..... U sd
Transformers ..... U an
Tubing, heat shrink ..... U hr

a – Insulator, pin type, porcelain

ANSI Class	55-2	55-3	55-4
Application	5 kV	12.5/7.2 kV and 13.2/7.62 kV systems	12.5/7.2 kV and 13.2/7.62 kV systems (where greater insulation is needed)
Pinhole diameter	1 in.	1 in.	1 in.
ICB	ICB 552	ICB 553	ICB 554
Porcelain Products (Knox)[2]	253	261-S	366-S
Victor Insulators, Inc.	8	5, VI 605R	6, VI 606R
Gamma Insulators Corp.	6188R-70	6184R-70	6183R-70
ANSI Class	56-1	56-3	56-4
Application	24.9/14.4 kV distribution lines	33 – 34.5 kV transmission lines	44 – 46 kV transmission lines
Pinhole diameter	1-3/8 in. Metal thimble (unless noted)	1-3/8 in. Metal thimble	1-3/8 in. Metal thimble
ICB	ICB 561	-	-
IUSA[1]	P-3000	-	-
Porcelain Products (Knox)	-	2045-S	-
Victor Insulators, Inc.	27-R[1], VI 627R	245-R, VI 645R	255-R
Gamma Insulators Corp.	8248R-70	8190R-70	-

[1]Does not have a metal thimble.
[2]ANSI class 55-2, 55-3, and 55-4 pin insulators manufactured at both the Knoxville and Macomb plants are acceptable.

a – Insulators, pin type, polymer

Manufacturer	Catalog Number	ANSI Class
Advanced Rubber Products	ARP-SKPI-55-3	55-3
	ARP-SKPI-56-1	56-1
Aluma-Form	INS-15-PC-1	55-3
	INS-15-PF-1	55-4
	INS-25-PH-2	56-1
Hendrix	HPI-55-3	55-3
	HPI-55-4	55-4
	HPI-25-J-02	56-1
Preformed Line Products	IP-15-C	55-3
	IP-15-F	55-4
	IP-25-J2	56-1

a – Insulators, pin type, composite, vise top

Manufacturer	Catalog Number	ANSI Class	Conditions
Hendrix			
	HPI-15VTC	55-4	To Obtain Experience. For use with Conductor Diameters of 1.75 inches or less.
	HPI-15VTP	55-4	
	HPI-25VTC-02	56-1	
	HPI-35VTC-02	55-7	
	HPI-35VTP-02	55-7	
Preformed Line Products	IP-15-VTU	55-3, 55-4	To Obtain Experience.
	IP-15-VTN	55-3, 55-4	
	IP-15-VTC	55-3, 55-4	
	IP-15-PVTU	55-3, 55-4	
	IP-15-PVTN	55-3, 55-4	
	IP-15-PVTC	55-3, 55-4	
	IP-25-VTU2	56-1	
	IP-25-VTN2	56-1	
	IP-25-VTC2	56-1	
	IP-25-PVTU2	56-1	
	IP-25-PVTN2	56-1	
	IP-25-PVTC2	56-1	
	IP-35-VTU2	55-7	
	IP-35-VTN2	55-7	
	IP-35-VTC2	55-7	
	IP-35-PVTU2	55-7	
	IP-35-PVTN2	55-7	
	IP-35-PVTC2	55-7	

b – Pin, pole top, steel

DISTRIBUTION

	12.5/7.2 or 13.2/7.62 kV	24.9/14.4 kV
Pin length, inches:	20	20
Thread diameter, inches:	1	1-3/8
Hole spacing, inches:	8	8
RUS Specification:	D-3	DT-3
Hubbell (Chance)	2199	2195
Joslyn	J740	J720
Kortick	-	K8086
MacLean (Continental)	U36606F-REA	U36652

Pins listed below have 4-1/2” offset which eliminates the use of Item cs

Hubbell (Chance)	C206-0271
Joslyn	J25179
MacLean (Continental)	U36549

TRANSMISSION

Pin Length, inches:	24
Thread diameter, inches:	1-3/8
Hole spacing, inches:	8
RUS Specification:	DT-3
Hubbell (Chance)	2196
Kortick	K8087
MacLean (Continental)	U36653F

NOTE

1. Flared type pins may be mounted with either side against the pole.

Conditional List
b(1)
January 2015

b – Pin, pole-top
(Non-lead threads)

Manufacturer	Conditions
Hubbell Power Systems 2195P (1-3/8” threads) 2199P (1” threads)	To obtain experience.
Hughes Brothers 2770-A20-100 (1” threads) 2770-A20-130 (1-3/8” threads)	To obtain experience.
Joslyn J740Z (1” threads) J720Z (1-3/8” threads)	To obtain experience.

b – Pin, Fiber-reinforced plastic pole top

Manufacturer	Conditions
Joslyn 7581-624NT (1” threads)* 7581-624XNT (1-3/8” threads)*	To obtain experience.

* Add suffix LT (less tabs) if for steel pole.

c – Bolt, machine

Applicable Specification: ANSI C135.1, “Standards for Galvanized Steel Bolts and Nuts” except that the lengths are in the ranges given below.

Applicable Sizes:

½-inch diameter, 6 through 10-inch length
5/8-inch diameter, 6 through 24-inch length
¾-inch diameter, 6 through 26-inch length
7/8-inch diameter, 6 through 28-inch length

The following manufacturers have shown compliance with the applicable specifications for machine bolts:

Action Manufacturing
Allied Bolt, Inc.
Hughes Brothers
* Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)
* Portland Bolt & Manufacturing Company
The Rockford Bolt & Steel Company
Steel City Bolt & Screw Co., Inc.
Threaded Fasteners, Inc.

*”Static proof” design available.

d – Washers, Flat

Flat Rolled Steel

Size, inches: Thickness, in.: Hole Diam., in.:	2-1/4 x 2-1/4 3/16 13/16	3 x 3 ¼ 13/16	4 x 4 3/16 13/16	4 x 4 ½ 13/16	1-3/8 round 12 gauge 9/16	1-3/4 round 10 gauge 11/16
Allied Bolt, Inc.	11550	11551	11557	-	104	1103
C & C Spacer	4	-	-	-	-	-
FWC	FW1076	-	FW1080	-	FW1086	FW1088
Hubbell (Chance)	6814	6817	6818	6819-1/2	6803	6805
Hughes	SW2-1/4-70-3/16	SW3-70	SW4-70	SW4-70(1/2)	RW1-3/8-50	-
Joslyn	J1076	J1079	J1080	-	J1086	J1088
Kortick	K1553	K1555	K1557	K1559-1/2	K1524	K1525
Line Hardware	SWF Series	SWF Series	SWF Series	-	-	-
MacLean (Continental)	U5485	U5487A	U5488	U5490A	U5478	U5479
Wrought Washer	011206	-	-	-	-	-

Flat Cast

Size, inches: Thickness, in.: Hole Diam., in.:	3 x 3 ¼ 13/16
Hubbell (Chance) (N)	BB214
Joslyn (Flagg) (N)	P56A

Spurred – 3” Round, 3/16” Thick, 13/16” Hole

MacLean (Continental)	TCSF-30-6

(A) Aluminum Alloy (M) Malleable Iron (N) Nodular Iron

d – Washers, Curved

Curved Cast

Size, inches:	2-1/4 x 2-1/4	3 x 3	3 x 4	4 x 4
Thickness, in.:	¼	5/16	7/16	½
Hole Diam., in.:	11/16	11/16	15/16	13/16
Hubbell (Chance) (N)	GCW1A	GCW31	CRW4A	GCW41
Joslyn (Flagg) (M)	P141	P143	P120	P144
Line Hardware (M)	SWC Series	SWC Series	SWC Series	SWC Series
MacLean (Bethea)	-	WC-33-5	WC-34-7	WC-44-6
MacLean (Continental)	-	CW-33	CW-34	CW-44
M.D. Henry Company, Inc. (A)	UW-225	UW-335	UW-347	UW-446

(A) Aluminum Alloy (M) Malleable Iron (N) Nodular Iron

Curved Rolled Steel

Sizes, inches:	4 x 4(1)
Thickness, in.:	¼
Hole Diam., in.:	15/16
Joslyn (Steel)	J6829
Line Hardware, Inc.	SWC Series

1. To be used only on transmission systems.

f – Pin, crossarm
(With square washer, nut and MF locknut)

DISTRIBUTION

Thread (inches diam.)	1	1-3/8	1	1-3/8
Length above base (in.)	5	7	5	7
Length below base (in.)	5-3/4	7	1-1/2	1-3/4
Shank (inches diam.)	5/8	5/8	5/8	¾
	Long Shank		Short Shank	
Hubbell (Chance)	881	4717	886	-
Joslyn	J203	J647	J221	J630
Kortick	K7104	K7611	K7122	K7631
MacLean (Continental)	U558	U3137A	U579	U3142

Clamp Type Pin

Thread (inches diam.)	1	1-3/8
Length above base (in.)	5-3/4	7
Hubbell (Chance)	14322	14322-1
Joslyn	J3322	J3324

Washer Plate for Clamp Type Pin

These plates are equipped with lugs to prevent slippage of pin along crossarm. They may be used to replace the bottom plate on pins already installed.

Hubbell (Chance)	450091

f – Pin, crossarm
(With square washer, nut and locknut)

TRANSMISSION

Thread (inches diameter)	1-3/8	1-3/8
Length above base (inches)	10	10
Length below base (inches)	7	1-3/4
Shank (inches diameter)	¾	¾
	Long Shank	Short Shank
Hubbell (Chance)	4332	-
Joslyn	J610	J633
Kortick	K7643	K7635
MacLean (Continental)	U3140	U3145

f – Pin, crossarm
(Non-lead threads)
(With square washer, nut and MF locknut)

Manufacturer	Conditions
Hubbell	
881P – 1” thread, 5 ¾” shank	To obtain experience.
886P – 1” thread, 1 ½” shank	
Hughes Brothers	
2775-A5-3/4, 1” thread, 5-3/4” shank	To obtain experience.
Joslyn	
J203Z, 1” thread, 5-3/4” shank	To obtain experience.
J221Z, 1” thread, 1-1/2” shank	
J647Z, 1-3/8” thread, 7” shank	
J630Z, 1-3/8” thread, 1-3/4” shank	

Conditional List
g(1)
April 2016

g – Crossarms, fiberglass

Manufacturer	Description	Conditions
Aluma-Form, Inc.*		
FTA20-4-96	8’	To obtain experience.
FTA20-6-96	8’	
FTA20-6-120	10’	
FTA25-4-96	8’	
FTA25-6-96	8’	
FTA25-6-120	10’	
FTA30-4-96	8’	
FTA30-6-96	8’	
FTA30-6-120	10’	
Creative Pultrusions, Inc.		To obtain experience.
Braced Application		
MT30962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
MT30962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
MT31202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT40962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT40962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT41202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT60962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT60962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT61202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT80962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT80962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT81202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
Braceless (centermount) Application		
MT30962I (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
MT30962I (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
MT31202I (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT40962D (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT40962D (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT41202D (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT60962M (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT60962M (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT61202M (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT80962P (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT80962P (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT81202P (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	

Conditional List
g(1.1)
April 2016

g – Crossarms, fiberglass

Manufacturer	Description	Conditions
Geotek (PUPI)		
Braced Application		
T220009603X (with horizontal bushing at center hole)	8’ Type-3 Drill Pattern	To obtain experience.
T220009604X (with horizontal bushing at center hole)	8’ Type-4 Drill Pattern	
T220012005X (with horizontal bushing at center hole)	10’ Type-5 Drill Pattern	
T200009603X	8’ Type-3 Drill Pattern	
T200009604X	8’ Type-4 Drill Pattern	
T200012005X	10’ Type-5 Drill Pattern	
T300009603X	8’ Type-3 Drill Pattern	
T250009603X	8’ Type-3 Drill Pattern	
T250009604X	8’ Type-4 Drill Pattern	
T250012005X	10’ Type-5 Drill Pattern	
T300009604X	8’ Type-4 Drill Pattern	
T300012005X	10’ Type-5 Drill Pattern	
Braceless (Centermount) Application		
TZ220209603X	8’ Type-3 Drill Pattern	To obtain experience.
TB220009603X	8’ Type-3 Drill Pattern	To obtain experience.
TB220009604X	8’ Type-4 Drill Pattern	
TB220012005X	10’ Type-5 Drill Pattern	
TB200009603X	8’ Type-3 Drill Pattern	
TB200009604X	8’ Type-4 Drill Pattern	
TB200012005X	10’ Type-5 Drill Pattern	
TB300009603X	8’ Type-3 Drill Pattern	
TB250009603X	8’ Type-3 Drill Pattern	
TB250009604X	8’ Type-4 Drill Pattern	
TB250012005X	10’ Type-5 Drill Pattern	
TB300009604X	8’ Type-4 Drill Pattern	
TB300012005X	10’ Type-5 Drill Pattern	
TZ220209604X	8’ Type-4 Drill Pattern	
TZ220212005X	10’ Type-5 Drill Pattern	

*May be used in Braceless or Braced Application.

g – Crossarms, fiberglass

Manufacturer	Description	Conditions
MacLean Power Systems		
Braced Application		
PW08REA003	8’ Type-3 Drill Pattern	To obtain Experience
PW08REA004	8’ Type-4 Drill Pattern	
PW08REA005	8’ Type-5 Drill Pattern	
PX08REA003	8’ Type-3 Drill Pattern	To obtain Experience
PX08REA004	8’ Type-4 Drill Pattern	
PX10REA005	10’ Type-5 Drill Pattern	
Braceless (Centermount) Application		
PW08ST003	8’ Type-3 Drill Pattern	To Obtain Experience
PW08ST004	8’ Type-4 Drill Pattern	
PW10ST005	10’ Type-5 Drill Pattern	
PX08ST003	8’ Type-3 Drill Pattern	To obtain Experience
PX08ST004	8’ Type-4 Drill Pattern	
PX10ST005	10’ Type-5 Drill Pattern	
Powertrusion International, Inc.		To obtain experience.
Braced Application		
PST08001NR03	8’ Type-3 Drill Pattern	
PST08001NR04	8’ Type-4 Drill Pattern	
PST10001NR05	10’ Type-5 Drill Pattern	
PHT08001NR03	8’ Type-3 Drill Pattern	
PHT08001NR04	8’ Type-4 Drill Pattern	
PHT10001NR05	10’ Type-5 Drill Pattern	
Braceless (Centermount) Application		To obtain experience.
PST08001BR03	8’ Type-3 Drill Pattern	
PST08001BR04	8’ Type-4 Drill Pattern	
PST10001BR05	10’ Type-5 Drill Pattern	
PHT08001BR03	8’ Type-3 Drill Pattern	
PHT08001BR04	8’ Type-4 Drill Pattern	
PHT10001BR05	10’ Type-5 Drill Pattern	

*May be used in Braceless or Braced Application.

Conditional List
g(1.3)
March 5, 2023

g – Crossarms, fiberglass

Manufacturer	Description	Conditions
Shakespeare		
without Center Mount		To obtain experience.
STN096N0040(X)**	8’ Type-3 Drill Pattern	
STN096N0060(X)**	8’ Type-4 Drill Pattern	
STN120N0060(X)**	10’ Type-5 Drill Pattern	
MTN096N0040(X)**	8’ Type-3 Drill Pattern	
MTN096N0060(X)**	8’ Type-4 Drill Pattern	
MTN120N0060(X)**	10’ Type-5 Drill Pattern	
HTN096N0040(X)**	8’ Type-3 Drill Pattern	
HTN096N0060(X)**	8’ Type-4 Drill Pattern	
HTN120N0060(X)**	10’ Type-5 Drill Pattern	
TTN096N0040(X)**	8’ Type-3 Drill Pattern	
TTN096N0060(X)**	8’ Type-4 Drill Pattern	
TTN120N0060(X)**	10’ Type-5 Drill Pattern	
with Center Mount		To obtain experience.
STB096N1240(X)**	8’ Type-3 Drill Pattern	
STB096N1260(X)**	8’ Type-4 Drill Pattern	
STB120N1260(X)**	10’ Type-5 Drill Pattern	
MTB096N1240(X)**	8’ Type-3 Drill Pattern	
MTB096N1260(X)**	8’ Type-4 Drill Pattern	
MTB120N1260(X)**	10’ Type-5 Drill Pattern	
HTB096N1240(X)**	8’ Type-3 Drill Pattern	
HTB096N1260(X)**	8’ Type-4 Drill Pattern	
HTB120N1260(X)**	10’ Type-5 Drill Pattern	
TTB096N1240(X)**	8’ Type-3 Drill Pattern	
TTB096N1260(X)**	8’ Type-4 Drill Pattern	
TTB120N1260(X)**	10’ Type-5 Drill Pattern	

(**X=2-gray color or 5-dark bronze color)

DIS-TRAN Wood Products, LLC		
CTLBC Series, CTSBC Series, CTHBC Series, CTLBB Series, CTSBB Series, CTHBB Series,	8’ Type-3 and Type-4, 10’ Type-5 Drill Pattern	To obtain experience.
Wagners		To obtain experience.
WGN-S1000	8’ or 10’	
WGN-S3000	8’ or 10’	

Note: Gripping studs or teeth on clamp type crossarm pins (item f) should not be installed against the surface of the fiberglass crossarms.

g – Crossarms, composite

Manufacturer	Description	Conditions
Petroflex North America, Inc.		
Braced Application		
CA-8(X)** (**X=B for black color X=G for grey color)	8’ Type-4 Drill Pattern	To obtain experience.

h – Brace, crossarm, steel

Wherever item “h” is shown on a construction drawing, use a brace from page cu.

i – Bolt, carriage

Applicable Specification: ANSI C135.1, “Standard for Galvanized Steel Bolts and Nuts.”

Applicable Sizes: 3/8 inch diameter, 3 through 6 inch length
½2 inch diameter, 3 through 6 inch length

The following manufacturers have shown compliance with the applicable specifications for carriage bolts.

Allied Bolt, Inc.
Hubbell (Chance)
Hughes Brothers
Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)
The Rockford Bolt & Steel Company

j – Screw, lag

Applicable Specifications: ANSI C135.3 “Standard for Zinc Coated Ferrous Lag Screws”

Applicable Sizes:
1/2 inch diameter, 4 inch length
1/2 inch diameter, 5 inch length
5/8 inch diameter, 4 inch length
5/8 inch diameter, 5 inch length

The following manufacturers have shown compliance with the applicable specifications for lag screws:

Allied Bolt, Inc.
Hubbell (Chance)
Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)

k – Insulators, suspension

ANSI Class Type	52-9A Clevis	52-1 Clevis	52-4 Clevis	52-3 Ball & Socket
Disc Diameter	4-1/4”	6”	9” or 9-1/2”	9” or 9-1/2”
M & E Rating, lbs.	10,000	10,000	15,000	15,000
Leakage	6-3/4”	7”	11-1/2”	11-1/2”
Flashover, kV: Dry	60	60	80	80
Flashover, kV: Wet	30	30	50	50
NOTES	(3) (4)	(3) (4)	(5)	(2)

Manufacturer	Catalog Number			
ICB	ICB 529-A	ICB 521	-	-
Lapp	-	-	9100	9000
Locke	16044	16583	15S410	15S409
Gamma Insulators Corp.	6815-70	6605-70	8265 8267	8255 8256 8257
Sediver	CT-4R2-M	-	-	-
Victor Insulators, Inc.	817	804	-	-

ANSI Class Type	52-3 Ball & Socket	52-4 Clevis	52-5 Ball & Socket	52-6 Clevis
Disc Diameter	10”	10”	10”	10”
M & E Rating, lbs.	15,000	15,000	25,000	25,000
Leakage	11-1/2”	11-1/2”	11”	11”
Flashover; kV: Dry	80	80	80	80
Flashover, kV: Wet	50	50	50	50
NOTES	(2)	(1)	(2)	-

Manufacturer	Catalog Number			
GEC Alsthom	-	105452	-	-
Lapp	8200	8100	301425	2300
Locke	-	20S580	-	30S257
Gamma Insulators Corp.	-	-	8258	-
Porcelain Prod. (Knox)	81022	81012	-	-
Sediver	-	CT-8R2	-	-

Notes:

(1) Use two for 24.9/14.4 kV deadends.
(2) To be used only on transmission lines.
(3) To be used only on distribution lines.
(4) Use two insulators for 12.5/7.2 kV deadends and three for 24.9/14.4 kV deadends.
(5) Use two insulators for 24.9/14.4 kV deadends.

k – Insulator, suspension, Toughened Glass

Manufacturer

Sediver

10” suspension insulator
N-8R2 (ball & socket, 20,000 lbs.)
CT-14R2 (clevis, 30,000 lbs.)
N-14R2 (ball & socket, 30,000 lbs.)
N100/146 DC
N14/146 DC

Hubbell Power Systems

10” suspension insulator
PSN70146 (ball & socket, 15,000 lbs.)
PSN100146 (ball & socket, 22,000 lbs.)
PSN12146 (ball & socket, 25,000 lbs.)
PSN14146 (ball & socket, 30,000 lbs.)

11” suspension insulator
PSN160146 (ball & socket, 36,000 lbs.)
PSN180146 (ball & socket, 40,000 lbs.)
PSN21156 (ball & socket, 50,000 lbs.)

Conditional List
k(3)
February 2015

k – Insulator, polymer distribution deadend

Manufacturer	Conditions
Aluma-Form DEI-15 DEI-28 DEI-25/35 DEI-35	1. To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.
Advanced Rubber Products* ARP-15EACE-I (EPDM – 15 kV) ARP-25EACE-I (EPDM – 25 kV ARP-35EACE-I (EPDM – 35 kV) ARP-15SKCE-S (Silicone – 15 kV) ARP-15SKCE-A (Silicone – 15 kV) ARP-25SKCE-S (Silicone – 25 kV) ARP-27SKCE-SSI (Silicone – 25 kV) ARP-35SKCE-S (Silicone – 35 kV) * A = Aluminum end-fitting, I = Cast iron end-fitting, S = Steel end-fitting	Same as above.
Dulmison H-15 kV-4 H-25 kV-6	Same as above.
GLP DS-15 (15 kV) DS-28 (25 kV)	
IUSA ASSI-15-70 (15 kV) ASSI-25-70 (25 kV) ASSI-35-70 (35 kV)	Same as above.
Hubbell (Ohio Brass) Veri*Lite PDI 401015-0215 (15 kV) 401025-0215 (25 kV) 401028-0215 (25kV) (DS-28) 401035-0215 (35 kV) 401046-0215 (35 kV) DS-46)	Same as above.
K-Line KL-15ASCTM (15 kV line-to-line) KL-28ASCTM (25 kV line-to-line) KL-35SCTM (35 kV line-to-line)	Same as above.
MacLean (Reliable) DS-15G (15 kV) DS-15M (15 kV) (metal end fittings) DS-28G (25 kV) DS-28M (25 kV) (metal end fittings) DS-35G (35 kV) DS-35M (35 kV) (metal end fittings)	Same as above.

NOTE: When insulators from this page are used, adjust construction drawing material list quantities as necessary. Recommended maximum working load is 5,000 lbs.

Conditional List
k(3.1)
November 2015

k – Insulator, polymer distribution deadend

Manufacturer	Conditions
Porcelain Products PDEI-15, 15 kV PDEI-25, 25 kV	1. To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.
Pyungil Co. Ltd DN15SD-CT, 15kV DN28SD-CT, 28kV DN35SD-CT, 35kV	Same as above.
Salisbury 9501U-SI (silicone – 15 kV) 9502U-SI (silicone – ANSI DS-28) 9503U-SI (silicone – 35 kV) 9502L-EP (silicone – 25 kV)	Same as above.
Sediver ODI-11-70-15 (15 kV) ODI-15-70-28 (25 kV) ODI-17-70-35 (35 kV)	Same as above.
Victor Insulators, Inc. 8015 (15kV) 8025 (25kV) 8035 (35kV) 8215 (15kV) 8225 (25kV) 8235 (35kV)	Same as above.
Volt Tek 1515-00 (EPDM – 15 kV) 2515-00 (EPDM – 25 kV) 3515-00 (EPDM – 35kV) 1515S-00 (Silicone – 15kV) 2515S-00 (Silicone – 28kV) 3515S-00 (Silicone – 35kV)	Same as above.
Electroporcelana Gamma S.A. PS015 (15kV) PS025 (25kV) PS035 (35kV)	1. To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.

NOTE: When insulators from this page are used, adjust construction drawing material list quantities as necessary. Recommended maximum working load is 5000 lbs.

Conditional List
k(3.2)
June 18, 2026

k – Insulator, polymer distribution deadend

Manufacturer	Conditions
Newell (Gamma-Corona) NCDS015 (PS015) NCDS028 (PS025) NCDS035 (PS035)	1.)To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.
IUSA 339072 (15kV) 339073 (25kV) 339074 (35kV)	(Same as Above)

NOTE: When insulators from this page are used, adjust construction drawing material list quantities as necessary. Recommended maximum working load is 5000 lbs.

I – Clamp, deadend

DISTRIBUTION

Copper 2 through 6 CWC 4A through 8A		ACSR (Aluminum Clamps) 4/0 & 3/0	2/0	1/0	2&4
-	AFL	302	302	302	302
80500-2000	Hubbell (Anderson)	PG-57N	PG46N	PG-46N	PG-46N
-	C & R	CR-20-90	CR-10-90	CR-10-90	CR-10-90
-	Lapp	306120N	306118N	306118N	306118N
-	MacLean (Bethea)	DA-20N	DA-15-N	DA-15-N	DA-15-N

I – Deadend for steel strand (overhead ground wire)

TRANSMISSION

For high strength, extra high strength steel strand and aluminum clad steel strand

	High Strength Steel		Aluminum-clad steel			Extra High Strength		
Manufacturer	3/8”	7/16”	7 No. 9 AWG	7 No. 8 AWG	7 No. 7 AWG	5/16”	3/8”	7/16”
Compression Type								
AFL	4620.12	4627.14						
Burndy	YTW375E	YTW438E	YTW7M9T	YTW7M8T	YTW7M7T			
Hubbell (Fargo)	861255	861430	861225	861227	861430	861022	861225	861430
Formed Type*								
Helical Line Prod.	HG210-3/8	HG211-7/16	HG523-12.5M	HG525-16M	HG528-20M	HG209-5/16	HG210-3/8	HG211-7/16
Hubbell (Chance)				16M-AWTLG	20M-AWTLG			
Automatic Type								
Hubbell (Fargo)	GDE-302	GDE-303	GDE-302	GDE-302	GDE-303	GDE-301	GDE-302	GDE-303
MacLean (Reliable)	5202	5203	5202	5202	5203	5201	5202	5203
Clamp Type								
MacLean (Continental)	FQD-55-3LW	FQD-55-3-LW						
Hubbell (Anderson)	SWDE-55N	SWDE-55N						
MacLean (Bethea)	FD-550-N							

* Class B galvanizing. When overhead ground wire has Class C galvanizing, formed deadend should also have Class C galvanizing.

l – Clamp, deadend

DISTRIBUTION

2-Bolt Straight Line, Aluminum Alloy*

Manufacturer	Conditions
Burndy Aluminum alloy deadend Catalog No. CUW26RE-1 (#2-2/0 Str. Aluminum, #4-2/0 ACSR)	1. To obtain experience. 2. Applications limited to replacements under hot line conditions.
C & R Products Catalog No. CRDE-10-180 (#4 – 2/0 ACSR) Catalog No. CRDE-20-180 (3/0 – 4/0 ACSR)	Same as above.
Hubbell (Anderson) Aluminum alloy deadend Catalog No. ADSO-88(#2-1/0 ACSR) Catalog No. ADS-48-N (2/0 ACSR) Catalog No. ADS-60-N (3/0 ACSR)	Same as above.
Hubbell (Chance) Aluminum alloy deadend Catalog No. SDF10A (4 through 4/0 ACSR)	Same as above.
Hubbell (Fargo) Aluminum alloy deadend Catalog No. GD-961A side opening keeper (No. 4 and No. 2 ACSR) Catalog No. GD-972A (2/0, 3/0, 4/0 ACSR)	Same as above.
MacLean (Bethea) Aluminum alloy deadend Catalog No. ASO-684-2 (1/0, 2/0, 3/0 ACSR) Catalog No. ASD-2-N (4-2/0 ACSR) Catalog No. ASD-34-N 3/0, 4/0 ACSR Catalog No. HDSO 57 (with side opening) (4-4/0 ASCR)	Same as above.
Aluma-Form Catalog# DES-ASD-1 8 - 2/0 ACSR Catalog# DES-ASD-45 4/0 - 477 ACSR Catalog# DES-ASO-398-1 6 - 2/0 ACSR Catalog# DES-ASO-684-1 4 - 336.4 ACSR (Side Opening) Catalog# DES-ASO-858-2 4 - 556.5 ACSR (Side Opening) Catalog# DES-HDSO-47 8 - 2/0 ACSR (Side Opening) Catalog# DES-HDSO-57 4 - 4/0 ACSR (Side Opening) Catalog# DES-HDSO-82 2-477 ACSR (Side Opening) Catalog# DES-HDSO-88L-6 4-556.5 ACSR (Side Opening)	Same as above.

*Straight line deadend clamps are applicable for urban construction where tensions are moderate and on lines often worked hot.

l – Clamp, deadend

DISTRIBUTION

(wedge type)

Manufacturer	Conditions
Hubbell (Fargo)	
GDW-2010A (#4 – 2/0 ACSR) Bare Aluminum jaws	To obtain experience.
GDW-2010 (#4 – 2/0 Str Cu) Plated Aluminum jaws for use with copper conductor	
GDW-2040A (#4 – 4/0 ACSR) Bare Aluminum jaws	
GDW-2040 (#4 – 3/0 Str Cu) Plated Aluminum jaws for use with copper conductor	
GDW-556 (266.8 – 477 kcmil ACSR)	

m – Clamp, suspension

2 BOLT – DISTRIBUTION

	Copper & CWC	ACSR with Straight or Formed Armor Rods			
		4	2	1/0 & 2/0	3/0 & 4/0
ABB	6240	6241	6242	6243	6244
AFL	-	-	-	-	HSU*
C & R Products	-	-	-	CRSC-1	CRSC-2
Dulmison	-	-	-	-	HSU*
Hubbell (Anderson)	MS-46-N	MS-60-N	MS-70-N	HAS-85-N	HAS-104-N
Hubbell (Chance)	FWG1	FWG2	FWG3	FWG4	-
Lapp	305740N	306027N	306028N	306029N	306030N
MacLean (Bethea)	FS-46-N	GW-1-N	LS-0-N	LS-1-N	LS-2-N
MacLean (Continental)	FSC-46-N	FSC-60-N	SC-70-N	SC-85-N	SC-105-N
Preformed Line Products	-	-	-	-	AGS*

*Accepted for larger sizes.

m – Clamp, Suspension

ANGLE – DISTRIBUTION No. 2 & 4 ACSR Plus Rods		2-BOLT TRANSMISSION For 3/8” Steel Overhead Ground Wire
2300	ABB	6240
	MacLean (Continental)	FSC-46N
AAC-301 & 302	Hubbell (Anderson)	MS-46-N
-	Hubbell (Chance)	FGW1
GD-907A	Hubbell (Fargo)	-
306092	Lapp	305740N
AC-60	Line Hardware	-
RALS-1	MacLean (Bethea)	

m – Clamp, suspension – cushioned

Condition: To obtain experience

ACSR

	kcmil					
	266.8	336.4	477	556.5	795	954
Preformed	CGS-1100	CGS-1102	CGS-1105	CGS-1106	CGS-1110	CGS-1112

m – Clamp, suspension, high temperature
For use with High Temperature Conductors

Manufacturer	Conditions
Preformed Line Products (PLP) Suspension System To be used with CTC Global High Temperature Conductors ACCC (Aluminum Conductor Composite Core)	4. To obtain experience. 5. Use high temperature accessories approved by the manufacturer and accepted by RUS

Note: These clamps are acceptable when installed using tools and dies in accordance with the conductor manufacturer's recommendations.

n – Bolt, double arming

Applicable Specification: ANSI C135.1, “Standard for Galvanized Steel Bolts and Nuts.”

Applicable Sizes: 5/8 inch diameter, 12 inch through 24 inch length

¾ inch diameter, 20 inch through 24 inch length

The following manufacturers have shown compliance with the applicable specifications for double arming bolts:

Action Manufacturing
Allied Bolt, Inc.
Hubbell (Chance)
Hughes Brothers
* Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)
Portland Bolt & Manufacturing Company
Steel City Bolt & Screw Co., Inc.
Threaded Fasteners, Inc.

*”Static proof” designs available.

o – Bolt, eye, oval

Applicable Specification: ANSI C135.4, “Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction.”

Applicable Sizes: 5/8-inch diameter, 6 through 20-inch length
¾-inch diameter, 8 through 20-inch length

The following manufacturers have shown compliance with the applicable specifications for oval eye bolts:

Action Manufacturing
Allied Bolt, Inc.
Berny’s Forging Company
* Joslyn Manufacturing Company
Hubbell Power Systems (5/8-inch diameter ONLY)
Kortick Manufacturing Company
MacLean (Continental)

*”Static proof” designs available.

Shoulder Eye Bolt
for Transmission Structures
¾4 inch diameter, 8 inch through 20 inch length

	Catalog Number
Joslyn	J9528 to J9540
Kortick	K9558 to K2570

p – Connectors, distribution (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to ACSR
To same size or smaller

Bare Conductor

	4/0 – 2/0	1/0	2	4
AFL	-	396.6	490.0	490.0
Blackburn	PAE 4141-9	PAE 2121-9	PAE 2121-9	PAE 2121-9
Burndy	KVS28A	UCG25R	UC25R2R	UC25R2R
Connector Mfg.	APC-2/0	APC-2/0	APC-1/0	APC-1/0
Hubbell (Anderson)	LC-53A	LC-51C	LC-51A	LC-51A
Hubbell (Fargo)	GA-9040L	GA-9020L	GA-9002L	GA-9003L
MacLean (Reliable)	APG-3	APG-2	APG-1	APG-1
Penn-Union	PCAA-20BF	PCAA-15BF	PCAA-10BF	PCAA-10BF
TE Connectivity – Energy	1710521-5	1710521-3	1710521-1	1710521-1

Over Armor Rods

	3/0	2/0	1/0	2	4
Blackburn	-	-	PAA10	PAA10	PAA10
Burndy	-	-	UC32R	UC32R	UC32R
Hubbell (Anderson)	LC-83A	LC-52C	LC-52C	LC-52C	LC-52C
Hubbell (Fargo)	GA-9843	GA-9842	GA-9041L	GA-9020L	GA-9020L
MacLean (Reliable)	-	-	744AL	600AL	600AL
Penn-Union	-	-	ARC-12	ARC-11	ARC-14

p – Connectors, Distribution (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to Copper or Copperweld-Copper

ACSR Size (Bare Conductor)

	3/0	2/0	1/0	2	4
AFL	197	R193	R193	195	195
Blackburn	PAC7	PAC7	PAC345	2CA	4CA
Hubbell (Anderson)	LC-811A	LC-811A	LC-522A	LC-511A	LC-511
Hubbell (Fargo)	GA-9040L	GA-9040L	GA-9020L	GA-9002L	GA-9003L
MacLean (Reliable)	600ALC	555ALC	438ALC	438ALC	438ALC

ACSR Size (Over Armor Rods)

	3/0	2/0	1/0	2	4
AFL	201	R197	R197	R197	199
Blackburn	-	-	PAC7	PAC7	PAC7
Hubbell (Anderson)	LC-833	LC-833	LC-811A	LC-811A	LC-811
Hubbell (Fargo)	GA-9843C	GA-9842C	GA-9040L	GA-9020L	GA-9020L
MacLean (Reliable)	-	-	744ALC	600ALC	600ALC

p – Connector, Distribution

Applicable Specification: ANSI C119.4

Copper Type Conductors
Connections to same size or smaller

Bare Conductor

	Copperweld Copper	2A		4A	6A	8A
	Copper	0x7	2x3		4	6
(s)	Blackburn	1/0H	1H	2H	4H	6H
(s)	Burndy	KS-25	KS-23	KS-23	KS-20	KS-17
(s)	Dossert	DS-10-F	DS-6-F	DS-6-F	DS-3-F	DS-2-F
(s)	Greaves	-	A-8	-	A-5	A-3
(s)	Homac	-	1F	2F	4F	6F
	Hubbell (Anderson)	DG-1/0	DG-1	DG-2	DG-4	DG-6
	Hubbell (Fargo)	GC-5020	GC-5002S	GC-5002	GC-5004	GC-5006
(s)	ILSCO	IK-1/0	IK-2	IK-2	IK-4	IK-6
(s)	Kearney/Eaton	118109	118109	118108	118104	118102
(s)	Krueger & Hudepohl	UC58C-EV	-	-	-	-
(s)	Penn-Union	S1/0	S2	S3	S4	S6
	Richards Manufacturing	VC10	VC10	VC7	VC5	VC3
	Royal Switchgear	1739	1739	-	-	-

Over Armor Rods

	Burndy	KVS-31	KVS-31	KVS-28	KVS-26	KVS-26
	Hubbell (Anderson)	K-5	K-4	K-4	K-2	K-2
	Hubbell (Fargo)	GC-5035	GC-5035	GC-5040	GC-5020S	GC-5020
	ILSCO	IKB-350	IKB-350	IKB-4/0	-	-
(s)	Kearney/Eaton	118112	118112	118111	118110	118110
	Penn-Union	VT-4	VT-3	VT-3	VT-2	VT-1

(s) Designates split bolt connectors

Long Connectors (Split Bolt)
Copper to Copper

	2	4	6
Blackburn	2H3	4H3	6H3
Burndy	KS-22-3	KS-20-3	KS-17-3
Dossert	DS5-3	DS3-3	DS2-3
Greaves	A-9	A-6	A-4
Homac	-	4F	6F
Hubbell (Anderson)	C-2-L	C-4-L	C-6-L
Kearney/Eaton	118107	118105	118103
Penn-Union	SEL-2	SEL-4	SEL-6

p – Connectors, Service (Parallel Groove)

Applicable Specification: ANSI C119.4
Aluminum-to-Aluminum
Solid or Stranded

	No. 2	No. 4
AFL	490.0	490.0
Blackburn	PAE 2121-9	PAE 2121-9
Burndy	UC25R2R	UC25R2R
Hubbell (Anderson)	LC-51A	LC-51A
Hubbell (Fargo)	GA-9002L	GA-9002L
MacLean (Reliable)	APG-1	APG-1
Penn-Union	PCAA-10BF	PCAA-10BF

p – Connectors, Service (Parallel Groove)

Applicable Specification: ANSI C119.4
Aluminum-to-Copper
Solid or Stranded

	2 Al to 4 Cu	4 Al to 6 Cu
Blackburn	PAC345	PAC345
Hubbell (Anderson)	LC-511A	LC-511A
Hubbell (Fargo)	GA-9002L	GA-9002L

p – Connectors, Service

Applicable Specification: ANSI C119.4
Copper-to-Copper
Solid or Stranded

Manufacturer	No. 4	No. 6
Blackburn	4N	6N
Burndy	KP4C	KP6C
Dossert	ES-4	ES-6
Hubbell (Anderson)	4E	6ES
Hubbell (Fargo)	GC-5004	GC-5006
Ilsco	SX-4	SX-6
Maclean (Reliable)	BVC-4	BVC-6
Penn-Union	SX-4	SX-6
Richards Manufacturing	VC5	VC3
Southport	SE-3	SE-2

p – Connectors, Guy Bond (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to Guy Strand

	2/0	1/0	2 & 4
AFL	396.6	396.6	490.0
Blackburn	PAE 2121-9	PAE 2121-9	PAE 2121-9
Burndy	UC 28R	UCG25R	UCG25R
Dossert	AC103-LW	AC101-LW	AC100-LW
Hubbell (Anderson)	LC-52A-GP	LC-51C-GP	LC-51A-GP
Hubbell (Fargo)	GA-9040L	GA-9040L	GA-9040L
MacLean (Reliable)	744AL	555AL	438AL
Penn-Union	ALC-15	ALC-10	PCA-010

Copper to Guy Strand

TE Connectivity – Energy	C-LOK Series
Blackburn	K-1 2HPW (1/4”) 1/0 HPW (3/8”)
Burndy	UC8W26L
C & R	CRJC-1
Dossert	UDV 13-1-P
Galvan Industries, Inc.	K1
Hubbell (Anderson)	LC-511A
Hubbell (Fargo)	GC-8040P
ILSCO	SK-3 (1/4”) SK-1/0 (3/8”)
Joslyn	J8300
Kearney/Eaton	9968-1
Krueger & Hudepohl	UC58B-EV
MacLean (Reliable)	438ALC
Penn-Union	JC-1-AC (1/4”, 3/8” guy strand) (1/0 strand copper max.)

p – Connectors, Compression
Applicable Specification: ANSI C119.4

DISTRIBUTION

	Aluminum to aluminum	Aluminum to copper	Copper to copper	Tap Connections (Al to Al,Al to Cu)
Blackburn	Type WR	Type WR	Type CF-1	Type WR
Burndy	“Hycrimp” (Type YH)	“Hycrimp” (Type YH)	“Crimpit” (Type YC-C)	“Cabelok Crimpit” (Type YP-U)
Cembre	-	-	C	-
Homac	H Tap-OB&DB	H Tap-OB&DB	CC	H Tap-OB&DB
Hubbell (Anderson)	AC Series	AC Series	VCUC	VCP
Kearney/Eaton	“Squeezeon” (Aluminum)	“Squeezeon” (Aluminum)	“Squeezeon” (Copper)	“Squeezeon” (Aluminum)
Penn-Union	“Press-On” (Aluminum)	“Press-On” (Aluminum)	“Press-On” (Copper)	“Penn-L-Tap”

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer’s recommendations.

p – Connectors, Compression
Applicable Specification: ANSI C119.4

SERVICE

	Aluminum-to-Aluminum Aluminum-to-Copper	Copper-to-Copper
Blackburn	CS, KL ICS-1, IKL (Insulated)	-
Burndy	"Linkits" (Type YSU, YSD) "Insulink"(ES)	"Hysplice" (Types YDS-C, YDS-W)
Homac	"Shure Splicers"	-
Hubbell (Anderson)	VAUS	VHS
Kearney/Eaton	"Serv-ens"	-
National Tel. Supply	"Nicopress"	-
Penn-Union	"Penn Sleeves"	-

These connectors are furnished in a variety of sizes to fit all combinations of aluminum and copper service wire.

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer's recommendations.

p – Connectors, Transmission
Applicable Specification: ANSI C119.4

BOLTED TYPE

ACSR to ACSR
ACSR to Copper

AFL	580 Series
Burndy (ACSR to ACSR)	UP-A, UP-R

When ordering these clamps specify size, stranding and material of both conductors.

COMPRESSION TYPE

ACSR to ACSR
Same Size

Conductor Size	AFL	Blackburn	Burndy	Hubbell (Anderson)	Kearney/Eaton
1/0	5074.438	RCJ10	YCS25R	VPUS	OHR-1/0-61AJ
2/0	5074.484	RCJ20	YCS26R	-	OHR-2/0-61AJ
3/0	5075.547	RCJ30	YCS27R	Order	OHR-3/0-61AJ
4/0	5075.609	RCJ40	YCS28R	by	OHR-4/0-61AJ
266.8 kcmil	5076 Order by	RCJ266M	YCS30R	Conductor	HR-266-267AJ
336.4 kcmil	5076 stranding	RCJ336M	YCS33R	Size	HR-336-267AJ

ACSR to Copper

AFL	5070 Series
Burndy	YCR-R-CA
Hubbell (Anderson)	VPUS

(Order by conductor sizes)

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer's recommendations.

p – Connectors

(wedge type)

Manufacturer	Aluminum-to-aluminum	Aluminum-to-copper	Copper-to-copper	Tap Connections (Al to Al ,Al to Cu)
AFL	Wedge Tap	Wedge Tap	-	Wedge Tap
TE Connectivity	AMPACT MINIWEDGE AMPACT BAT	AMPACT MINIWEDGE AMPACT BAT	AMPACT C-LOK Series -	AMPACT MINIWEDGE AMPACT BAT
Burndy	WEJTAP	WEJTAP	WEJTAP	WEJTAP
Connector Products, Inc.	Aluminum Tap Connector	Aluminum Tap Connector	-	Aluminum Tap Connector
Homac	Power Tap	Power Tap	-	Power Tap
Richards Manufacturing Co.	ABWC series	ABWC series	-	ABWC series

p – Connectors

Manufacturer	Conditions
Blackburn	
Bolted, insulated IPC 1102 (#2-1/0 run, #2 tap) IPC 4111 (1/0-4/0 run, #2-1/0 tap) IPC 4141 (1/0-4/0 run, 1/0-4/0 tap)	1. For use on 600 volt maximum insulated conductors. 2. To be used only for connecting service drop conductors to service entrance conductors. 3. To obtain experience.
Homac	
*Compression, Insulated "Shure Splicers" Types Q1N and U1N	To obtain experience.
Hubbell (Anderson)	
*Compression al to al al to cu "Versa-Crimp" L tap.	To obtain experience.
Parallel groove, aluminum LC-52C (1/0 – 6/1 ACSR over armor rods) LC-51C (1/0 – 6/1 ACSR)	To obtain experience.
Kupler	
Bolted, insulated 130001 (#2-1/0 run, #2 tap) 130003 (1/0-4/0 run, #2-1/0 tap) 130004 (1/0-4/0 run, 1/0-4/0 tap)	1. For use on 600 volt maximum insulated conductors. 2. To be used only for connecting service drop conductors to service entrance conductors. 3. To obtain experience.
Penn Union	
*Compression, Insulated Type PIK	To obtain experience.
TE Connectivity (Raychem)	
Insulated service compression connector, TIL Series	To Obtain Experience.
Utilco	
Two bolt style, al to al Type PM	To obtain experience.

*NOTE: These connectors are acceptable when installed with tools and dies in accordance with the connector manufacturer's recommendations.

p – Connectors, Transmission
Applicable Specification: ANSI C119.4

BOLTED TYPE

ACSR to ACSR
ACSR to Copper

Manufacturer	Conditions
Power Connector Specialties (PCS)	
Shear-Bolt Connectors (Mechanical) AL/CU, #6 AWG – 1500 kcmil	To obtain experience
PCS Series (Straight Splice) PCRS Series (Repair) PCL Series (Lugs) PCH Series (H-Type) PCY Series (Y-Type) PCA / PCE Series (Elbow Connectors) PCSS Series (Step) PCSL Series (Stem) PCGR / PCGT Series (Grounding) PCSLT Series (Inline / Streetlight)	

q – Bolt, double upset

Applicable Specification: "RUS Specifications for Single and Double Upset Spool Bolts," D-5

Diameter, inches:	5/8	5/8	5/8	5/8
Length, inches:	7	8	9	10
Manufacturer				
Allied Bolt, Inc.	-	-	1716	1717
Hubbell (Chance)	-	7826	7828	7830
Joslyn	-	J2394	J2395	J2396
Kortick	K4760	K4761	K4762	K4763
MacLean (Continental)	U31065	U31067	U31069	U31071

s – Clevis, secondary swinging

Applicable Specifications: "RUS Specifications for Secondary Swinging Clevises," D-6

Manufacturer	Clevis only*	Clevis with 1-3/4" groove spool	Clevis with 3" groove spool
Hubbell (Chance)	0352	0352-C909-1032	0352-C909-1034
Joslyn	J0322	-	-
Kortick	K9259	K9109	K9149
MacLean (Continental)	U32043	U36043	U32143

*Catalog Number does not include spool. See page cm for spool type insulators.

u – Deadend for galvanized steel or aluminum-clad steel guy strand

3-Bolt Guy Clamp

	Light (1/2” bolts)	Heavy (5/8” bolts)*
Almat	-	K162-4
Allied Bolt, Inc.	5059	5056
Hubbell (Chance)	6450	6461
Joslyn	J930	J931
Kortick	K4124	K4005
MacLean (Continental)	U5273	U5275

U-Bolt Guy Clamp

	Light (3/8” bolts)	Heavy (1/2” bolts)
Hubbell (Chance)	GCU38C	-
Joslyn (Flagg)	PAX-64C	PAX-67C
MacLean (Continental)	GC-64C	GC-67C

Offset Guy Clamp

	Light (1/2” bolts)	Heavy (5/8” bolts)
Hubbell (Chance)	6409	6410
Joslyn	J926	J927

*For use on transmission.

u – Deadend for galvanized steel guy strand

Strand Size:	¼	9/32”	5/16”	3/8”	7/16”
			Automatic		
Aluma-Form	AGD-250 AGDU-250	-	AGD-312 AGDU-312	AGD-375 AGDU-375	AGD-437
MacLean (Reliable)					
Bail for thimble eye	5100	5201	5201	5102	5103
Bail for guy insulator	5150	5251	5251	5152	5153
			Formed Type		
AFL					
For standard guy*	GYDEGB061	GYDEGB071	GYDEGB079	GYDEGB091	GYDEGB110
Dulmison					
For standard guy*	SGG-0610	SGG-710	SGG-0790	SGG-0915	SGG-1105
Florida Wire & Cable					
For standard guy*	FLA 1300	FLA 1400	FLA 1500	FLA 1600	FLA 1700
Helical Line Products					
For standard guy*	HG-207-1/4”	HG-208-9/32”	HG-209-5/16”	HG-210-3/8”	HG-211-7/16”
Payer Industries					
For standard guy*	25-GNBS	-	30-GNBS	35-GNBS	38-GNBS
Preformed Line Products					
For standard guy*	GDE-1104	GDE-1105	GDE-1106	GDE-1107	GDE-1108
For wrapped guy	WGL-2100	WGL-2101	WGL-2102	WGL-2103	WGL-2104

*Class B galvanizing. When guy wire has Class C galvanizing, formed deadend should also have Class C galvanizing.

u – Deadend for aluminum clad steel guy strand

Strand Size	3#10 (4M)	7#12 (6M)	7#11 (8M)	7#10 (10M)	7X.110" (11.5M)	7#9 (12.5M)	7X.121" (14M)	7#8 (16M)	7X.148" (20M)
Formed Type Aluminum-Clad Steel Guy Strand									
AFL For standard guy	GYDEAW055	GYDEAW060	GYDEAW068	GYDEAW077	GYDEAW082	GYDEAW087	GYDEAW090	GYDEAW096	GYDEAW112
Dulmison For standard guy	AWGG 0555	AWGG 0600	AWGG 0685	AWGG 0770	AWGG 0825	AWGG 0870	AWGG 0905	AWGG 0965	AWGG1125
Helical Line Products For standard guy	-	HG517-6M	HG519-8M	HG521-10M	-	HG523-12.5M	HG524-14M	HG525-16M	HG528-20M
Hubbell (Chance) For standard guy	-	6M-AWTLG	8M-AWTLG	10M-AWTLG	-	12.5M-AWTLG	-	-	-
Preformed Line Products For standard guy	AWDE-4108	AWDE-4110	AWDE-4113	AWDE-4116	AWDE-4118	AWDE-4119	AWDE-4120	AWDE-4122	AWDE-4126
For wrapped guy	-	WGL-4110	WGL-4113	WGL-4116	-	WGL-4120	-	-	-
Automatic Aluminum-Clad Steel Guy Strand									
Hubbell (Fargo)	-	GDE-300	GDE-301	GDE-301	-	GDE-302	-	-	-
MacLean (Reliable)	-	5200	5201	5201	-	5202	-	-	-

v – Guy Attachment
for 5/8” bolt

Type:	Formed Strap	Angle Bolt Eye	Guy Hook	Guy Hook*
Maximum Working Load Rating	23,130 N (5200 lbs.)	23,130 N (5200 lbs.)	23,130 N (5200 lbs.)	37,800 N (8500 lbs.)
Eaton				
Hubbell (Chance)	5004	0100	-	GH5
Joslyn	J25164	J6500	J6555 J6556	-
Joslyn (Flagg)	-	-	-	P151X
Kortick	K4035 K4047	K3140	-	-
Line Hardware	-	-	-	HGA-58C
MacLean (Bethea)	-	-	-	AG-5
MacLean (Continental)	U31030	U5531	GAD	GAD-56-4
Power Play Products	-	-	-	B58GH
M.D. Henry Company, Inc.	-	-	-	UGA-56C

*This hook may be used in place of the wrapped guy arrangement in assemblies E3-2 and E3-3.

Pole Eye Plates
(5/8” Bolt)

Type	Pole Eye Plate
Maximum Working Load Rating	37,800 N. (8500 lbs.)
Hubbell (Anderson)	GSP-05
Line Hardware	PGA-548
MacLean (Bethea)	PE5-6A
MacLean (Continental)	PEP-66-45

v – Guy attachment

Manufacturer	Conditions
MacLean (Continental)	
Pole Band, UCB-15E	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.
Hubbell (Chance)	
Pole Band, with cone head bolt 6280, and guy clip 456 6276 (for 6” to 10” pole) 6277 (for 8” to 14” pole)	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.
Joslyn	
Pole Band, with cone head bolt J-6281, and guy clip J-6275 J-6280 (for 6” to 10” pole) J-6270 (for 8” to 14” pole)	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.

w – Insulators, guy strain
(Fiber Reinforced Plastic)

Ult. Strength, lbs.	11,000	15,000	21,000
Aluma-Form, Inc.	-	FGS 16 Series	FGS 21 Series
Dulmison	II1-1P Series	HSI-2X Series	HSI3-2P Series
Fiberglass Line Hardware		FCC Series FCTE Series	FCC Series FCTE Series
GAMMA CORONA	-	GS15 Series	GS21 Series
EPAC	CC Series	CC Series	CC Series
Gamma Insulators Corp.	-	GS15 Series	-
Hubbell (Chance)	-	GS-16	GS-21
Hughes Brothers	-	692 Series	694 Series
Joslyn (Flagg)	150 Series	150 Series	210 Series
K-Line	-	-	KL Series
MacLean (Continental)	G-11 Series GAC 11 Series (for 5/16” guy strand)	G-15 Series GAC 15 Series (for 3/8” guy strand)	G-21 Series -
Preformed Line Products	-	GSF16 Series	GSF21 Series

x – Rod, anchor

Applicable Specification: ANSI C135.2, “Standards for Galvanized Ferrous Strand Eye Anchor Rods”

Applicable Sizes:

Single guy: 5/8 inch diam. 6, 7 and 8 ¾t long
3/4 inch diam. 8, 9 and 10 feet long
1 inch diam. 9 and 10 feet long

Double guy: 5/8 inch diam. 7 and 8 f¾ long
3/4 inch diam. 8, 9 and 10 feet long
1 inch diam. 9 and 10 feet long

Single Guy: Drive: 5/8 inch diam. 7 and 8 ¾t long
3/4 inch diam. 8, 9 and 10 feet long
1 inch diam. 9 and 10 feet long

Double Guy: Drive: 5/8 inch diam. 7 and 8 ¾t long
3/4 inch diam. 8, 9 and 10 feet long
1 inch diam. 9 and 10 feet long

The following manufacturers have shown compliance with the applicable specifications. Some manufacturers cannot supply all sizes listed above. Check with manufacturer or distributor for availability.

Allied Bolt, Inc.
Dixie
Eritech (Carolina Galvanizing/Knight)
Grip-Tite
Hubbell (Chance)
Joslyn
Kortick
Utilities Service

Conditional List
x(1)
July 2009

x – Rod, anchor

Applicable Specification: ANSI C135.2 “Standards for Galvanized Ferrous Strand Eye Anchor Rods” except rods are copper covered. Copper coating thickness is **13 mils minimum** at any point and a 15 mil average. All purchases should specify that a factory certification to the thickness of the copper must accompany the shipment of the rods.

Applicable Sizes: Dou¾ Guy – 3/4 inch diameter, 8 and 9 feet long.

Manufacturer	Conditions
Joslyn	1. To obtain experience. 2. For transmission purposes only. 3. For use with log anchors or copper covered plate anchors only. 4. To be used with copper coated hardware or bronze hardware underground.

Conditional List
x(2)
July 2012

x – Rod, anchor

Applicable Specification: ANSI C135.2 “Standards for Galvanized Ferrous Strand Eye Anchor Rods” except rods are copper covered. Rods meet UL-465 specification for copper coating thickness of **10 mils minimum** at any point. All purchases should specify that a factory certification to the thickness of the copper must accompany the shipment of the rods.

Applicable Sizes: Double Guy – 3/4 inch diameter, 8 and 9 feet long.

Manufacturer	Conditions

y – Galvanized Steel Strand

Usage: Guy, Distribution or Transmission Line
Overhead Static Wire

ASTM Specification: A 475 – For Guy Strand
A 363 – For Overhead Static Wire

Following grades/diameters of steel wire strands are preferred sizes:

For Guying

Siemens-Martin	High Strength	Extra High Strength Grade	
Distribution Line	Dist. Or Trans.	Distribution	Transmission
¼" dia.	¼" dia.	¼" dia.	¼" dia.
-	9/32"	9/32"	9/32"
-	5/16"	5/16"	5/16"
3/8"	3/8"	3/8"	3/8"
7/16"	7/16"		7/16"

For Overhead Static Wire (Groundwire)

High Strength (dia.)	Extra High Strength Grade (dia.)
-	5/16"
3/8"	3/8"
7/16"	7/16"

Alcan Cable
Armco Steel Corporation
Bekaert Steel Wire Corporation
Cal-Wire
Central de Herramientes, S.A. de C.V.
Conex Cable, LLC
Davis-Walker
DeAcero, S.A. de C.V.
Emcocables
Florida Wire and Cable
Guardian Cable Systems, LLC
Indiana Steel and Wire
Knight Industries
Mitchell Industries
National Strand Products
Paulsen Wire and Rope Corporation
Seal Wire Company
Southwire

Note: The buyer should specify Class A, B, or C coating per ASTM A363 or A475.

y – Steel Strand

Aluminum-Clad
Specifications: ASTM B415 and B416

For overhead groundwire
(Joint and splice requirements for wire and strand to meet ASTM A363)
AWG Sizes: (a) 7 No. 10, (c) 7 No. 9, (d) 7 No. 8, (e) 7 No. 7

Emcocables	(a), (c), (d), (e)
Intral and Company, Ltd.	(a), (c), (d), –e)
Nehri–g - Conex	(a), (c), (d), (e)
AFL	(a), (c), (d), (e)

For guy strand
(M is rated breaking load in thousand lbs)
M Sizes: 6M (7 No. 12), 8M (7 No. 11), 10M (7 No. 10), 11.5M (7 x .110"), 12.5M (7 No. 9), 14M (7 x .121"), 16M (7 No. 8), 18M (7 x .139"), 20M (7 x .148")

Alumoclad de Mexico, S.A. de C.V.	8M, 10M, 16M
Emcocables	6M, 8M,10M, 12.5M, 16M, 18M, 20M
Intral and Company, Ltd.	6M, 8M,10M, 12.5M, 16M, 18M, –0M
Nehri–g - Conex	8M, 10M, 12.5M, 16M, 18M
AFL	6M, 8M, 10M, 12.5M, 14M, 16M, 18M, 20M

y – Aluminum Coated Steel Wire
Applicable Specification ASTM A474

National Strand Products, 3/8"

Distribution Guy Strand Siemens-Martin High Strength Extra High Strength	To obtain experience.
Transmission Guy Strand High Strength Extra High Strength	To obtain experience.
Overhead Static Wire High Strength Extra High Strength	1. To obtain experience. 2. Must meet the joint requirements of ASTM A363.

Conditional List
y(2)
November 2018

y - Zinc - 5% Aluminum - Mischmetal alloy (Zn-5Al-MM) - Coated
Steel Wire Strands
Applicable Specification ASTM A855

Bekaert Corporation

Type/Grade: Nominal diameter (7-wire strand) in.

(S-M): 1/4", 3/8", & 7/16".
(HS): 1/4", 5/16", 3/8", & 7/16", 9/32".
(EHS): 1/4", 5/16", 3/8", & 7/16", 9/32".

	Conditions
Distribution Guy Strand Siemens-Martin (S-M) High Strength (HS) Extra High Strength (EHS)	To obtain experience.
Transmission Guy Strand High Strength (HS) Extra High Strength (EHS)	To obtain experience.
Overhead Static Wire High Strength (HS) Extra High Strength (EHS)	1. To obtain experience. 2. Must meet the joint requirements of ASTM A363.

NOTE: Only available with Class A coating.

Type/Grade: Nominal diameter (7-wire strand), in.

(S-M): 1/4", 3/8", & 7/16".
(HS): 1/4", 9/32", 5/16", 3/8", & 7/16".
(EHS): 1/4", 9/32", 5/16", 3/8", & 7/16".

Indiana Steel & Wire Co.

Guardian Cable Systems, LLC

	Conditions
Distribution Guy Strand Siemens-Martin (S-M) High Strength (HS) Extra High Strength (EHS)	To obtain experience.
Transmission Guy Strand High Strength (HS) Extra High Strength (EHS)	To obtain experience.
Overhead Static Wire High Strength (HS) Extra High Strength (EHS)	1. To obtain experience. 2. Must meet the joint requirements of ASTM A363.

NOTE: The buyer should specify Class A, B, or C coating.

Conditional List
y(3)
November 2018

y - Conzinal 95% Zinc - 5% Aluminum+ Mischmetal Alloy (AL-ZN-MM)
Coated Steel Wire Strands

Applicable Specifications:	ASTM A363, A475, A855/A855M, A925
	ASTM B498, B802/B802M, B803/B803M, B958/B958M

Conex Cable LLC

Type/Grade: Nominal diameter (7-wire strand) in.

(EHS): 1/4", 5/16", 3/8", & 7/16".

	Conditions
Distribution Guy Strand Extra High Strength (EHS)	To obtain experience.
Transmission Guy Strand Extra High Strength (EHS)	To obtain experience.
Overhead Static Wire Extra High Strength (EHS)	To obtain experience.

z - Anchors, Expanding and Plate

DISTRIBUTION

Designated Maximum holding power-lbs.		6,000	8,000	10,000	12,000
Min. Area (sq. in.)		90	100	120	135
Rod Dia. (inch¾		¾	5/8	¾	¾
Rod Length (feet)		7	7	8	-
	Type				
Grip-Tite	8 way	A322812G	A322812G	A322812G	A322812G
Hubbell (Chance)	8 way	88135	88135	88135	88135
MacLean Power Systems	8 way	-	J8115	J8135	J8135
Line Hardware	8 way	8-100G	8-115G	8-135G	8-135G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, plate

Applicable Specification "RUS Specification for Steel Plate Anchors," T-3

TRANSMISSION

Minimum Area 400 sq. in.

	¾" Galv. Rods
Grip-Tite	XP24 - 3/4 - G
Hubbell (Chance)	X24 - 3/4
MacLean Power Systems	J3524 - 3/4
Line Hardware	CP-24G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, Service

Designated Maximum Holding Power in Sand - 2500 lbs.

	Screw	Expanding
Eritech (Carolina Galvanizing)	86346606	-
Grip-Tite	-	322065G
Hubbell (Chance)	6346	6870
MacLean Power Systems	J6526W-CA	JO870
Line Hardware	-	8-70G
Salco	NW756606	-

z - Anchors, Swamp

DISTRIBUTION

	10" dia.	12" dia.	15" dia.
MacLean Power Systems	D-6710-S	D-6713-S	D-6715-S
Foresight	-	MR-SR*	-
Hubbell (Chance)	C1101169	C1101170	C1101171

*Drive type anchor. Surface area meets or exceeds that of 12" diameter anchors.

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, Rock

Anchor Size - inches	1-3/4	1-3/4	1-3/4	1-3/4
Rod Length - inches	15	30	53	18
Rod Diameter - inches	3/4	3/4	3/4	1
Almat	K148-15	K148-30	K148-53	-
Hubbell (Chance)	R315	R330	R353	-
MacLean Power Systems	J3436	J3437	J3438	-
Kortick	K5503	K5504	K5505	K2377

z - Pole keys

Hubbell (Chance)	P-4817
MacLean Power Systems	J-4817

z - Anchors, Power-installed screw

Manufacturer: Earth Contact Products
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
A2 (Soil Class 3)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
B (Soil Classes 4 & 5)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
C (Soil Classes 6 & 7)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	

Manufacturer: MacLean Power Systems
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	D-6632 D-6636 D-6637	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6636 D-6637 D-6638
A2 (Soil Class 3)	D-6632 D-6636 D-6637	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6637 D-6638
B (Soil Classes 4 & 5)	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6636 D-6637	D-6638
C (Soil Classes 6 & 7)	D-6636 D-6637	D-6637	D-6638	

NOTES:
1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.

z - Anchors, Power-installed screw

Manufacturer: Hubbell (A. B. Chance Company)
"SS" Multi Helix Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	012642AE 012642AEJ 012642EJN	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642AEJ 012642EJN 012642ENJNS
A2 (Soil Class 3)	012642AE 012642AEJ 012642EJN	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642EJN 012642EJNS
B (Soil Classes 4 & 5)	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642EJNS
C (Soil Classes 6 & 7)	012642AEJ 012642EJN	012642EJN	012642EJNS	

Manufacturer: Street & Area Lighting (Salco)
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	S736U810 S766U81012 S784U101214	S736U810 S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S766U81012 S784U101214 S7126U10121414
A2 (Soil Class 3)	S736U810 S766U81012 S784U101214	S736U810 S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S784U101214 S7126U10121414
B (Soil Classes 4 & 5)	S736U810 S766U81012 S784U101214	S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S7126U10121414
C (Soil Classes 6 & 7)	S766U81012 S784U101214	S784U101214	S7126U10121414	

NOTES:

1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.

z - Anchors, Power-installed screw

Manufacturer: Grip-Tite Manufacturing Co.

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	G66327 G66347 G66367 G66377	G66327 G66347 G66367 G66377	G66367 G66377	G66367 G66377
A2 (Soil Class 3)	G66327 G66347 G66367 G66377	G66327 G66347 G66367 G66377	G66367 G66377	G66377
B (Soil Classes 4 & 5)	G66327 G66347 G66367 G66377 G134-6	G66367 G66377		
C (Soil Classes 6 & 7)	G66367 G66377	G66377		

NOTES:

1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.

z - Anchors, Power-Installed Screw, Distribution

Manufacturer	Catalog Number	Rating (lbs.)
Hubbell (Chance)	C1025006	10,000
	C1025007	10,000
	C1025010	10,000
	C1025207	8,000
	C1025210	8,000
Grip-Tite		
	GHD250-114	10,000
	GHD250-134	10,000
	GHD225-112	8,000
	GHD225-134	8,000
	G112-6	6,000
Salco		
	SD225-12-1	10,000
	SD225-14-1	10,000
	PH7-12-1	7,000
	PH7-14-1	7,000

Conditional List
z(2)
March 2020

z - Anchors, plate

Manufacturer	Catalog #	Conditions
Watson Anchor*	W16B18775	To obtain experience.
	W16B18710	
	W20B18710	
	W20B25010	
	W24B18710	
	W24B25010	
	W30B50012	
	W36B62515	

NOTES:

*Watson cap nut and anchor rod should be used. Consult manufacturer for proper pairing.

Conditional List
z(5)
October 11, 2024

z – Anchors, screw, power installed

Manufacturer	Conditions
Bathurst BMS-003 (6,000 lbs.) BMS-003R (5/8” rod) BMS-004 (10,000 lbs.) BMS-004R (3/4” rod)	To obtain experience.
Cantsink 1.5RCS Series	To obtain experience.
Earth Contact Products TAPL-625-10-12 (6,000 lb., 5/8” rod) TAPL-100-10-14 (10,000 lb., 1” rod)	
Foresight MR-1, MR-2, MR-3, MR-4	To obtain experience. Each installation must be proof tested. Maximum rating is test value achieved.
Hubbell (Chance) 024462 (6,000 and 8,000 lb.) 12332P (5/8” rod) 12587 (5/8” thimble eye nut) 024484 (10,000 and 12,000 lb.) 12632P (3/4” rod) 6512 (3/4” thimble eye nut)	To obtain experience.
MacLean Power Systems J1lB-CA (6,000 & 8,000 lb., 5/8" rod) J13C-CA (10,000 & 12,000 lb., ¾” rod)	To obtain experience.
Oklahoma Design Technologies, LLC STAD Series CSTAD Series	To obtain experience.
Street & Area Lighting (Salco) S100-84 (10,000 lb., 1” rod) TEN-1 (1” triple eye nut)	To obtain experience.

NOTES:
1. Where galvanized anchors are listed, the same anchors ungalvanized (coated) are also acceptable.
2. Catalog numbers shown for screw anchors are for anchors with 1-3/8" hubs. Equivalent anchors with 1-1/2" hubs are also acceptable. (A special installing wrench is required.)

aa, ab
December 13, 2023

aa – Nut, eye
b - Nut, thimble eye

	aa			ab	
	Oval eye nut 5/8”	Oval eye nut 3/4”	Thimble Eyelet	Thimble eye nut 5/8”	Thimble eye nut 3/4”
Allied Bolt, Inc.	5876	5877	2050	5050	5051
Berny's Forging Co.	OE1	-	-	-	-
Dixie	-	-	-	D6510	-
Hubbell (Chance)	6502	-	B14A	6510	-
Hughes	EN60	-	-	-	-
Joslyn	J1092	-	J1126	J6510	-
Kortick	K4212	J1093	K4413	K3111	-
Line Hardware	OEN-58	-	BEL-58	-	-
MacLean (Continental)	EN-5	-	BE-5	TN-5	-

ac - Brace, sidearm diagonal

	1-1/2 inch angle 3/16" x 5'	1-3/4 inch angle 3/16" x 7'
Hubbell (Chance)	-	6984
Joslyn	-	J1525
Kortick	K1951	K1954
MacLean (Continental)	U5210	U5212

ae – Surge (lightning) Arrester, Distribution Class

SiC Type

Manufacturer	Type	Ratings, kV	Housing	Duty
General Electric	Alugard	9, 10, 18	Porcelain	Heavy

MOV Type

Manufacturer	Type	Ratings, kV	Housing	Duty
Celeco	PSAMOV-HDDC	9-27	Polymer	Heavy
	HSCEL	9-27	Polymer	Heavy
	RPCEL	9-27	Polymer	Riser Pole
Eaton	AZL VariSTAR	9-27	Porcelain	Heavy
TE Connectivity	HDA Series	9-27	Polymer	Normal
	DAH Series	9-27	Polymer	Heavy
Aluma-Form, Inc.	AHD	3-27	Polymer	Heavy
	ARP	3-27	Polymer	Riser Pole

ae - Surge (Lightning) Arresters, Substation*

SiC Type

Manufacturer	Type	Accepted Ratings - kV	Housing	Manufacturer's Classification
General Electric	Alugard	3, 9, 10, 18	Porcelain	Distribution

MOV Type

Manufacturer	Type	Accepted Ratings - kV	Housing	Manufacturer's Classification
Hubbell Power Systems (Ohio Brass)	DynaVar			
	VLA	3-27	Porcelain	Station
	VL	3-48	Porcelain	Station
	VN	54-312	Porcelain	Station

* For instructions concerning application at substations, refer to RUS Bulletin 1724E-300, "Guide for the Design of Substations for Electric Borrowers." In the purchase of arresters, care should be taken to select the type and voltage ratings in accordance with the line voltage and the type of construction (grounded or ungrounded).

ae - Surge (Lightning) Arresters, Distribution Class

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type

Manufacturer	Type	Ratings, kV	Housing	Duty
ABB	Polim-D	9,10,18	Polymer	Heavy
Eaton	AZS VariSTAR	9,10,18,27	Porcelain	Normal
	UNS Ultra Sil Housed VariSTAR	9,10,18,27	Polymer	Normal
	UHS Ultra Sil Housed VariSTAR	9,10,18,27	Polymer	Heavy
General Electric	Tranquell, 9L23 Series	9,10,18,27	Polymer	Heavy
Hubbell Power Systems (Ohio Brass)	DynaVar PDV-65	9,10,18,27	Polymer	Normal
	PDV-100 Optima	9,10,18,27	Polymer	Heavy
Joslyn	ZNP	9,10,18,27	Polymer	Normal
	ZHP	9,10,18,27	Polymer	Heavy

MOV Type (Internally Gapped)

Manufacturer	Type	Ratings, kV	Housing	Duty
Eaton	URT Evolution	9,10,18,27	Polymer	Heavy

Conditional List
ae(2)
March 2016

ae – Surge Arrester, Substation*

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type

Manufacturer	Type	Accepted Ratings – kV	Housing	Manufacturer's Classification
ABB	XPI-III	9, 10, 18, 27	Polymer	Intermediate
	XPS	9, 10, 18, 27	Polymer	Station
	EXLIM-R	9, 10, 18, 27	Porcelain	Station
	EXLIM-Q	9, 10, 18, 27	Porcelain	Station
Eaton	VariSTAR	3-312	Porcelain	Station
	VariSTAR AZF	3-120	Porcelain	Intermediate
	VariSTAR UI	3-108	Polymer	Intermediate – 3.9 kJ/kV(1)
	VariSTAR US	3-108	Polymer	Station – 3.4 kJ/kV
	VariSTAR US	3-108	Polymer	Station – 3.9 kJ/kV(1)
	VariSTAR US	120-240	Polymer	Station – 6.2 kJ/kV(1)
	VariSTAR UH	3-108	Polymer	Station – 5.6 kJ/kV
	VariSTAR UH	3-108	Polymer	Station – 6.2 kJ/kV(1)
	VariSTAR UH	120-240	Polymer	Station – 10 kJ/kV(1)
	VariSTAR UX	3-108	Polymer	Station – 10 kJ/kV(1)
	VariSTAR UXL	3-360 kV	Polymer	Station – 15 kJ/kV(2)
General Electric	Tranquell	2.7-612	Porcelain	Station
	Tranquell	3-120	Porcelain	Intermediate
Hubbell Power Systems (Ohio Brass)	PVI-LP	3-72	Polymer	Intermediate
	PVIA	3-72	Polymer	Intermediate
	PVI	3-144	Polymer	Intermediate
	EVP	3-288	Polymer	Station
	SVN	54-444	Polymer	Station
	MVN	54-444	Porcelain	Station
Joslyn	Type ZS	3-240	Porcelain	Station
	Type ZSH	258-468	Porcelain	Station
	Type ZIP	3-120	Polymer	Intermediate
	Type ZSP	3-144	Polymer	Station
MagneTek	ZSE-E2A	3-39	Porcelain	Station
	ZSE-E3A	45-312	Porcelain	Station
Siemens Power	3EQ1	36-240	Polymer	Station
	3EQ4	96-444	Polymer	Station
	3EP2	12-384	Porcelain	Station
	3EP4	12-150	Porcelain	Station
TE Connectivity	PBA	3-192	Polymer	Intermediate

*For instructions concerning application at substations refer to RUS Bulletin 1724E-300, "Design Guide for Rural Substations." In the purchase of arresters, care should be taken to select the type and voltage rating in accordance with the line voltage and the type of construction (grounded or ungrounded).

(1) Energy ratings based on single impulse ratings.
(2) Meets Class H energy levels per IEEE Std C62.11™-2012 standard.

af – Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating
ABB	ICX	15, 27 kV
	LBU-II	15, 27 kV
Advanced Rubber Products	LCNL-15 – polymer (load break)	15 kV
	LCNL-27 – polymer (load break)	27 kV
	LCNL-36 – polymer (load break)	36 kV
	CSNL-15 – polymer	15 kV
	CSNL-27 – polymer	27 kV
	CSNL-36 – polymer	36 kV
Aluma-Form, Inc.	CPG-15 (porcelain)	15 kV
	CPG-27 (porcelain)	27 kV
	CSG-15 (polymer)	15 kV
	CSG-27 (polymer)	27 kV
Eaton	S1	15, 27 kV
	L (porcelain)	15, 27 kV
	L (polymer)	15, 27 kV
Hubbell (Chance)	C	15, 27, 35 kV
	C (load break)	15, 27, 35 kV
	C-Polymer	15, 27 kV
	C-Polymer (Load break)	15, 27 kV
Kearney/Eaton	HX	15, 27 kV
Peak Demand Inc.	FCP series	15, 27, 36kV
Power Line Hardware	DHC	15, 27 kV
	SIL (polymer)	15, 27 kV
MacLean Power Systems	XS-Polymer	15, 27 kV
Southern States	Series 66	15, 27 kV
	Series 70	15 kV
United Copper Industries	APD1516100110	15 kV
	APD2712100125	27 kV

NOTE: The buyer should specify the load rating, voltage rating, interrupting rating and required accessories. Cutouts used on underground riser poles should be load break type or have hooks for portable load interrupters.

af – Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating
IUSA	C (porcelain)	15, 27 kV
	C (polymer)	15, 27 kV

NOTE: The buyer should specify the load rating, voltage rating, interrupting rating and required accessories. Cutouts used on underground riser poles should be load break type or have hooks for portable load interrupters.

af - Cutout, open-link fuse support

Manufacturer	Mounting	12.5/7.2 kV 50 amp.	24.9/14.4 kV 50 amp.
Eaton	Crossarm	FT1A2	FT1A4
	Bushing	FT10A3	-
Kearney/Eaton	Crossarm	6484-55	-
	Bushing	6483-59	-

NOTE: The open link fuse supports listed above are fuse supports only and have no inherent interrupting capacity. They should be used with fuse links capable of interrupting at least 1200 amperes and for transformer protection only.

af - Power Fuses, Substation

Manufacturer	Type	Voltage Rating (kV)
Eaton	CMU (Boric acid, non-refillable)	15-34.5
Eaton (Cutler-Hammer)	RDB (Boric acid, refillable)	15-34.5
	DBA (Boric acid, non-refillable)	46-69
	DBU (Boric acid, non-refillable)	15-34.5
Kearney/Eaton	HX	15
	HX	27
S & C Electric*	SMD (Boric Acid)	15-138
Southern States	Series P	15-161

*Available with porcelain insulators. “Available with "Cypoxy" cycloaliphatic epoxy insulators 34.5 kV on request.

NOTE: All fuses listed on this page should be furnished with NEMA standard insulators. The buyer should specify the current rating, voltage rating, interrupting rating and required accessories.

af - Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating	Conditions
Peak Demand Inc.	FCS series (polymer)	15, 27, 36kV	To obtain experience.

af - Cutouts, Distribution, Open with Linkbreak Attachment

Manufacturer	Type	Voltage Rating	Conditions
Hubbell	C	15, 27 kV	1. To obtain experience. 2. Limited to 100 amp cutouts. 3. To be used only with Hubbell (Chance), Eaton and Kearney fuses. Will not break S&C and some other fuse types.
	C-Polymer	15, 27, 35kV	1. To obtain experience. 2. Limited to 100 amp cutouts. 3. To be used only with Hubbell (Chance), Eaton and Kearney fuses. Will not break S&C and some other fuse types.

ag - Fuses, Current Limiting, Backup

Manufacturer	Conditions
ABB 15 kV Class Type CLTX, 25K/15T 25 kV Class Type CLTX, 25K/15T	1. To obtain experience. 2. Must be used in series with external expulsion fuse 25K OR 15T or smaller or with CSP transformers 50 kVA or smaller.
Eaton 15 kV Class FAH series 25 kV Class FAH series	Same as above.
General Electric 15 kV Class 9F59U Series 25 kV Class 9F59U	Same as above.
High-Tech Fuses 15 kV Class No. HTDE23 (X)025 25 kV Class No. HTDE24 (X)025 35 kV Class No. HTDE25 (X)025	Same as above.
Hubbell (Chance) 15 kV Class Type K-Mate 25 Catalog No. C70L-31KA 25 kV Class Type K-Mate 25 Catalog No. C70L-32KA	Same as above.

ah - Tie, insulator, formed type

AFL	DTF "Dist. F Neck Tie w/Pad" (Order for specific conductor size and insulator)
	DBST "Double Side Tie w/Pad" (Order for specific conductor size and insulator)
	SPL “Spool Tie for ACSR* (Side tie for use on spool insulator with 1-3/4" Neck)
	DSTCF “Double support Tie (Order for specific conductor size and insulator)
	STF “Side Tie w/pad” (Order for specific conductor size and insulator)
	LTF “Longspan Tie w/pad” (Order for specific conductor size and insulator)
Dulmison	LT "Longspan" top tie (Order for specific conductor size and insulator) ST side tie (Order for specific conductor size and insulator) Type SPL* (Side tie for use on spool insulator with 1-3/4" groove) DBST double side tie (Order for specific conductor size and insulator) DST double support tie (Order for specific conductor size and insulator)
Helical Line Products	HTT Series (Order for specific conductor size and insulator)
Hubbell (Chance)	Super Top-Tie, Type STT for single or double support use, with insulators 2-1/"" through 3-1/2" neck diameter and single support use on spool insulators with 1-3/4" groove diameter (Order for specific conductor size.)
Preformed Line Products	Alloy Side, Spool and Top Ties EZ-WRAP* spool tie (order for specific conductor size) EZ-WRAP Side Ties, EZST-series EZ-WRAP Twin Ties, TT-series WT "Wraplock" (Order for specific conductor size an“ insulator) S” "Groove-Formed" side tie (Order for specific conductor size and insulator) Spool Tie for ACSR, Type SPL* (Side tie for use on spool insulator with 1-3/4" groove) DST double support top tie (Order for specific conductor size and insulator) DBST double side tie (Order for specific conductor size and insulator) UT-series Distribution Tie

*Not for side mounting on pin or post insulators.

ah - Tie, insulator, formed type

Manufacturer	Conditions
Dulmison Type QSPL “Quick Spool” spool tie (Order for specific conductor size)	To obtain experience.

ai - Rods, Ground, 13-mil

Applicable Size: The standard length is 8 feet and catalog numbers listed below are for this length. Longer rods may be required for special conditions.

Copper-covered ground rods are listed with a **13-mil minimum** at any point and a 15-mil average covering of copper. All purchases should specify that a factory certification of the thickness of the copper must accompany the shipment of the rods.

Copper-covered

	5/8"	3/4"
Alumoclad	AL- 588	-
Blackburn	625813MX	-
Boggs	EB-810-13	-
Erico	615883	-
Galvan Industries, Inc.	6258G13	7508G13
Harger	588RUS	
Joslyn	J8338-13	-
Korns	KCG588-13	-
Republic Wire	RGC5883	-
South Atlantic, LLC (Southern Grounding)	C58813	C34813
Wilcor	WA588C	-

ai - Rods, Ground

Applicable Size: The standard length is 8 feet and catalog numbers listed below are for this length. Longer rods may be required for special conditions.

Hot Dip Galvanized Steel

Manufacturer	5/8"	3/4"
Blackburn	-	GR7508
Boggs	G588	G348
	PTG588**	PTG348**
Dixie	D8578	D8618
Erico	815880	813480
	815889**	813489**
Galvan Industries, Inc.	GR6258F	GR7508F
	GR6258FP**	GR7508FP**
Grip-Tite	GT588	GT348
Hubbell (Chance)	8578	8618
	C203-0107**	-
	C203-0377*	-
Joslyn	J5328	J5338
Korns	KG58	KG34
Kortick	K4658	K4678
Line Hardware	GR-588G	GR-348G
Lloyd	6258H	7508H
MacLean (Continental)	U5307	U6338
Porcelain Products	7338	7348
South Atlantic, LLC (Southern Grounding)	ZZ588	Z348
Wilcor	WA8580G	WA8340G

Electro-Galvanized Steel

Apache	G588	G348
	G588PT**	G348PT**
Blackburn	GR6258	-
Calpico	G8580	-
LMP	6258E**	7508E**

Stainless Steel

Erico	685880	683480
Galvan Industries, Inc.	S6258	S7508
Harger	588SS3	-
Wilcor	WA 588-S	WA348-S

*Rod furnished with clamp.
**Rod furnished with 4 ft., No. 6 tinned or galvanized copper pigtail.

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

ai - Rods, ground, sectional, 13-mil

Galvanized steel and
Copper-covered steel

Copper-covered ground rods are listed with a **13-mil minimum** at any point and a 15-mil average covering of copper. All purchases should specify that a factory certification of the thickness of the copper must accompany the shipment of the rods. Rods are copper-covered unless marked galvanized steel.

Sectional Ground Rods

Manufacturer	8' long	10' long	Coupling	Driving studs
Blackburn	6258S13MX	6260S13MX	60C 60CNT2*	60DS 60DSNT*
Demark	-	-	GRC 58B*	-
Galv. Steel			GRC 58G*	
Erico	635883	635803	CR-58/CC-58*	DS58
Galvan Industries, Inc.				
Galv. Steel	6258G13S	6260G13S	GRC-625G** GRC-34G**	
Copper-covered			60-C 60-TC*	60-DS
Hubbell (Chance)				
Galv. Steel	C203-0052	8512	8611	-
Joslyn	-	-	J9182	J9186
Galv. Steel	-	-	J23282A	-
South Atlantic, LLC				
(Southern Grounding)	CS58813 CS34813	CS581013 CS341013	- -	- -

* Threadless coupling or drive head
** Threadless coupling for galvanized rod

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

ai - Rods, Ground, 10-mil

These copper-covered ground rods are listed with a **10-mil minimum** at any point. They must also be Underwriters Laboratory (UL) listed. All purchases should verify that rods have official UL mark.

Copper-covered steel

Manufacturer	5/8" x 8'	¾" x 8'	5/8" x 10'	¾" x 10'
Erico	615880	613480	615800	613400
Galvan Industries, Inc.	6258	7508		
Southern Grounding Products (South Atlantic, LLC)	C588	C348	C5810	C3410

ai - Rods, ground, sectional, 10-mil

Galvanized steel and Copper-covered steel

Copper-covered ground rods are listed with a **10-mil minimum** at any point. They must also be Underwriters Laboratory (UL) listed. All purchases should verify that rods have official UL mark. Rods are copper-covered unless marked galvanized steel.

Sectional Ground Rods

Manufacturer	Rod				Coupling		Driving studs	
	5/8" x 8'	¾" x 8'	5/8" x 10'	¾" x 10'	5/8"	¾"	5/8"	¾"
Erico	635880	633480	635800	633400	CR58	CR34	DS58	DS34
Galvan Industries, Inc.	6258S		6260S		60-C		60-DS	
Southern Grounding Products (South Atlantic, LLC)	CS588		CS5810		58C	34C	DS58	DS34

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

aj - Clamp, Ground Rod

Manufacturer	For 5/8" Copper-covered Rod	For 3/4" Galv. or Stainless Steel Rod	For 5/8" Galv. or Stainless Steel Rod
TE Connectivity - Energy	C-LOK Series	81412-1	81412-1
Blackburn	G5	-	-
Boggs	G31	-	-
Burndy	GRC58	-	-
C & R Products	CRGC-58	-	-
Connector Castings	G5	-	-
Dossert	GNL62H	-	-
*Erico (Cadweld)			
1 ground wire	GR1-161G	GR1-181G	GR1-161G
2 ground wires	GT1-161G	GT1-181G	GT1-161G
Erico	EHL58C1T	-	EHL58G1T
	EHL58C1K	-	EHL58G1K
	EHL58C1G	-	EHL58G1G
Eritech (Carolina Galv./Knight)	CP 58	UCSS	-
*FCI Burndy	Type BCR-1	Type BCR-1	Type BCR-1
	BS-2012	BS-2017	BS-2012
Galvan Industries, Inc.	G5	-	-
	SRC	SRC	SRC
	SRC-SS	SRC-SS	SRC-SS
	DGC-5844	-	-
	DGC-5866	-	-
Greaves/Mercury	G-580	-	-
*Harger			
1 ground wire	G11-588	G11-348	G11-588
2 ground wires	G21-588	G21-348	G21-588
Hubbell (Anderson)	GC-5	-	-
Ilsco	GRC-58	-	-
Joslyn	J8392AB	J25985	J25932
Kortick	K4647	-	-
Lew Electric Fittings	GRC-5/8"	-	-
Line Hardware	RC-58CB	-	-
Penn-Union	CEB-2	CEB-3-TN	CEB-2-TN
MacLean (Reliable)	E58	3459	3459
*Thermoweld	Type CR-1	Type CR-1	Type CR-1
	M-2012	M-2017	M-2012
Wilcor	HGR5/8	WAU 5834-B	WAU 5834-B

*Includes disposable molds.

aj - Clamp, ground rod

Manufacturer	Conditions
Burndy	
YGHP (for 5/8" copper-covered rods)	To obtain experience.
DeMark	
Copperhead (for 5/8” copper-covered, galvanized, and stainless rods)	To obtain experience.
DMC Power **	
GC***B***-625 (for 5/8” steel rods) GC***B***-662 (for 5/8” copper clad rods) GC*¾***-750 (for 3/4” steel rods)	To obtain experience.
Line Hardwar”	
RC-3¾”or 5/8" and 3/4") galvanized or stainless steel ground rods	To obtain experience.
Thomas & Betts	
DGC58-44 (#4 copper ground wire) DGC58-66 (#6 copper ground wire) (for 5/8" copper-covered rods)	To obtain experience.

** These clamps require the use of special swage connection tools for installation. Manufacturer’s recommendations should be followed.

al - Staples, ground wire

Applicable Specification: “ANSI C135.14, "Standards for Staples with Rolled or Slash Points"

Length x Spread(i¼es): Diameter:	½/2 x 1/4 9 gauge Galv. Steel	2 x 1/2 8 gauge Galv. Steel	1-1/2 x 3/8 8 gaug¼opper- Coated	3 x 1-1/16 1/4 Molding
Apollo	AP52l-S1672G	AP521-S1570	AP501-S6652	AP500-S6497
Copperweld Bimetallics, LLC	-	CP52	-	-
FWC	FW1672G	FW157	FW6652	FW6497
Hubbell (Chance)	C205-0247	C205-0216	9167	9161
Joslyn	J1672G	J157	J6652	J6497
Kortick	-	-	K247	K236
L & J Industrial Staples	C1525148-G	D2050162-G	C1538162-C	D3090250-C
Larson	-	350453	750233	721312
Lindsey	10248	-	-	10270
Minerallac (Redmore®)	CG1525K	DG2050Q CG2050Q	CC1538Q	DG3090W
MacLean (Continental)	U88	U86	U48	U46

Barbed staples, ground wire

Length x Spread (inches) Diameter	1-1/2 x 3/8 .131 Galv. Steel	2 x 5/8 .165 Galv. Steel	1-1/2 x 3/8 .140 Copper-Coated	3 x 1-1/16 7/32 Galv. Steel
Apollo	AP520-57488HTG	AP50l-S66525	-	-
Hubbell Power Systems	C205-0460	C205-0463	C205-0464	C205-0462
Joslyn	J7656	J7672	J7682	J7664
Minerallac (Redmore®)	CG1538M(B)	CG2063T(B)	CC1538P(B)	CG3090N(B)

Staples, alumoweld

Length x Spre½(inches) Diameter	2 x 1/2 ¼auge	1-1/2 x 3/8 8 gauge	3 x1-1/16 1/4 molding
Apollo	AP531-S6655AL	AP531-S6652AL	AP530-S7493AL
Minerallac (Redmore®)	-	-	DA3090W

Clip, ground wire

Kearney/Eaton	12326

al - Staples, ground wire

Applicable Specification: ANSI C135.14, "Standards for Staples with Rolled or Slash Points"

Manufacturer	Thickness (gauge)	Conditions
ITW Paslode		
GS-16 (1-1/2” Galvanized)	16 ga.	To obtain experience.
Fasco		
EF40-315 (1-9/16” Galv. Steel)	10 ga.	To obtain experience.
EF40-315CU (1-9/16” Copper-Clad)	10 ga.	To obtain experience.

Note: These staples utilize power tools for installation. Use of a hammer for hand driving of these staples is not recommended.

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

Applicable Specifications: "RUS Specifications for Rural Distribution Transformers," D-10

Listing is by type rather than by catalog number because of the many possible combinations of voltage, kVA and taps and protective equipment.

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
Power Partners, Inc.			
Conventional, single bushing	S-B3	S-B3	S-B3
Self-protected, single bushing	CSP-B3	CSP-B3	CSP-B3
Conventional, two bushing	S-A	S-A	S-A
Type S-B3 may also be obtained with internal fuse, with internal fuse and double gap, and with lightning arrester and open link cutout (Type PC).			
Arkansas Electric Cooperative			
Conventional, single bushing	ASE	-	-
Central Moloney			
Conventional, single bushing	AOD	AOD	AOD
Conventional, two bushing	AOD	AOD	AOD
Self-protected, single bushing	DVP	DVP	DVP
The single bushing transformer may also be obtained with bushing mounted cutout and lightning arrester, and with internal fuse and double gap.			
Eaton[1]			
Conventional, single bushing*	REA-Conv	REA-Conv	REA-Conv
Self-protected, single bushing*	REA-CSP	REA-CSP	REA-CSP
Conventional, two bushing*	REA-Conv	REA-Conv	REA-Conv
Conventional single bushing type may also be purchased with external overload protection and double gap and with bushing mounted cutout and lightning arrester.			

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

Note:
1. Available with optional covers insulated for 15 kV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
ERMCO, INC.[1]			
Conventional, single bushing	CONV	CONV	CONV
Conventional, two bushing	CONV	CONV	CONV
Self-protected, single bushing	CSP	CSP	CSP

The single bushing transformer may also be obtained with double gap and internal fuse (Type DG) or lightning arrester and external cutout (Type COLA).

Dead-front for use in “enclosure: Add “R"”(Radial) or "LF" (Loop feed) to designation

Howard Industries			
Conventional, single bushing	REC-C	REC-C	REC-C
Conventional, two bushing	Conv-2B	Conv-2B	Conv-2B
Self-protected, single bushing	REC-P	REC-P	REC-P
Conventional, single bushing, amorphous core	REC-C-AM	REC-C-AM	REC-C-AM
Conventional, two bushing, amorphous core	Conv-2B-AM	Conv-2B-AM	Conv-2B-AM
Self-protected, single bushing, amorphous core	REC-P-AM	REC-P-AM	REC-P-AM
Kuhlman			
Conventional, single bushing	I	I	I
Conventional, two bushing	B	B	B
Self-protected, single bushing	H	H	H

Type I may also be purchased with internal fuse, with internal fuse and double gap (Type G), and with bushing mounted cutout and lightning arrester (Type J).

Moloney Electric, Inc.			
Conventional, single bushing	CONV	CONV	CONV
Conventional, two bushing	CONV	CONV	CONV
Self-protected, single bushing	CSP	CSP	CSP

Note:
1. Available with optional covers insulated for 15 kV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

an - Transformers, distribution, pole type
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
Magnetic Electric			
Conventional, single bushing	AOD	AOD	AOD
Conventional, two bushing	AOD	AOD	AOD
Self-protected, single bushing	AOD	AOD	AOD
Magnetron, S.A.			
Conventional, single bushing, Single Phase 10–500 kVA	X	X	-
Conventional, two bushing, Single Phase 10–500 kVA	X	X	-
Sesco			
Conventional, single bushing	RU	-	-
Self-protected, single bushing	ESP	-	-
Conventional, two bushing	CONV	-	-
United (Ky. AEC)			
Conventional, single bushing	SC	SC	DSC
Conventional, two bushing	SC	SC	DSC
Self-protected, single bushing	SCP	SCP	DSCP
VanTran			
Conventional, single bushing	CR	-	-
Self-protected, single bushing	CSP-R	-	-
Conventional, two bushing	CD	-	-
Rymel SAS			
Conventional, single bushing	CONV	CONV	CONV
Conventional, two bushing	CONV	CONV	CONV

Type RU may also be purchased with internal fuse and/or lightning arrester.

SC and DSC may be purchased with external fuse and arrester (SP and DSP)

*Optional natural ester less flammable fluid filled designs are available
* Available with covers insulated for 15 kV dielectric strength
* Available with internal fuses and circuit breaker for self-protected operation.
* Available with Internal Fault Detector (IFD).
* Available with lightning arrester

an - Transformers, Power
Single-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage (kV)	Nominal OA Capacity (kVA) 167 - 833	1250 - 10,000
ABB	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
Central Moloney	34.4	X	
Eaton*	34.4	X	X
	43.8	X	X
Kuhlman	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
Pennsylvania Transformer Technology, Inc.	34.4	X	X
	43.8	X	X
	67.0	X	X
Waukesha Electric Systems	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and, 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

an - Transformers, Power
Three-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage - kV	Nominal OA Capacity 750 to 3750 kVA	Nominal OA Capacity 5 to 30 MVA
ABB	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Types UTS-A, UTT-B and UVW load tap changers.

Eaton*	34.4	X	X
	43.8	X	X

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

Transformers 5 MVA and larger also accepted as load tap changing transformers using Eaton Types 550, 550B and 550C load tap changers.

Kuhlman	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using Siemens-Allis Types TLS and TLH load tap changers

Virginia Transformer	34.4	X	X
	43.8		X
	67.0		X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB type UZE and Reinhausen type RMV-2 tap changers.

an - Transformers, Power
Three-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage - kV	Nominal OA Capacity 750 to 3750 kVA	Nominal OA Capacity 5 to 30 MVA
ABB	34.4	X	X
	43.8	X	X

Manufacturer	Primary Voltage - kV	Nominal OA Capacity 750 to 3750 kVA	Nominal OA Capacity 5 to 30 MVA
Pennsylvania Transformer Technology, Inc.	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using Eaton Types 550, 550B and 550C load tap changers.

Waukesha Electric Systems	34.4	X	X
	43.8	X	X
	67.0	X	X
	115	X	X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Type UZE; Reinhausen RMT-1;Reinhausen RMV-2; or Waukesha Electric Systems Type UZD load tap changers.

Notes:
All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and, 15 kV or 25 kV class secondary voltages.
115 kV and 138 kV transformers may have one step reduced BIL.

an - Transformers, Step Ratio, Single Phase, Autotransformers or Two-Winding Transformers for Use in System Voltage Conversion

Manufacturer	Designation	Size
Howard Industries		
2-WND	STEPS	167-500
AUTO	STEP-AUTO	100-1500

NOTE: Two-winding transformers are self-protected under external short circuit in accordance with ANSI C57.12.90A. Auto-transformers will withstand 25 times rated current under external short circuit in accordance with ANSI C57.12.90A.

an - Transformers, Distribution, Pole Type

Manufacturer	Conditions
Power Partners, Inc. 7.2/12.5, 7.62/13.2 14.4/24.9 kV & Dual Voltage	
Single-phase, single bushing, 25 and 50 kVA pole type distribution transformers with amorphous metal cores.	To obtain experience.
Single-phase, single bushing and two-bushing with internal UMX Under-oil Arrester or with internal "Tranquell" Under-oil Arrester.	To obtain experience.
Eaton[1] 7.2/12.5, 7.62/13.2, 14.4/24.9 kV and Dual Voltage*	
Single-phase, single bushing, self-protected, with Magnex Interrupter	To obtain experience.
Above or Conventional, single or two bushing; Type REA Conv. or Self-protected, single bushing Type REA-CSP with Type AZU, MOV, heavy-duty under-oil arrester.	To obtain experience.

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

ERMCO, Inc.[1] 7.2/12.5 and 7.62/13.2 and14.4/24.9 kV	
Single-phase, single bushing with internal Tranquell Under-oil Arrester	To obtain experience.

Note:
1. Available with optional covers insulated for 15 KV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

Conditional List
an(1.1)
June 25, 2020

an - Transformers, Distribution, Pole Type

Manufacturer	Conditions
Prolec GE 12.47/7.2, 13.2/7.62, & 14.4/24.9 kV; 5 through 167 kVA Single bushing and two bushing Conventional & self-protected and 12.47/7.2 x 24.9/14.4 dual voltage	To obtain experience.
Howard Industries 7.2/12.5, 7.62/13.2, 14.4/24.9 kV and Dual Voltage	
Single-phase, single bushing, and two bushing with internal "AZU" or "Tranquell" under-oil arrester	To obtain experience.
Kuhlman 7.2/12.5 kV and 7.62/13.2 kV Toroform design 10, l5, & 25 kVA	To obtain experience.
NECO 7.2/12.5 kV and 14.4/24.9 kV Single-phase, two bushing, 10-50 kVA, Conventional	To obtain experience.
VanTran 14.4/24.9 kV and Dual Voltage	
Conventional, single bushing Type CR	To obtain experience.
Conventional, two bushing Type CD	To obtain experience.
Self-protected, single bushing Type CSP-R	To obtain experience.

an - Transformers, Distribution, Pole Type with non-porcelain secondary bushings

Manufacturer	Conditions
Eaton*	
Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.	
ERMCO, INC.[1]	
Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
Howard Industries	
Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
Kuhlman	
Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
Magnetic Electric	
Fully accepted with Central Moloney polymer secondary bushings	To obtain experience.
Prolec GE	
Fully accepted with Celeco and H.J. International polymer secondary bushings	To obtain experience.
United (Ky. AEC)	
Fully accepted with Central Moloney polymer secondary bushings	To obtain experience.

Note:

1. Available with optional covers insulated for 15 KV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

Conditional List
an(2)
July 2009

an - Transformers, Power
Single-Phase, Step-Down
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience
"T" - Manufacturer to furnish RUS with satisfactory test results
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV–	Nominal OA Capacity (kVA) 167 - 833	1250 - 10,000
Delta-Star	34.4	E	E
	43.8	E	E
	67.0	E	T
	115	-	T
ESCO	34.4	E	-
Ferranti-Packard	67.0	T	E
Industrias IEM, S.A. de C.V.	67	-	E

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

Conditional List
an(3)
June 2011

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience
"T" - Manufacturer to furnish RUS with satisfactory test results
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV	Nominal OA Capacity 750 to 3750 kVA	Nominal OA Capacity 5 to 30 MVA
Delta Star	34.4	E	E
	43.8	E	E
	67.0	E	E
	115	-	E
	138	-	T
Transformers 5 MVA and larger also accepted as load tap changing transformers using Seimens-Allis Types TLS and TLH-21 load tap changers.			
Ferranti-Packard	34.4	E	T
	67.0	T	E
	115	-	E
GE-Prolec	67	-	E
	115	-	E
	138	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II, Reinhausen type RMV-A, and ABB type UZE load tap changers.			
Howard Industries	115	-	E
	138	-	E
Hyundai Heavy Industries Co., Ltd.	115	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB type UZE and Reinhausen type RMV-II load tap changers.			
Industrias IEM, S.A. de C.V	115	-	E
MGM	34.4	E	T
	43.8	E	T
	67.0	T	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Types UTS-A and UTT-B load tap changers.			
CG Power Systems USA, Inc.	34.4	-	E
	67.0	-	E
	115	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II, Reinhausen type RMV-A, and ABB type UZE load tap changers.			
Uptegraff	34.4	T	E
	43.8	T	E

Conditional List
an(3.1)
November 18, 2020

an - Transformers, Power
Three-Phase, Step-Down
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience
"T" - Manufacturer to furnish RUS with satisfactory test results
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV	Nominal OA Capacity 750 to 3750 kVA	Nominal OA Capacity 5 to 30 MVA
Georgia Transformer	138	-	E
WEG	67.0	-	E
	115	-	E
	138	-	E
Howard Industries	67.0	-	E

Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II load tap changers.

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

Conditional List
an(4)
February 2014

an - Transformers, Step Ratio, Single Phase,
Autotransformers or Two-Winding Transformers
for Use in System Voltage Conversion

Condition of Acceptance: To obtain experience

Manufacturer	Designation	Size
Power Partners, Inc.		
2-WND	"Jumbo"	167-500
Central Moloney		
2-WND	AOD	167-500
Eaton*		
2-WND	"Round-Coil"	167-500
AUTO	MEPS-AUTO	167-1000

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

Delta Star		
2-WND	LTD	167-500
AUTO	LTD-A	167-1000
General Electric		
2-WND	HS STEP	167-500
AUTO	HS STEP	167-1000

NOTE: Two-winding transformers are self-protected under external short circuit in accordance with ANSI C57.12.90A. Auto-transformers will withstand 25 times rated current under external short circuit in accordance with ANSI C57.12.90A.

ao - Bolt, strand eye, straight (thimble eye)

Applicable Specification:	ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction."
Applicable Sizes:	5/8 inch, 6 through¾ inch length 3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specification:

Hubbell (Chance)
Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)

ap – Clamp, hot line
Copper and Copperweld-copper Conductor
(Clamps with internal springs and enclosed threads)

Conductor	Conductor Size
Copper:	6 thru 2/0
Copperweld-copper:	8A thru 2A

Manufacturer	
AFL	HT1-563/563RUS
	HT2-858/563RUS
Blackburn	HLC 2108
Connector Products, Inc.	HTC 100
	HTC 100-6
	HTC 200
	HTC 200-4
Electric Motion Company	EM HLC-101
H-J Enterprises	UBBC20-001
Hubbell (Anderson)	BC-2/0
Hubbell (Chance)	S1520CC
Hubbell (Fargo)	GH-100S
	GH-201 (For use with CL Fuse)
Ideal	3532
MacLean (Reliable)	C1520
Penn-Union	HLC-020-LS
Richards Manufacturing, Sales Inc.	BHLC-100

ap - Clamp, hot line
ACSR with armor rods
Clamps listed below have spring action and enclosed thread chambers.

Manufacturer	Tap Conductor	Conductor Size 477 & 336.4	4/0 & 3/0	2/0	1/0 & 2	4
Aluma-Form	Aluminum		AF-1540	AF-BC20	AF-1530	AF-BC20
	Copper		AF-1540	AF-BC20	AF-1530	AF-BC20
AFL	Aluminum	HT2-858/563RUS HT3-1125/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS	HT1-563/563RUS
	Copper	HT2-858/563RUS HT3-1125/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS	HT1-563/563RUS
Connector Mfg.	Aluminum		HL 4/0	-	-	-
	Copper		-	-	-	-
Connector Products, Inc.	Aluminum	HTC 200 HTC 200-4 HTC 300	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6	HTC 100 HTC 100-6
	Copper	HTC 200 HTC 200-4 HTC 300	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6	HTC 100 HTC 100-6
H-J Enterprises	Aluminum		-	UBBC30-001	UBBC30-001	UBBC30-001
	Copper		-	UBBC30-001TP	UBBC30-001TP	UBBC30-001TP
Hubbell (Anderson)	Aluminum		AC-800	AH-4	AH-4	AH-4
	Copper		AC-800-GP	AH-4-GP	AH-4-GP	AH-4-GP
Hubbell (Chance)	Aluminum		S1540-AA	S1540-AA	S1530-AA	S1530-AA
	Copper		S1540-AC	S1540-AC	S1530-AC	S1530-AC
Hubbell (Fargo)	Aluminum		GH-202AL	GH-202AL	GH-101A	GH-101A
	Copper		GH-102AC	GH-102AC	GH-101AC	GH-101AC
MacLean (Reliable)	Aluminum		-	-	C1530A	C1530A
	Copper		-	-	C1530A	C1530A
Penn Union	Aluminum		-	-	HLCA-040	HLCA-040
	Copper		-	-	HLCA-040	HLCA-040
Richards Manufacturing, Sales Inc.	Aluminum				AHLC300-TN	AHLC300-TN
	Copper					
Utilco	Aluminum		-	HLC-397	-	HLC-40
	Copper		-	-	-	-

ar - Wireholder

Applicable specification: "RUS Specification for Service Wireholders," D-15

	With #22 Wood Screw
Blackburn	SW3
Hubbell (Chance)	3-11-44
Porcelain Products	1986

NOTE: For triplex type service cable see clevis type wireholders on page bt-1.

ar - Wireholder
(with #22 wood screw)

Manufacturer	Conditions
Hubbell Power Systems (Chance) C207-0138 (nylon alloy)	To obtain experience.
Joslyn J089Z (nylon alloy)	To obtain experience.

as - Clevis, service swinging

Applicable Specifications: "RUS Specifications for Service Swinging Clevises," D-7

Manufacturer	Clevis Only*	Clevis with Wet Process Spool	Clevis with Dry Process Spool
Hubbell (Chance)	1948C	1948C-C909-1031	1948C-0606
Joslyn	J1614	-	-
Kortick	K9260	K9141	K9142
MacLean (Continental)	U32004	U31003	U31004

*Catalog number does not include spool; for spool insulators see Item cm.

at - Guy Marker, 8 Foot Length

Steel

Manufacturer	Full Round	Half Round
Joslyn	J1618	J1528
Kortick	K3729	-

at - Guy Marker
8 Foot Length
Plastic or Fiberglass

Manufacturer	Catalog Number
Auburn Extrusions	TK-808 (Yellow) (with bolt type clamp)
Charles Industries	12-08GWMYC-FR
Custom Plastics	CPI-100XX-PVC Series
Dulmison	HGG-OL8Y-C (Yellow)*
Electrical Materials	70-7 tie G (Gray)* 70-7 tie Y (Yellow)* 70-7 tie O (Orange)* 70-7 tie YORS (Yellow with Orange Stripes)*
Hubbell (Chance)	96-PBG-2 (Gray) 96-PBG-2Y (Yellow) 96-PBG-2ORG (Orange) 96-FRPMR-GRY (Gray)* 96-FRPMR-YEL (Yellow)* 96-FRPMR-ORG (Orange)* 96-FRPMR-GRN (Green)*
Jabat, Inc.	BU31020YE (Yellow) ILQT2291 (Yellow)
Joslyn	J1491Y (Yellow) J1491G (Gray) J5518 (Yellow)*
Mangrum	R-8-Y
Osmose	OZ-25-18R (Yellow)
Preformed Line Products	PG-5508 (Gray)* PG-5518 (Yellow)*
Radar	6032B (Yellow)*
Vaughn	003-7l40 (Gray)* 004-7l40 (Yellow)* 005-7l40 (White)*
Virginia Plastics	TG-137-8G (Gray)* TG-137-8Y (Yellow)* FG-8G (Gray)** FG-8Y (Yellow)**

* For use with formed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.
** Available with either 1 or 2 bolt clamps.

at - Guy Marker
(Non-Flame Retardant)
8 Foot Length
Plastic or Fiberglass

Manufacturer	Catalog Number
Central Moloney, Inc.	70383818 w/Cable Tie 70383819 w/Metal Clamp
Custom Plastics	CPI-100XX-PVC Series
Charles Industries	12-08GWMYC
Joslyn	J5718 (Yellow)* J1493Y (Yellow)
L. F. Manufacturing	MS-8-Y
Petroflex	P100-SDR17 Series
Preformed Line Products	PG (Poly) Series
R&M Plastics	GGY-TU-8 RMY GG-SM-8*
Radar Engineers	6034 and 6036
Virginia Plastics	TGP-16 PF

*For use with formed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.

Conditional List
at(1)
February 2013

at - Reflective Guy Marker, 8-foot length

Plastic or Fiberglass

Manufacturer	Conditions

av – Conductor, ACSR

Applicable Specification: ASTM Specification B 232

Preferred Sizes:

Distribution	Transmission
4 – 6/1	1/0 – 6/1
4 – 7/1	2/0 – 6/1
2 – 6/1	3/0 – 6/1
2 – 7/1	4/0 – 6/1
1/0 – 6/1	266.8 kcmil – 26/7
2/0 – 6/1	336.4 kcmil – 26/7
3/0 – 6/1	477 kcmil – 26/7
4/0 – 6/1	556.5 kcmil – 26/7
266.8 kcmil 18/1	795 kcmil – 26/7
336.4 kcmil 18/1	954 kcmil – 54/7
477 kcmil 18/1	

NOTE: Larger sizes may be used where the engineer's study shows they are required.

The following manufacturers have shown compliance with the applicable specifications:

Alcan Cable
Alubar
Centelsa
Conductores Monterrey S.A. de C.V.
Condumex
Encore Wire Corporation
General Cable
Kobrex S.A. de C.V.
Marmon Utility LLC (Hendrix/Kerite)
Midal Cables Ltd.
Nehring
Nexans Canada
Nexans Korea
Noranda
Phelps Dodge
Phelps Dodge – Honduras
Phelps Dodge – Mexico
Procables S.A.
Prysmian
Southwire
Synergy Cables USA, Ltd.
Taihan Electric Wire
WTEC

NOTES:

1. Conductors with 18/1 stranding have different sag characteristics than conductors with 6/1 or 26/7 stranding. This difference in sag characteristics must be taken into consideration in the line design.
2. 266.8 kcmil 26/7, 336.4 kcmil 26/7, and 477 kcmil 26/7 may be used for distribution underbuild on transmission lines.

av - Conductor, copper

Applicable Specifications: ASTM Specification B1 for hard-drawn solid
ASTM Specification B8 for hard drawn stranded and soft stranded
ASTM Specification B3 for soft or annealed solid

Preferred Sizes: Hard-drawn solid - 4 and 6
Soft or annealed solid - 4 and 6
Hard-drawn stranded - 2x3, 1/0 x 7, 2/0 x 7
Soft stranded - 4 and 6

The following manufacturers have shown compliance with the applicable specifications:

Alan Wire Company

Conductores Monterrey S.A. de C.V.

Condumex

Copperweld

Encore Wire Corporation

General Cable

Hickory Wire, Inc.

Nehring

Procables S.A.

Republic Wire

Rome Cable

Seal Wire Company

Service Wire Company

Southwire

av - Conductor, Copper and Copper-clad steel

Applicable Specification: ASTM Specification B 229

Preferred Sizes

Distribution	Transmission
8A	1/0 F
6A	2/0 F
4A	3/0 F
2A	4/0 F

The following manufacturers have shown compliance with the applicable specification for the sizes indicated:

Copperweld Bimetallics, LLC	(All sizes)
Southwire	(2A and smaller)

av - Conductor, Service
(Single Conductor)

Manufacturer	Aluminum	Copper
Alcan Cable	x	-
Conductores Monterrey	x	-
Condumex	x	x
Encore Wire Corporation	x	-
General Cable	x	x
Nehring	x	-
Nexans Canada	x	-
Prysmian	x	x
Rome Cable	x	x
Southwire	x	x

Applicable Specification: ICEA S-95-658 / NEMA WC70

Insulation: Cross-linked thermosetting polyethylene or equal.

Conductor: MHD copper or HD (Aluminum 1350) aluminum (Compact or compressed stranded conductor is acceptable.)

Marking: Manufacturer's name and type of insulation shall be clearly shown in durable markings on the surface of the insulation at intervals no greater than 24 inches.

av - Conductor, Service Cable
(Triplex and Quadruplex)

Manufacturer	Aluminum	Copper
Alcan Cable	x	-
Conductores Monterrey	x	-
Condumex	x	x
Encore Wire Corporation	x	-
General Cable	x	x
Hendrix	x	x
Nehring	x	-
Nexans Canada	x	-
Phelps Dodge	x	x
Phelps Dodge (Honduras)	x	-
Prysmian	x	x
Rome Cable	x	x
Service Wire	-	x
Southwire	x	x

Applicable Specifications: RUS Specification D-2, Specifications for 600 Volt Neutral-Supported Secondary Service Drop Cables.

av - Conductor, Aluminum Alloy

Applicable Specification: ASTM Specification B399

Preferred Sizes:

DISTRIBUTION		TRANSMISSION	
6201	ACSR Equiv.	6201	ACSR Equiv.
48,690 cmil - 7 str.*	4	123,300 cmil - 7 str.**	1/0
77,470 cmil - 7 str.*	2	155,400 cmil - 7 str.**	2/0
123,300 cmil - 7 str.	1/0	195,700 cmil - 7 str.**	3/0
155,400 cmil - 7 str.	2/0	246,900 cmil - 7 str.	4/0
195,700 cmil - 7 str.	3/0	312,800 cmil - 19 str.	266,800 cmil
246,900 cmil - 7 str.	4/0	394,500 cmil - 19 str.	336,400 cmil
		559,500 cmil - 19 str.	477,000 cmil
		652,400 cmil - 19 str.	556,500 cmil
		927,200 cmil - 37 str.	795,000 cmil

*Not recommended for multiphase lines with span lengths exceeding 300 ft.

**Not recommended for suspension type construction.

The following manufacturers have shown compliance with the applicable specifications:

Manufacturer	Type
Alcan	6201
General Cable	6201
Midal Cables Ltd.	6201
Procables S.A.	6201
Phelps Dodge	6201
Southwire	6201
Condctores Monterrey	6201

av - conductor

Manufacturer	Conditions
Alcan Cable Duplex type, with ACSR or AAAC (6201) conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations.
Copperweld Bimetallics, LLC Alumoweld-aluminum 6/1 ACSR/AW, 2, 1/0, 2/0, 4/0 4/3 AWAC, 4, 2, 1/0	1. To obtain experience.
General Cable ACSR/TW, ACSS/TW conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.
Phelps Dodge ACSR/TW, ACSS/TW conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.
Viakon Conductores Monterrey ACSR/AW-TP conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.

Conditional List
av(2)
May 8, 2025

av – covered tap wire
(for use as primary jumpers)

Manufacturer	Conditions
Copperweld	
Stingray	To obtain experience.
Hendrix	
TW#2, TW#4	To obtain experience.

Conditional List
av(3)
July 2009

av - Conductor, Service
(Single and Multi-Conductor)

Manufacturer	Conditions
Southwire	
SIW (Single input wire) type construction in accordance with ASTM B 901.	1. To obtain experience.

Applicable Specification: ICEA S-95-658 / NEMA WC70

Insulation: Cross-linked thermosetting polyethylene or equal.

Conductor: HD (Aluminum 1350) aluminum

Marking: Manufacturer's name and type of insulation shall be clearly shown in durable markings on the surface of the insulation at intervals no greater than 24 inches.

Conditional List
av(4)
April 2015

av – Conductor, High Temperature

Preferred Conductor Sizes
(equivalent in diameter to the following ACSR conductors)*

Transmission Lines
336.4 kcmil - 26/7
477 kcmil - 26/7
556.5 kcmil - 26/7
795 kcmil - 26/7
954 kcmil - 54/7
1272 kcmil - 54/19

Manufacturer	Conditions
3M ACCR – Aluminum Conductor Composite Reinforced CTC Global ACCC – Aluminum conductor Composite Core General Cable ACSS – Aluminum Conductor Steel Support Viakon ACSS - Aluminum Conductor Steel Support	1. To obtain experience. 2. Conductor handling and installation shall be i accordance with the manufacturer's recommendations. 3. Use high temperature accessories approved by the manufacturer and accepted by RUS.

NOTES:
1. Larger sizes may be used where the engineer's study shows they are required.
2. Conductor diameter should be within 10% of ACSR equivalent diameter size.

Conditional List
av(5)
July 2009

av – Conductor, Twisted Pair (T-2 & VR type)

Preferred Conductor Sizes
(equivalent in diameter to the following ACSR conductors)*

Transmission Lines
336.4 kcmil - 26/7
477 kcmil - 26/7
556.5 kcmil - 26/7
795 kcmil - 26/7
954 kcmil - 54/7
1272 kcmil - 54/19

T-2 type (ACSR-II)

Aluminum Conductor Steel Reinforced- Twisted Pair
ACSR or AAAC (6201)

Manufacturer	Conditions
General Cable Nexans Canada	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Use accessories recommended by the manufacturer and accepted by RUS

VR-2 type

Aluminum Conductor Steel Reinforced- Twisted Pair
ACSR or AAAC (6201)
Vibration Damping

Manufacturer	Conditions
Southwire	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Use accessories recommended by the manufacturer and accepted by RUS

NOTES:
1. Larger sizes may be used where the engineer's study shows they are required.
2. Conductor diameter should be within 10% of ACSR equivalent diameter size.

aw - Washer, spring

Clip
1/4" x 1-3/4" x 3-1/2"

Manufacturer	Bolt Size 5/8"	3/4"	7/8"
Allied Bolt, Inc.	7013	7014	-
Hubbell (Chance)	3540	3541	-
Joslyn	J3540	J3541	J3542
Kortick	K2909	-	-
Line Hardware	SCW-58	SCW-34	SCW-78

Double Coil Lock

Manufacturer	Bolt Size 5/8"	3/4"	7/8"	1”
Electrical Materials Company	#MW 5/8”	#MW 3/4” #MW3/4EXT	#MW 7/8”	#MW 1”
Allied Bolt, Inc.	1108	1109	1120	1121
Line Hardware Inc.	DLW-58	DLW-34	DLW-78	-

ax - Cutout and Arrester, Combination

Nominal System Voltage		For 12.5Y/7.2 kV			For 13.2Y/7.6 kV		For 24.9Y/14.4 kV	
Cutout Max. Voltage Rating		7.8 kV		15 kV	15 kV		18 kV	27 kV
Application				3ø Bank		3ø Bank		3ø Bank
		1ø Trans.	1ø Sect.	3ø Sect.	1ø Trans.	3ø Sect. 1ø Sect.	1ø Trans.	3ø Sect. 1ø Sect.
Cutout Current Rating		50*	100	100	50*	100	50*	100
Manufacturer	Type Mounting	Catalog Numbers						
ABB	Crossarm		7.8 NCX/9 LVG	15 NCX/10 LVG		15 NCX/10 LVG		24.9 NCX/18 LVG
	Crossarm (L)		7.8 LBU-II/9 LVG	15 LBU-II/10 LVG		15 LBU-II/10 LVG		24.9 LBU-II/18 LVG
Eaton	Crossarm (L)		AFZS510B Series	AFZS510C Series		AFZS510C Series		AFZS518D Series
	Transformer	AFZS110M010			AFZS110M010		AFZS110M018	
	Crossarm		L4B Series (Porcelain)	L4B Series (Porcelain)		L4B Series (Porcelain)		L9C or L9d series (Porcelain)
			S4B Series (Polymer)	S4B Series (Polymer)		S4B Series (Polymer)		S9D Series (Polymer)
Hubbell	Crossarm		C7 Series	C7 Series		C7 Series		C7 Series
	Transformer							
	Crossarm			CP7 Series (Polymer)				
Kearney/Eaton	Crossarm			KE3AB110E-110		KE4AB110E-110		KE7BD109E-110
	Transformer	294072			294073		294074	

Either normal duty or heavy duty distribution class arresters listed on page ae-1 are acceptable for use with these combination units.

*These cutouts have open links and must not be used where fault currents are high or for sectionalizing.

(L) Indicates loadbreak type is available.

az - Pole Numbers and Letters, Metal

Manufacturer	Catalog No.
Almetek Industries, Inc.	"E-Z Tags" - Order by description
Premax Products	1523
Tech Products	Everlast Tag
Electromark	EMB-1.5 EMB-3.0 HOLD-AL1 HOLD-PL1 PERMAGRAVE SLIDE-INS #ET1041-KY-1S PERMAHOLD-AL1 PERMAHOLD-PL1 SLIDE-1S

ba - Bolt, Angle Eye

Thimble Type

Applicable Specification: ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction"

Applicable Sizes : 5/8 inch, 6 through 12 inch length
3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specifications:

Allied Bolt, Inc.
Hubbell (Chance)
Joslyn Mfg. and Supply Company
Kortick Manufacturing Company
MacLean (Continental)

bb - Brace, sidearm vertical

	26" brace 24" bolt-hole spacing	50" brace 24" bolt-hole spacing
Dixie	D6986	D6987
Kortick	K1931	K1932
MacLean (Continental)	U5249	U5250

be - Reclosers, oil and vacuum

Mfr.	Phases	Type	Circuit Voltage	Continuous Rating	Int. Rating	Oil/ Vacuum	Hydraulic/ Electronic
Eaton	1	H	12.5/7.2	5-50	1250	O	H
	1	4H	12.5/7.2	5-100	2000	O	H
	1	L	12.5/7.2	25-100	4000	O	H
	3	6H	12.5/7.2	5-100	2000	O	H
	3	W	12.5/7.2	100-560	10,000	O	H
	3	WE	12.5/7.2	560	10,000	O	H
	3	VSA-12	12.5/7.2	100-560	12,000	V	E
	1	E	24.9/14.4	5-100	2500	O	H
	(Type E available with shunt lockout solenoid for three-phase operation)						
	1	4E	24.9/14.4	50-200	4000	O	H
	3	WV	34.5/19.9	560	8000	O	H
	3	WVE	34.5/19.9	560	8000	O	E
Lexington Switch and Controls	1	A Line Model B	12.5/7.2	5-50	1250	O	H
	1	A Line Model D	12.5/7.2	25-100	2000	O	H
	1	A Line Model K	12.5/7.2	25-100	4000	O	H

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, oil circuit

12.5/7.2 kV

Manufacturer	Conditions
ABB Three phase oil circuit recloser (Shunt trip with static or relay type controls)	
Type ES-400 (15-400 amperes) Type ES-560 (15-560 amperes) Type ESM-560 (100-560 amperes) Type ES-105 (15-560 amperes)	To obtain experience.
Eaton Single phase, Type D rated 100 amperes continuous, 10,000 amperes symmetrical	To obtain experience.
Lexington Switch and Controls Three phase oil circuit recloser, 50,100 and 280 ampere frames. A Line, Model 3B (5-50 amperes) Model 3D (5-100 amperes) Model 3K (25-280 amperes)	To obtain experience.

24.9/14.4 kV

Lexington Switch and Controls Oil circuit recloser, Single phase-A Line, Model M rated 100 amperes Three phase-A Line, Model 3M rated 100 amperes	To obtain experience.

34.5/19.9 kV

Eaton Single phase, Type DV rated 100-280 amperes continuous, 8,000 amperes symmetrical	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Reclosers, vacuum interrupter

Manufacturer	Conditions
ABB	
Three phase Type ESVA rated 560/800 amps continuous, 12,000 amps symmetrical, maximum voltage 15.5 kV for 12.5/7.2 kV	To obtain experience.
Three phase Type ESMVA rated 560 amps continuous, 16,000 amps symmetrical, maximum voltage 15.5 kV for 12.5/7.2 kV	To obtain experience.
Eaton	
Single Phase Type V4E rated 15 to 200 amperes continuous, 6,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV.	To obtain experience.
Single phase, Type V4H rated 5-100 amperes continuous, 2,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Single phase, Type V4L rated 50-100 amperes continuous, 6,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type V6H rated 5-100 amperes continuous, 2,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser vacuum interrupter

Manufacturer	Conditions
Eaton	
Three phase, Type VW rated 560 amperes continuous, 2,000 amperes symmetical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VWE rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VSA-16 rated 560 amperes continuous, 16,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VWV27 rated 560 amperes continuous 12,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Three phase, Type VWVE27 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Three phase, Type VWV38 rated 50-560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for34.5/19.9 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interrupter

Manufacturer	Conditions
Eaton Three phase, NOVA-NXT rated 800 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.
Three phase, Type VWVE38 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Three phase, Type VSO-12 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Three phase, Type VSO-16 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Single phase, type VXE electronically controlled, vacuum interrupting, rated 10-200 amps continuous, 8000 amperes symmetrical, maximum voltage of 15.5 kV for 12.5/7.2 kV & 27 kV for 24.9/14.4 kV systems	To obtain experience.
Engineering & Equipment de Mexico Three phase, type, EEVW15, rated 25 to 560 amp continuous, 12000 amp interrupting, maximum voltage 15.5 kV for 12.4/7.2 kV.	To obtain experience.
Hubbell Power Systems Single phase, Type VERSA-TECH electronically controlled, vacuum interrupting, rated 400 amperes continuous, 8,000 amperes symmetrical, maximum voltage of 27 kV for 24.9/14.4 kV systems	To obtain experience.
Joslyn Three phase, Type JVR, SF6 insulation, rated 400 amps continuous, 6,000 amperes symmetrical, maximum voltage 15 kV for 12.5/7.2 kV	To obtain experience.

NOTES:
1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

Conditional List
be(2.3)
November 29, 2022

be - Recloser, vacuum interrupter

Manufacturer	Conditions
Lexington Switch Single phase, type EV627 rated 400 amp continuous, 6000 amp interrupting, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Single phase, type EV815 rated 400 amp continuous, 8000 amp continuous, maximum voltage 15.5 kV for 12.9/14.4 kV	To obtain experience.
S&C Electric Single phase, TripSaver II (cutout mounting), rated 100 amp continuous, 4000 amp and 6300 amp interrupting, maximum voltage 15.5 kV for 12.9/14.4 kV and 27 kV for 24.9/14.4 kV	To obtain experience.
Whipp & Bourne Three-phase, Type GVR, SF6 insulation with vacuum interruption, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption for 15.5 kV and 27 kV, 8000 amps RMS symmetrical for 38 kV. 15.5 kV maximum voltage for 12.5/7.2 kV, 27 kV maximum voltage for 24.9/14.4 kV, 38 kV maximum voltage for 34.5/19.9 kV.	To obtain experience.
Siemens Single phase, CMR rated 630 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.
Multi-phase, CMR rated 630 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.

NOTES:
1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, SF6 interrupter

Manufacturer	Conditions
Hawker Siddeley	
Type PMR-3/15 rated at 560 amperes continuous, 12,000 amperes symmetrical maximum, 15.5 kV	To obtain experience.
Type PMR-3/27 rated at 560 amperes continuous, 12,000 amperes symmetrical maximum, 24.9 kV	

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
ABB Single phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 800 amps maximum continuous, 10000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 630 amps maximum continuous, 12500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16000 amps RMS symmetrical interruption, 38 kV maximum for 34.5/19.9 kV.	
Eaton Three phase, Type NOVA electronically controlled, vacuum interruption, solid dielectric, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Single Phase, Type NOVA electronically controlled, vacuum interruption, solid dielectric, 400 amps maximum continuous, 8000 amps RMS symmetrical interruption, or 800 amps maximum continuous, 12500 amps RMS symmetrical interruption 15.5 kV maximum for 12.5/7.2 kV, 29.2 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type NOVA-TS Triple-Single electronically controlled, vacuum interruption, solid dielectric, 400 amps maximum continuous, 12500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 29.2 kV maximum for 24.9/14.4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

Conditional List
be(4.1)
September 2013

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
G & W Electric Company Three phase, electronic, VIPER Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14/4 kV.	To obtain experience.
Single phase, electronic, Viper SP, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Joslyn Hi-Voltage Three-phase, Type TRIMOD 300 series, vacuum interruption, solid dielectric foam, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV	To obtain experience.
Single-phase, Type TRIMOD 100 series, vacuum interruption, solid dielectric foam, 560 amps maximum continuous, 12500 amps RMS symmetrical interruption, 17.1 kV maximum for 12.5/7.2 kV, 29.3 kV maximum for 24.9/14.4 kV	To obtain experience.
Schneider Electric USA, Inc. Three phase, Type U27-12-125-630, solid dielectric insulation, 630 amps maximum continuous, 12500 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV - 125 kV BIL.	To obtain experience.
Siemens Three phase, Type SDR Recloser, rated 800A maximum continuous, electronically controlled, vacuum interruption, solid dielectric, 12500 amps RMS symmetrical interruption for 15.5 kV, 16000 amps RMS symmetrical interruption for 27 kV, (15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV)	To obtain experience.
S&C Electric Company Three phase, IntelliRupter PulseCloser with vacuum interrupter, solid dielectric, 630 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

Conditional List
be(4.2)
November 2015

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
Thomas & Betts	
Three phase, electronic, MVR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27kV maximum for 24.9/14.4 kV, 38 kV maximum for 34.5 kV/19.9 kV	To obtain experience.
Single phase, electronic, MVR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27kV maximum for 24.9/14.4 kV, 38 kV maximum for 34.5 kV/19.9 kV	To obtain experience.
NOJA Power	
Three phase, Type OSM15 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5kV maximum for 12.5/7.2kV.	To obtain experience.
Three phase, Type OSM27 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 27kV maximum for 24.9/14.4kV.	To obtain experience.
Three phase, Type OSM38 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 38kV maximum for 34.5/19.9kV.	To obtain experience.
Single Phase, Type OSM38 Series electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 38kV maximum for 34.5/19.9kV.	To obtain experience.
Schneider Electric	To obtain experience
Single phase, Type W27-ACR-Solid-24-6-125, solid dielectric insulation, 400 amps maximum continuous, 6000 amps RMS symmetrical interruption, 24 kV phase to ground - 125 kV BIL. PN 250010000	

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

Conditional List
be(4.3)
April 2, 2024

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
Southern States	
Three-phase and Single-phase, Gang Operated, type SSR, rated 900A maximum continuous, electrically controlled, vacuum interruption, solid dielectric, 16,000 amps RMS symmetrical interruption for 15.5 kV, 12,500 amps RMS symmetrical interruption for 27 kV	To obtain experience.
Togami Electric Mfg. Co., Ltd.	
Single phase, electronic, FAULT CLEAR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, electronic, FAULT CLEAR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

bh - Clevis, Service Deadend

Applicable Specification: "RUS Specification for Service Deadend Clevises," D-8

Manufacturer	Clevis Only*	Clevis with dry process spool	Clevis with wet process spool
Hubbell (Chance)	0341	0341-0606	0341-C909-1931
Joslyn	J0313	-	-
Kortick	K9250	K9100	K9099
MacLean (Continental)	U32136	U31136	U36136

*Catalog number does not include spool; for spool see Page cm.

bi - Gain, Pole

For use with rectangular crossarms

Hubbell (Chance)	4092
Joslyn (Flagg)	PX252
MacLean (Continental)	CAG-44-5

For braceless crossarms (narrow profile construction)

Hubbell (Chance)	PG84XE12
Joslyn (Flagg)	PX182A
MacLean (Bethea)	GCAF-6A
MacLean (Continental)	DEA-65-10A

Transmission

Grid Gains

	Sizes in inches	
	4" x 4"	4" x 9"
Hubbell (Chance)	PG44	PG945
Hughes Brothers	I263	I260
Joslyn (Flagg)	PX122	PX260
MacLean (Bethea)	GSF-44-7	GSFT-95-7
MacLean (Continental)	GGSF-4040-7	GRF-9045-7

bj - Guy Hook

Applicable Specification: Edison Electric Institute Specification TD-11- 1951, "Specifications for Guy Hooks and Guy Strain Plates."

Hubbell (Chance)	6584
Joslyn	J1019
Kortick	K4031
MacLean (Continental)	U5310

bk - Guy Plate

Applicable Specifications:

Strain Type: Edison Electric Institute Specification TD-11 1951, "Specifications for Guy Hooks and Guy Strain Plates."

Lift Type: None

	Strain Type 4" x 8" x 14 gage	Lift Type 2-1/2" x 7" x 1/4", 2 hole
Almat	K45-1	-
Hubbell (Chance)	6575	7898
Joslyn	J1034	-
Kortick	K4015	K3511
Line Hardware	GSP-1	-
MacLean (Continental)	U5351	UC434

bn - clamp, loop deadend

For ACSR

	3/0	2/0	1/0	2	4
AFL	-	413	413	412	411
Blackburn	DLC23	DLC2106	DLC2106	DLC2106	DLC2106
Burndy	-	-	UW25R	UW2R	UW2R
C & R	-	-	CRLD-10	CRLD-10	CRLD-10
Hubbell (Anderson)	LC-74B	LC-71B	LC-70B1	LC-70B	LC-70B
Hubbell (Fargo)	GA-145	GA-145	GA-144	GA-144	GA-144
MacLean (Bethea)	ALD-7373-U	ALD-34-U	ALD-1313-U	ALD-1313-U	ALD-1313-U

bo - Shackle, anchor

Distribution

	20,000 lbs. 5/8" Pin
Hubbell (Anderson)	AS-25
Hubbell (Chance)	5801
Joslyn	J2742
Kortick	K4481
Lapp	33852
Lindsey	3260
Line Hardware	AS-1
MacLean (Bethea)	ASH-45
Sur-Loc, Inc.	5500

Transmission

	30,000 lbs. 3/4" bolt	50,000 lbs. 7/8" bolt
Joslyn	BT3023BNK	BT3036BNK
MacLean (Bethea)	ASH-56-BC	ASH-67-BC

br – Chain Link (End Link)

Manufacturer	Catalog Number
Joslyn	BT-3082
Lapp	6415-HT
Lindsey	3403
MacLean (Bethea)	CL-5
Preformed Line Products	CL-60

bs - Bolt, single upset

Applicable Specifications: "RUS Specifications for Single and Double Upset Spool Bolts," D-5

Diameter, inches:	5/8	5/8	5/8	5/8
Length, inches:	7	8	9	10
Manufacturer				
Allied Bolt, Inc.	-	-	1712	1713
Hubbell (Chance)	-	7741	7741-1/2	7742
Joslyn	-	J2342-1/2	J2343-1/2	J2344-1/2
Kortick	K4929	K4950	K4930	K4951
MacLean (Continental)	U3105-1/2	U31053	U31053A	U31054

bt - Wireholder, clevis type
with No. 24 wood screw

(For use with triplex type service cable, Drawing K10C-A)

Hubbell (Chance)	0192*
Joslyn	J075*

*Catalog number does not include insulator. Use secondary type spool insulator with 1-3/4 inch groove diameter. See page cm-1.

bu - Connector, grounding
for transformer or other equipment

Manufacturer	Copper Alloy [1]	Plated Copper Alloy [2]	Aluminum Alloy [3]
Blackburn	TTC-4	TTC2P	-
Burndy	EQC632C	EQC632C-TN	-
Dossert	TGCL8-50	TGCL8-50-SN	-
Hubbell (Anderson)	GTCL-23A	GTCL-23A-TP	-
Hubbell (Fargo)	GC-207	GC-207P	GA-220
Line Hardware	TGL-110	TGL-110P	-
Maclean (Reliable)	BVC-207	-	-
Penn-Union	GSE-C1	GSE-C1TN	-
Richards Manufacturing, Sales Inc. (Chin Fong Co., Ltd.)	RTG512	-	-
Tanner	-	GET-1-TN	-

1 - For use with copper type ground wire.

2 - For use with both copper and aluminum type ground wire.

3 - For use with aluminum type ground wire.

bv - Rods, armor

(Includes standard, double insulator, and tapping rods)

Aluminum or aluminum alloy rods for use on ACSR

Manufacturer	Type
AFL	Formed Type
Dulmison	Formed Type
Florida Wire and Cable	Formed Type
Helical Line Products	Formed Type
Helix Uniformed Ltd.	Formed Type
Preformed Line Products	Formed Type

Copperweld rods for copper or CWC conductor

Dulmison	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

Alumoweld rods for aluminum clad steel (Alumoweld) Overhead ground wire

Dulmison	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

bx - Splice, automatic

Copper	Hubbell (Fargo)	MacLean (Reliable)
6	GL-111	61
4	GL-112	41
2 x 3	GL-115	-
1/10 x 7	GL-117	107
2/0 x 7	GL-118	207
3/0 x 7	GL-119	307
4/0 x 7	GL-120	407
CWC		
8A	GL-112	-
6A	GL-113	47
4A	GL-115	27
2A	GL-117	-
ACSR	GL-400A Series*	7650 Series*
Aluminum Alloy (6201 and 5005)	GL-400A Series	AL55 Series

*For use on conductors 4/0 and smaller only.

bx - Splice, automatic

Distribution

Manufacturer	Catalog #	AAC	AAAC	ACSR
Aluma-Form, Inc.	ASC42	#2 & #4	#2 & #4	6/1
	ASC1020	1/0 & 2/0	1/0 & 2/0	1/0 & 2/0
	ASC3040	3/0 & 4/0	3/0 & 4/0	3/0 & 4/0

Conditional List
bx(1)
July 2009

bx - Splice, automatic

Manufacturer	Conditions

DISTRIBUTION

Blackburn

#4, #2 ACSR or 6201 (ACSR equiv.) ATS42 1/0, 2/0 ACSR or 6201 (ACSR equiv.) ATS1020 3/0, 4/0 ACSR or 6201 (ACSR equiv.) ATS3040 266.8, 336.4 kcmil ACSR ATS266336 477 kcmil ACSR ATS397477	1. To obtain experience. 2. For use on distribution systems only.

Connector Products, Inc.

2 ACSR (S1000) #1 ACSR (S1000) #2 AAC (S1000) 1/0 AAC (S1000) 2/0 AAC (S1000) #2 AAAC (S1000) 1/0 AAAC (S1000)	1. To obtain experience. 2. For use on distribution systems only.

Hubbell (Fargo)

AWAC 4 - 4/3 GLA-105 AWAC 2 - 4/3 GLA-110 AWAC 1/0 - 4/3 GLA-115	Same as above.
266.8 kcmil ACSR 18/1 GL-410 336.4 kcmil ACSR 18/1 GL-411 477 kcmil ACSR 18/1 GL-413	Same as above.

MacLean (Reliable)

266.8 kcmil ACSR 18/1 7657 336.4 kcmil ACSR 18/1 7658 477 kcmil ACSR 18/1 7659	Same as above.

DISTRIBUTION AND TRANSMISSION

Hubbell (Fargo)

266.8 kcmil ACSR 26/7 336.4 kcmil ACSR 26/7 477 kcmil ACSR 26/7	To obtain experience.

by - Deadend, automatic and formed Type

Conductor Size

Cu	CWC	Hubbell (Fargo)	Maclean (Reliable)
-	4A	GD-515	27-SDS
-	6A	GD-513	47-SDS
-	8A	GD-512	-
2 x 3	-	GD-515	271
4	-	GD-512	41LD
6	-	GD-511	61LD

ACSR

*Blackburn	ATD Series
*Dulmison	AWDG-0805, 0990, and 1135
*Hubbell (Fargo)	GD-400 Series
*MacLean (Reliable)	7650 Series
Preformed	DG Series

*For use on conductors 4/0 and smaller only.

Aluminum Alloy (6201 and 5005)

Blackburn	ATD Series
Hubbell (Fargo)	GD-A Series
MacLean (Reliable)	AL Series
Preformed	DG Series

Conditional List
by(1)
July 2009

by - Deadends, automatic and formed type

FORMED TYPE

Manufacturer	Conditions
Preformed Line Products	
AWAC 4 - 4/3 DG-4560 AWAC 2 - 4/3 DG-4562 AWAC 1/0 - 4/3 DG-4565	To obtain experience.

AUTOMATIC TYPE

Hubbell (Fargo)	
AWAC 4 - 4/3 GDA-235 AWAC 2 - 4/3 GDA-240 AWAC 1/0 - 4/3 GDA-245	To obtain experience.
266.8 kcmil ACSR 18/1 GD-53I5A 336.4 kcmil ACSR 18/1 GD-53I5A 477 kcmil ACSR 18/1 GD-5325A	1. To obtain experience. 2. For use on distribution lines only.
MacLean (Reliable)	
AWAC 4 - 4/3 5201 AWAC 2 - 4/3 5202 AWAC 1/0 - 4/3 5204	To obtain experience.
226.8 kcmil ACSR 18/1 7657 SDS 335.4 kcmil ACSR 18/1 7658 SDS 477 kcmil ACSR 18/1 7659 SDS	1. To obtain experience. 2. For use on distribution lines only.

bz - Switch, oil

12.5/7.2 kV

	Type	Description
ABB	CSL**	Single-phase, manual and remote manual or elec. control, 200 amp. Three-phase, remote manual or elec. control, 200 amp.
Eaton	NR*	Single-phase, remote elec. control, 200 amp.
	VR*	Three-phase, remote elec. control, 400 amp.
General Electric	FKC-2	Single and three-phase, manual, 200 amp.
	FKC-2*	Single and three-phase, remote control, 200 amp.
Hubbell Trinetics	CSD	Single-phase, manual, and remote manual or elec. control, 200 amp. Three-phase, remote manual, or elec. control, 200 amp.
	VS	Single Phase 15kV, 95kV BIL, 200A vacuum under oil switch, with 11" creep bushings, manual handle, 120V motor operator, 5-pin receptacle, NEMA type pole mounting hanger, and (2) wildlife guards.

*Control equipment should be selected in accordance with the requirements of individual installations.

**This item is also available in a special design for use in areas where corrosion is a serious problem.

bz - Switch, oil

24.9/14.4 kV

	Type	Description
Hubbell Trinetics	VS	Single Phase 24kV, 95kV BIL, 200A vacuum under oil switch, with 11" creep bushings, manual handle, 120V motor operator, 5-pin receptacle, NEMA type pole mounting hanger, and (2) wildlife guards.

*Control equipment should be selected in accordance with the requirements of individual installations.

**This item is also available in a special design for use in areas where corrosion is a serious problem.

bz - Switch, oil

Manufacturer	Conditions
Eaton	
Capacitor oil switch Type TSC, 38 kV max. 100 ampere capacitor switch, 300 ampere load switch	1. To obtain experience.
Oil switch with125 kV BIL accessory Type NR, 15 kV, single- phase, remote electric control, 200 amp. at 75 to 100 percent power factor	1. To obtain experience. 2. For use on single- phase taps of 24.9/14.4 kV multi- grounded wye systems.

bz - Switch, vacuum
(For capacitor switching)

Manufacturer	Conditions
Eaton Type ECS, cycloaliphatic epoxy solid dielectric, vacuum capacitor switch, rated 200 amps, 95kV, 125kV and 150 bil, for use on 15kV, 25kV and 35kV grounded-wye systems	1. To obtain experience 2. The 25 kV rated switch with 150 kV external bil and 125 kV internal bil can be used in solidly grounded 35 kV applications. 3. Bil options can accommodate normal or extra creepage needs. Available in 95/95, 95/125, 125/125, and 125/50 combinations (internal bil kV/external bil kV).
Joslyn Capacitor vacuum switch, VerSaVac, 200 Amp, 95 or 125 kV BIL, single-phase or three-phase for use on 15 kV systems	1. To obtain experience. 2. Single-phase switch rated 125 kV BIL may be used on single- phase taps of 24.9/14.4 kV multi-grounded wye systems. 3. Three-phase switch requires special mounting bracket.
Yaskawa Types LFG-15E-K (15 kV), LFG-25E-K (25 kV), LFG-35E-K (35 kV) 3-phase SF6 capacitor switch, pole mounted type, 200 A (capacitive), 630 A (continuous)	1. To obtain experience.

cg - Switch, air, three-pole, group-operated
NEMA standard switches for station and line structures

Manufacturer	Acceptable Mounting on Structures	Tilting Ins. Type	Tilting Ins. kV	Vertical Break Type	Vertical Break kV	Side Break Type	Side Break kV	Center Break Type	Center Break kV	Double Break Type	Double Break kV
ABB	Horizontal			TTR6	345						
	Horizontal			TTR8	15-230						
G & W Electric Co.	Horizontal			MK-40	15-69	PMB-40A	15-69	LPC	69-230		
Hubbell (Chance)	Horizontal			D6(L)	15-34.5						
	Phase over Phase			D6(L)	15-34.5						
	Vertical			D6(L)	15-34.5						
Johnson	Horizontal			VIP	15-230	LS	15-69	M	15-230		
Joslyn (Hi-Voltage)	Horizontal			RF-2(VL)	15-230	RB-1(VL)	15-25				
	Horizontal					RB-1*	15-115				
Kearney/Eaton	Horizontal	AR 60-P	15-69								
MEMCO	Horizontal	AgF	15-69	EA	15-345			EE	69-230		
	Horizontal	AgC	15-69			Rl4-C	l5-46				
MORPAC (Morgan)	Horizontal			VBV (VL)	15-230			CBV	15-230		
	Vertical			VBV (VL)	15-230			CBV	15-230		
	Phase over Phase							CBV	15-25		
Royal Switchgear	Horizontal			AVT	15-345	SBF	15-46	V	15-230	DEB	34.5-345
								CB	34.5-230		
	Phase over Phase									DEV	69-345
	Underhung							CB	34.5-230		
	Vertical							CB	34.5-230		

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.
*These switches may be purchased with reduced voltage vacuum interrupters and may be applied for loop sectionalizing duty when peak recovery voltage does not exceed 25 kV

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.

cg - Switch, air, three-pole, group-operated
NEMA standard switches for station and line structures

Manufacturer	Acceptable Mounting on Structures	Tilting Ins. Type	Tilting Ins. kV	Vertical Break Type	Vertical Break kV	Side Break Type	Side Break kV	Center Break Type	Center Break kV	Double Break Type	Double Break kV
S & C***	Horizontal			Alduti(L)	15-34.5	Alduti(L)	15-25			Alduti(L)	34.5-46
	Phase over Phase			Alduti(L)	15-25	Alduti(L)	15-25			Alduti(L)	34.5-46
	Vertical			Alduti(L)*	15-34.5	Alduti(L)	15-25			Alduti(L)*	34.5-46
SEECO	Phase over Phase			GOABS(VL)	15-69						
Siemens-Allis	Horizontal			AVB(VL)**	115-345			CB	115-230		
								CBL-2	115-230		
Southern States	Horizontal			EV	15-230						
				TA(VL)	15-69	SSB-T	15-69	EC	115-230		
Turner	Phase over Phase					(1D, 2D, 3D)(VL)	15-161				
	Horizontal					1D(VL)	15-161				
	Horizontal			TH1(VL)	15-161						
USCO	Horizontal			AVR(VL)**	15-230	ASB	35-138	AGCH **	15-345		
	Horizontal							AGCH-V**	34.5-230		
	Phase over Phase					ASB-II	15-25	GCH	15-23		

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

*These switches, except 34.5 kV Alduti vertical break, are available and accepted with the S & C type SMD substation fuse cutouts listed on page af-3.

** Also available in bronze in some ratings.

***Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.

cg - Switch, air, three pole, group operated
(Factory Preassembled)
(FOR USE ON STEEL SUBSTATION STRUCTURES)

Manufacturer	Mounting	Vertical Type kV	Side Break Type kV
Hubbell (Chance)	Vertical	-	D7(L) 15-27
	Horizontal	-	D7(L) 15-27
S & C*	Phase-over-Phase	Alduti(L) 34.5(200 kV BIL)	Alduti(L) 34.5(200 kV BIL)
	Vertical	Alduti (L) 34.5(200 kV BIL)	

(L) Means gas or solid material full-load interrupters are accepted and available.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

cg - Switch, air, three-pole, group operated

(not Suitable for Substation Use)

Manufacturer	Acceptable Mounting	Vertical Break Type	Vertical Break kV	Side Break Type	Side Break kV	Center Break Type	Center Break kV
Hubbell (Chance)	Horizontal			D6(L)	15-34.5		
	Phase over Phase			D6(L)	15-34.5		
	Vertical	D7(L)	15-34.5				
Eaton (Kearney)	Horizontal			M-FORCE(L)	15-35		
	Phase over Phase			M-FORCE(L)	15-35		
	Vertical			M-FORCE(L)	15-35		
Royal Switchgear	Horizontal					V	15-23
	Phase over Phase					V	15-23

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.

cg - Switch, three-pole, group-operated
(Factory Preassembled)

Manufacturer	Acceptable Mounting on Structures	Vertical Break Type	Vertical Break kV	Side Break Type	Side Break kV
ABB	Horizontal (A)			SLB-3(L)	15-25
Siemens#	Horizontal (A)			Vector(L)	15-27
	Phase over phase (A)			Vector(L)	15-27
	Vertical (A)			Vector(L)	15-27
Eaton (Kearney)	Horizontal (A)			M-FORCE	15-35
	Phase over phase (A)			M-FORCE	15-35
	Vertical (A)			M-FORCE	15-35
Hubbell (Chance)	Horizontal (A)			D7(L)	15-27
	Phase over phase (A)			D7(L)	15-27
	Vertical (A)			D7(L)	15-27
	Horizontal (B)			D7(L)	34.5
	Phase over phase (B)			D7(L)	34.5
	Vertical (B)			D7(L)	34.5
Inertia Engineering	Horizontal (A)			LBS(L)	15-35
	Vertical (A)			LBS(L)	15-35
	Phase over phase (A)			LBS(L)	15-35
S&C*	Horizontal (A)			Alduti(L)	15-25
				Alduti(L) (200 kV BIL)	34.5
	Phase over phase (A)			Alduti(L)	25
				Alduti(L) (200 kV BIL)	34.5
	Vertical (A)			Alduti(L)	15-25
				Alduti(L) (200 kV BIL)	34.5
	Phase over phase (B)	Alduti(L)	34.5	Alduti(L)	34.5
	Vertical (B)	Alduti(L)	34.5		

(L) Means gas or solid material full-load interrupters are accepted and available.
(A) Not suitable for substation use.
(B) For station and transmission use only. The steel crossarm base must be grounded with an adequate grounding connector. 200 kV BIL only.

NOTES:

Switches with factory-assembled crossarm type bases for distribution lines must have non-conducting crossarm type bases, non-conducting braces, and insulated interphase and control rods, except as otherwise noted.

* Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5kV on request.

Both operating shaft and hookstick versions of switch accepted. Applies to both polymer and porcelain insulators.

cg - Switch, air, three-pole, group operated

Manufacturer	Conditions
Cleaveland/Price Type V2-C (15-69 kV) Vertical break, horizontal or vertical mounting Type RL-C (15-69 kV) Single side break, horizontal or vertical mounting	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
G & W Electric Company Type MK-40A 15 kV through 345 kV(horizontal upright mounting)	1. To obtain experience. 2. Insulated interphase and control rods required on 15 kV and 23 kV models used on wood structures. 3. Steel interphase base required when mounted as in RUS Drawing TM-3.
Type LPV, 3-pole 72.5-272 kV, 1200 amp., 1600 amp., 2000 amp., center sidebreak for horizontal mounting.	To obtain experience.
Hubbell (Chance) Type AR Side-break, horizontal phase-over-phase, and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15, 25 and 34.5 kV(grounded wye)	To obtain experience.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

cg - Switch, air, three-pole, group-operated

Manufacturer	Conditions
PASCOR VBP (15 - 230 kV) VBS (69 - 230 kV) Vertical break, vertical or horizontal mounting. Phase-over-Phase mounting(VBS, 69 - 115 kV only)	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
SB (15 - 69 kV) Side break, vertical or horizontal mounting.	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
CB (15 - 115 kV) Center break, vertical or horizontal mounting.	1. To obtain experience 2. Insulated interphase and control rods required on wood distribution structures.
CBSA (69 - 138 kV) Center Break Vee, vertical, horizontal, or phase-over-phase mounting. (Also accepted as a copper switch at 69 - 115 kV.)	To obtain experience.
S & C* Line-rupter with SF_6 interrupter. Horizontal mounted 115-230 kV	To obtain experience.
Omni-Rupter #(L) Side-break, horizontal phase-over-phase, and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15 kV and 25 kV #Both operating shaft and hookstick versions of switch accepted.	To obtain experience.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

cg - Switch, Air, Three-Pole, Group Operated

Manufacturer	Conditions
SEECO	
GOABS (VL) Vacuum interrupter type 115-169 kV	To obtain experience.
Southern States	
"Pole-Pak" 15-23 kV	To obtain experience.
Type ES; 15, 23 and 34.5 kV (horizontal upright models only)	1. To obtain experience. 2. For 15 kV and 23 kV distribution lines, insulated interphase and control rod spacers required. See RUS Drawings M3-15 and VM3-16. 3. NEMA insulators and steel interphase base required for transmission line structure as in TM-3. 4. Acceptable on steel substations 15 through 34.5 kV with NEMA insulators and uninsulated interphase rods.
Type 57L sidebreak, 115-161 kV,600 and 1200 amp., horizontal upright	To obtain experience.
Type CBL-T, 15-69 kV,1200 amp (center break, horizontal upright mounting)	1. To obtain experience. 2. Insulated interphase and control rods required on 15 kV and 25 kV models used on wood structures.
Travis Switchgear	
MA-32512, 25 kV, 150 kV BIL, vertical break	1. To obtain experience. 2. Insulated interphase and control rods required when used on wood structures.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

ci - Clevis, thimble

Rated Strength

Manufacturer	20,000 lbs.	40,000 lbs.	50,000 lbs.
Joslyn (Flagg)	PA271	PA272B	-

cj - Pole Ground Wire

Soft annealed iron, BB Grade, class C galvanizing
(For pole protection only)

Manufacturer	Size 1.15 Ohms/1000 ft., max.
Florida Wire and Cable	3-wire, 5/16 inch
Indiana Steel and Wire	3-wire, 5/16 inch
National Strand Products	3-wire, 5/16 inch
Southwire	3-wire, 5/16 inch

Copper, soft annealed solid
ASTM Specification B3

Manufacturer
(See page av-2)

Aluminum (for above ground use only)
Hard-drawn

Manufacturer
(See page av-1)

Aluminum Alloy (for above ground use only)

Manufacturer	Type
Alcan Cable	6201
American Electrical	6201
Southwire	6201

Copper-Clad Steel, Annealed 40 percent Conductivity

Manufacturer	Sizes
AFL Copperclad	No. 6, No. 4., No. 2
Copperweld Bimetallics, LLC*	No. 6 AWG No 4 AWG Stranded (7x0680”) No. 4 AWG No. 2 AWG Stranded (7x0860”) No. 2 AWG 7 No. 10 AWG 2/0 (19x0860” & 7x1379”)

* Theft deterrent versions, both poly-jacketed and camouflaged are acceptable.

cj - Pole Ground Wire, alternative conductor

Manufacturer	Conditions
ConduGround	To obtain experience.
CG-7/16”	
CG-1”	
CG-1-1/2”	
CThor55Lb	
GAP55Lb	
GAP25Lb	

ck - clamp, anchor rod bonding

For Standard and Drive Type Rods

Diam. of Rod	Type of Eye	5/8"	3/4"	1"
C & R Products	Single	CRBC-1	CRBC-1	CRBC-1
	Twin	CRBC-2	CRBC-2	CRBC-2
	Triple	-	CRBC-3	CRBC-3
Hubbell (Chance)	Single	G5060	G5060	G5060
	Twin	G5061	G5061	G5061
	Triple	-	G5063	G5063
Joslyn	Single	3230	3230	3230
	Twin	3231	3231	3231
	Triple	-	3233	3233
Kortick	Single	K3147	K3147	-
	Twin	-	K3148	K3148
	Triple	-	K3149	K3149
Line Hardware	Single	RBC-100	RBC-100	RBC-100
	Twin	RBC-200	RBC-200	RBC-200
	Triple		RBC-300	RBC-300
MacLean (Continental)	Single	UCG5060	UCG5060	-
	Twin	-	UCG5061	UCG5061
	Triple	-	UCG5063	UCG5063

For Power Installed Screw Anchors

C & R Products	Single	CRBC-4	CRBC-5	-
Hubbell (Chance)	Single	G5067	G5068	-
Joslyn	Single	J26714	J26715	-
Line Hardware	Single	RBC-400	RBC-500	-

cm - Insulator, Spool

Type:	Secondary (Wet Process)		Service: Wet Process	Service: Dry Process
Groove Diameter:	1-3/4"	3"	1-3/8"	1-3/8"
ANSI Class	53-2	53-4	53-1	NA
Eaton	DE4S3	DE5S3	DE2S2	DE2S1
Gamma Insulators Corp.	8442-70	8444-70	8441-70	-
Hughes	2102	-	-	-
ICB	ICB 532	ICB 534	ICB 531	-
Joslyn	-	J0101A	J150A	J100A
Kortick	K516	K522	K513	K514
MacLean (Continental)	U205	U31221	U208	U207
Porcelain Products (Knox)	5101	5119	5107	5207
M.D. Henry Company, Inc.	1082	-	-	-
Victor Insulators, Inc.	2012, VI 2612	2026, VI 2626	2011, VI2611	-

cm – Insulators, spool, composite/polymer

Manufacturer	ANSI Class 53-1	53-2	53-4
Aluma-Form, Inc.		INS-53-2	
Hendrix Wire and Cable	-	HPI-53-2	-
Hubbell (Chance)	-	C909-1032P	-
Preformed Line Products	-	IP-53-2	-

cp - Deadend, Compression Type

ACSR

Conductor Size	AFL	Burndy
1/0	Order by	
2/0	Conductor	Type Y-W
3/0	Size and	"
4/0	Stranding	"
		"
266.8 kcmil 18/1		
336.4 kcmil 18/1		
477 kcmil 18/1		
266.8 kcmil 26/7	2-piece	
336.4 kcmil 26/7	alloy	Type Y-W
477 kcmil 26/7	compression	Type YTW
556.5 kcmil 26/7	Type VES or	"
795 kcmil 26/7	HES	"
954 kcmil 54/7	"	"
		"

Conductor Size	Hubbell (Anderson)	Hubbell (Fargo)	Kearney/Eaton
1/0	VCD-50R	SEDA-8129	104000
2/0	thru	SEDA-7729	thru
3/0	VCD-61R	SEDA-7829	104000-03
4/0	"	SEDA-7929	"
266.8 kcmil 18/1	VCD-80-R		
336.8 kcmil 18/1	VCD-80-R		
477 kcmil 18/1	VCD-812-R		
266.8 kcmil 26/7	VCD-831-1-RM	Uni-Grip	104000-05
336.4 kcmil 26/7	VCD-831-1-RM	one die	thru
477 kcmil 26/7	VCD-832-2-RM	system	104000-14
556.5 kcmil 26/7	VCD-833-3-RM	Order by	"
795 kcmil 26/7	VCD-835-4RM	conductor size	
954 kcmil 54/7	VCD-835-4RM	and stranding	

NOTE: These compression deadends are acceptable when installed using tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, Compression Type

ACSR

Conductor Size	DMC Power
1/0	-
2/0	-
3/0	-
4/0	-
266.8 kcmil 18/1	Order by Conductor Size and Kit Pieces.
336.4 kcmil 18/1	
477 kcmil 18/1	
266.8 kcmil 26/7	One-piece Alloy Swage Full Tension Compression Type
336.4 kcmil 26/7	
477 kcmil 26/7	
556.5 kcmil 26/7	
795 kcmil 26/7	
954 kcmil 54/7	

NOTE: These compression deadends are acceptable when installed using tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, Compression Type

ACSR
Adjustable

Hubbell (Fargo)	Order by conductor size and stranding

Aluminum Alloy
(6201 and 5005)

Conductor Size:	4 thru 4/0
Hubbell (Anderson)	Type VCD, Order by conductor size

Copper

Conductor Size:	2 x 3	4	6
National Tel. Supply	71-258/3X	71-204-P	71-162-J

Copperweld-Copper

Conductor Size:	6A	8A
National Tel. Supply	71-6A-P	71-8A-P

NOTE: These deadends are acceptable when installed with tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, compression type

Manufacturer	Conditions
Burndy	
AWAC 4-4/3 YTW7M10T	To obtain experience.
AWAC 2-4/3 YTW7M9T	
AWAC 1/0-4/3 YTW7M7T	

NOTE: These deadends are acceptable when installed with tools and dies in accordance with the deadend manufacturer's recommendations.

cp –Dead-end, compression

For use with High Temperature Conductors

Manufacturer	Conditions
AFL Dead-end fitting To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
Burndy/Hubbell Dead-end Assembly To be used with CTC Global High Temperature Conductors ACCC (Aluminum conductor Composite Core)	Same as above.
Preformed Line Products (PLP) Thermolign Suspension To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	Same as above.

NOTE: These compressions are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

cq - Deadend, Secondary

(For use on secondary deadends only)

Copper
Offset Compression

Conductor Size:	4	6
National Telephone Supply	91-204-P	91-162-J

Copperweld-Copper
Offset Compression

Conductor Size:	6A	8A
National Telephone Supply	91-6A-P	91-8A-P

Copperweld-Copper
Automatic Deadend

Conductor Size:	6A	8A
Hubbell (Fargo)	GD-113	GD-112
MacLean (Reliable)	47FD	-

cr - Bracket, Angle Suspension

Applicable Specifications: "RUS Specification for Angle Suspension Brackets," DT-4

Manufacturer.	Distribution 5/8" Diam.	Transmission 3/4" Diam.
Hubbell (Chance)	-	5728
Joslyn	-	J7936
Kortick	K6231	K6230
MacLean (Continental)	U545	U546

cs - Bracket, Pole Top Pin

For Transmission and 24.9/14.4 kV Distribution

Applicable Specifications: "RUS Specifications for Pole Top Brackets for Channel Type Pins," D-14

Hubbell (Chance)	2157
Kortick	K8130
MacLean (Continental)	U36690

ct - Plate, Double Arming

Transmission

Manufacturer	4" x 1/2" x 24"	4" x 1/4" x 17"
Hubbell (Chance)	5844	5819
Joslyn	J1600	-
Kortick	K1454	K1465
Line Hardware	-	DAP-17
MacLean (Continental)	U4117	-

cu – 26 inch Brace, crossarm (side-mounted)

Manufacturer	Douglas Fir or Southern Yellow Pine	Apitong	Fiber Reinforced Plastic
Aluma-Form2	-	AF626	-
Barfield Mfg.	BAB-626	-	-
Brooks	58128	-	-
Dulmison	-	-	CAB-28
Hatheway Patterson	7026	-	
Hughes Brothers	2023	-	533
Joslyn	J5526	-	
MacLean (Continental)	-	-	CRB-28
Geotek (PUPI)	-	-	B3818SM

Note: Braces listed above have 26-inch hole spacing. They are to be used in place of the flat steel braces previously listed on page h.

cu – 60 inch Brace, crossarm (underarm)

	Span, inches:	60	60
	Drop, inches:	18	30
Manufacturer			
Aluma-Form		6018	6030
Barfield Mfg.		BAR-6018	BAR-6030
Brooks		446-60-18	446-60-30
Cox Industries		C-6018	C-6030
Dis-Tran		DT-60R	-
Hatheway Patterson		320-R	325-R
Hughes Brothers		2045-CC	2045-D
Joslyn		J4760R	J4730RW
Pennington		15018	15030
Geotek (PUPI)*		B6018BM	B6030BM
Utilities Structures Eng. Inc.		CU-60-18	CU-60-30

*Denotes Fiber Reinforced Plastic, all others are wood

cu – Bracket, Crossarm, center mount

Manufacturer	Catalog #
Brooks Manufacturing Co.	REA Type 01 FSNP-BBA REA Type 02 FSNP-BBA REA Type 03 FSNP-BBA REA Type 04 FSNP-BBA REA Type 05 FSNP-BBA REA Type 14 FSNP-BBA REA Type 22 FSNP-BBA

cx - Splice, oval tube

Copper

Conductor Size:	0 x 7	2 x 3	4	6
National Tel. Supply	464	463	459	457

Copperweld-Copper

Conductor Size:	6A	8A
National Tel. Supply	460	459

cy - Splice, Compression

ACSR

Conductor Size	AFL	Blackburn	Burndy
4 6/1	2-piece		"Unisplice"
4 7/1	Order	Type RC	(1-piece)
2 6/1	by	1-piece	or Y-S
2 7/1	Conductor	Order	(2-piece)
1/0	Size	by	Order by
2/0	and	Conductor	Conductor
3/0	Stranding	Size	Size and
4/0	"	and	Stranding
		Stranding	
266.8 kcmil 18/1			
336.4 kcmil 18/1			
477 kcmil 18/1			
266.8 kcmil 26/7	2-piece		2-piece
336.4 kcmil 26/7	Compression		Type YTS
477 kcmil 26/7	Alloy Type		"
556.6 kcmil 26/7	CJ		"
795 kcmil 26/7			"
954 kcmil 54/7			"

Conductor Size	Hubbell(Anderson)	Hubbell (Fargo)	Kearney/Eaton	
	VC-36R		2 pc	1 pc
4 6/1	VC-36R	-	-	OH4-61-71AS
4 7/1	VC-36R	-	-	OH4-61-71AS
2 6/1	VC-36R	-	-	OH2-61-71AS
2 7/1	VC-50R	-	-	OH2-61-71AS
1/0	VC-50R	TJA-8129	OH1/0-61A	OH1/0-61AS
2/0	VC-61R	TJA-7729	OHR2/0-61A	-
3/0	VC-61R	TJA-7829	OHR3/0-61A	-
4/0	-	TJA-7929	HR4/0-61A	-
	VC-80-R			
266.8 kcmil 18/1	VC-80-R	-	-	-
336.4 kcmil 18/1	VC-90-R	-	-	-
477 kcmil 18/1	-	-	-	-
	VC-831-1-RM			
266.8 kcmil 26/7	VC-831-1-RM	Uni-grip	HR-266-267A	-
336.4 kcmil 26/7	VC-832-2-RM	one die	HR336-267A	-
477 kcmil 26/7	VC-833-3-RM	system	HR-477-267A	-
556.5 kcmil 26/7	VC-835-4RM	Order by	HR-556-267A	-
795 kcmil 26.7	VC-835-4RM	conductor size	-	-
954 kcmil 54/7	-	and stranding	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

cy - Splice, Compression

ACSR

Conductor Size	Nat. Tel. Supply	Homac	ESP
4 6/1	"Nicopress"	"Tension	FTR-4
4 7/1	(1-pc. or 2-pc.)	splicer"	FTR-4
2 6/1	Order by Conductor	(1-piece or	FTR-2
2 7/1	Size and	2-piece	FTR-2.5
1/0	Stranding	Order by	FTR-1/0
2/0	2-pc.	Conductor	FTR-2/0.5
3/0	"	Size and	FTR-3/0
4/0	"	Stranding	FTR-4/0
266.8 kcmil 26/7	"	2-pc.	-
336.4 kcmil 26/7	"	"	-
477 kcmil 26/7	"	"	-
556.5 kcmil 26/7	"	"	-
795 kcmil 26/7	-	-	-
954 kcmil 54/7	-	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

Splice, Compression

Copper and Copperweld-Copper

Conductor Size	Burndy	Homac	Hubbell (Anderson)	Kearney/Eaton	National Tel. Supply
6 cu	YDS6W	J2C3	VCC-28	OH6C	1-162/J
4 cu	YDS4W	L2C5	VCC-28	OH4C	1-204/P
2 x 3 cu	YDS2C-3	S2C7	-	OH2-3CX	1-258/3X
0 x 7 cu	YDS25	U2C9	-	OH1-7C	1-325/7F6
8A CWC	YDS8KT	L2E1	VCC-28	OHR8ACW	1-8A-P
6A CWC	YDS6KT	L2E3	VCC-28	OHR6ACW	1-6A-P
4A CWC	YDS4KT	Q2E5	VCC-37	OHR4ACW	1-4A-X
2A CWC	-	U2E7	VCC-43	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

cy - Splice, compression
(one-piece)

(For 6201 and 5005 Aluminum Alloy Conductors)

Conductor Size	**Burndy**	**Blackburn**	**Homac**	**Hubbell (Anderson)**
#4	"Unisplice" Order by Conductor Size and Stranding	Type RC Order by Conductor Size and Stranding	"Tension Splicer" Order by Conductor Size and Stranding	Type VC-R Order by Conductor Size and Stranding
thru				
4/0	**ESP** Type FTR Order by Conductor Size and Stranding			
336.4	**DMC Power** Full Tension Compression One-piece (swage) High Strength Type 6000 Series. Order by Conductor Size & Kit pieces.			
thru				
2500 Kcmil				

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

cy - Splice, compression

1-piece splice for ACSR

Manufacturer	Conditions
*AFL	
"Jiffy Joint"	To obtain experience.

1-piece splice for AWAC

Manufacturer	Conditions
Burndy	
AWAC 4-4/3 YDS7M10T	To obtain experience.
AWAC 2-4/3 YDS7M9T	
AWAC 1/0-4/3 YDS7M7T	

*Satisfactory for use with 6201 and 5005 all aluminum alloy conductor through 4/0 and 19 strand conductors of sizes 266.8 kcmil and 477 kcmil.

NOTE: These splices are acceptable when installed using tools and dies in accordance with the splice manufacturer's recommendations.

cy -Splice, compression, high temperature

For use with High Temperature Conductors

Manufacturer	Conditions
AFL Fujikura Limited (AFL) Splice, Compression To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
Burndy/Hubbell Splice, compression To be used with CTC Global High Temperature Conductor, ACCC (Aluminum Conductor Composite Core)	Same as above.
Preformed Line Products (PLP) Thermolign Full Tension Splice To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	Same as above.

NOTE: These splices are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

cz - Splice for Steel Strand (Overhead Ground Wire)

Compression

Single Sleeve Only

	High Strength Steel		Extra High Strength			Aluminum Clad Steel		
	3/8"	7/16"	5/16"	3/8"	7/16"	7 No. 9 AWG	7 No. 8 AWG	7 No. 7 AWG
AFL				4914.386	4916.453			
Burndy	YTS375E	YTS438E				YDS7M9T	YDS7M8T	YDS7M7T
Hubbell (Fargo)	81l425	8ll630	81l222	81l425	81l630	811425	811427	811630
Kearney	HR-3/8-3-7S							
National.Tel.Supply	5-7/12OG92	5-7/145J22						
Steel and Aluminum Sleeves								
Homac	28414 (Two piece)							
Automatic								
MacLean (Reliable)	5002	5043	5041	5042	5043	5042	5042	5043
Bolted Type								
Electroline	GD-537							
Formed Type								
Helical Line Products	HS-310-3/8"	HS-311-7/16"						
Hubbell (Chance)	10SS 3/8C	16SS 7/16C	6SS 5/16C	10SS 3/8C	16SS 7/16C			

da - Bracket, insulated

	Bracket without Insulator	Bracket with 1-3/4” Spool Insulator	Bracket with 3” Spool Insulator
Hubbell (Chance)	0327	0327-C909-1032	0327-C909-1304
Hughes Brothers	1077LI	1077SI	1077I
Joslyn	J1300	-	-
Kortick	K9278	K9081	K9082

dh - Ground, pole

(For system grounds, see ground rods on page ai)

Manufacturer	Catalog Number

Galvanized Steel Plate With Insulated Copper Lead

(For connecting to a copper or aluminum ground wire above ground.)

Line Hardware	PGPS-56CL8

Galvanized Steel Plate with Connector

(For connecting to a galvanized iron ground wire)

Line Hardware	PGPS-56C

Copper Plate

Blackburn	GP-100
Drabco	D 101
Eritech	EGP-100
Galvan Industries, Inc.	GP-100
Homac	5575
Joslyn	J9196
Line Hardware	PGPC-56
Utilco	UGP-72*

* Plate area exposed to the soil is at least 0.046 m^2 or 0.5 ft^2; Plate thickness is at least 1.5 mm or 0.06 in.

dh - Ground, pole
Alternative Materials

(For system grounds, see ground rods on page ai)

Manufacturer	Catalog Number	Description
SAE	CD-2W-12	14” ConduDisc™ with 12 ft. of #2 Copperweld
	CD-2WC-12	14” ConduDisc™ with 12 ft. of #2 Copperweld Camo
	CD-4C-12	14” ConduDisc™ with 12 ft. of #4 Copper
	CD-2C-12	14” ConduDisc™ with 12 ft. of #2 Copper
	CD-1/0C-12	14” ConduDisc™ with 12 ft. of 1/0 Copper
	CD-2/0C-12	14” ConduDisc™ with 12 ft. of 2/0 Copper
	CC25	Conducrete® 25 lb.
	CC55	Conducrete® 55 lb.
	CF7000	ConduFlow 5ga1.

dl - Pipe Spacer

3/4" diameter x 1-1/2" length

Manufacturer	Catalog Number
Hubbell (Chance)	2237
Joslyn	J2031
MacLean (Continental)	U36695

dm - Bracket, transformer

(For cluster mounting of two or three transformers on pole)

Manufacturer	Transformer Size, kVA	Band Type	Through Bolt Type
Aluma-Form	3-50	6M3-6	3MW-24-M
	75-100	15M3-6	11MW-24
Barfield Manufacturing Co.	3-50	BMAC-366	-
	75-100	BMAC-3156	-
Dixie	3-25	-	DW-50
	37-1/2-50	-	DW-50
	75-100	-	DW-167
Hubbell (Chance)	3-50	C6M3-6	C3MW24M
	75-100	C15M3-6	C11MW24L
Hughes	3-25	-	3021
	37-1/2-50	-	3020
	75-100	-	3020 with adapter plates and back plate
Joslyn	3-25	-	J6865
	37-1/2-50	-	J6864
	75-100	-	J6866
MacLean Power Systems	3-50	-	M3MW-24-M
	75-100	M15M3-6	M11MW-24
Turner	3-25	-	305-25
	37-1/2-50	-	305-100
	75-100	-	305-100
	<u>For mounting of two transformers</u>		
Aluma-Form	3-100	-	DM-4M2
	3-50	-	DM-2M2
Hubbell (Chance)	3-100	-	C212-0001
Hughes	3-50	-	3022
MacLean Power Systems	3-50	-	MDM-2M2
Turner	3-50	-	205-25

dp - Clamp, ground wire

Transmission

For grounding steel towers and substation structures

Bolt Included

(For use with copper ground wires)

Manufacturer	Catalog Number
TE Connectivity - Energy	81416-3
Penn-Union	GH-30-C-A1
Royal Switchgear	12202-T (Type LCS)
Hubbell Power Systems	GC143AG2

For use in: Pole Grounding Assembly TM-9
Capacitor Assemblies M9-11, M9-12 and M9-13

Manufacturer	For 5/8" Bolt	For 3/4" Bolt
Joslyn	J1163	J1164
MacLean (Continental)	SBL-33	-

Conditional
dp(1)
January 2010

dp – Clamp, ground wire

Transmission

For grounding steel towers and substation structures

Bolt Included

(For use with copper ground wires)

Manufacturer	Catalog Number	Conditions
DMC Power	GC910B-***T (single hole pad for copper wire)	To obtain experience.

For use in: Pole Grounding Assembly TM-6, TM-7, TG-15, TG-17, TG-25, TG-27, TG-28, TG-29, TG-35
Capacitor Assemblies Y3.1, Y3.2, Y3.3, Y3.4

dq - Eye Screw, Elliptical

For use in deadending triplex type service cable, Drawing K2.3.

Manufacturer	Catalog Number
Joslyn	J8930

dr – Clevis, conduit, insulated

For use in deadending triplex service cable, Drawing K3.2.

Applicable Specifications: "RUS Specifications for Insulated Conduit Clevises and Conduit Wire-holders for Pipe Mast Deadends," D-16

Manufacturer	Catalog No.
Joslyn	J0311*
Hubbell Power Systems, Inc.	DW8M1

*Insulator not included. See page cm for spool insulator.

ds - Wireholder, conduit

For use in deadending open wire services on pipe masts, Drawing K3.1.

Applicable Specifications: "RUS Specifications for Insulated Conduit Clevises and Conduit Wireholders," D-16

Manufacturer	Catalog Number
Hubbell (Chance)	C207-0075, C2070144

ds - Wireholder, conduit

Manufacturer	Conditions
Joslyn	
J0588Z (nylon alloy)	To obtain experience.

dt - Deadend, service

For deadending triplex type service cable, Drawing K2.2.

Manufacturer	ACSR Size	Catalog Number	
		Wedge Type	Formed Type
Blackburn	4	W62-1	-
Dulmison	4	-	SG0570
	2	-	SG0735
	1/0	-	SG0915
	2/0	-	SG1020
Helical Line Products	4	-	HSG-514
	2	-	HSG-518
	1/0	-	HSG-522
MacLean (Reliable)	4	7195	-
	2	7187	-
	1/0	7287	-
Penn-Union	4	WDC-2S	-
Preformed Line Products	4	-	SG-4502
	2	-	SG-4504
	1/0	-	SG-4506
	2/0	-	SG-4507
	3/0	-	SG-4508
	4/0	-	SG4509

du - Link, Extension

DISTRIBUTION

Manufacturer	Catalog Number
Joslyn (Flagg)	PA319
Hubbell (Chance)	C207-0112
MacLean (Bethea)	LCE-14
MacLean (Continental)	CEL-14

TRANSMISSION
(25,000 lbs. min. strength)

Joslyn	J26082
MacLean (Bethea)	ASM 7209-I-BC

Guy Extension Link
(For "H" Structure)

Manufacturer	One Guy Attachment	Two Guy Attachment
Joslyn	J22421	J26025

NOTE: The distribution extension links may be substituted for anchor shackle (Item bo), eye bolt (Item o) and eye nut (Item aa) for both small and large conductor drawings shown in RUS Form 803 and RUS Bulletin 50-3 at the option of the owner.

du - Connecting Links for Pole Bands

Conditions - To obtain experience.in conjunction with pole bands [Item fv(1)]

For Use With Medium Duty Pole Bands

Manufacturer	Link to Insulators	Size	Minimum Strength Rating
Hughes Bros.	3176	3/8"x3"x9-1/2"	25,000 lbs.
Joslyn	J26034	3/8"x3"x9-1/2"	25,000 lbs.

	Link to Guy		
Hughes Bros.	3154	3/8"x2"x9-1/2"	36,000 lbs.
Joslyn	J26035	3/8"x3"x9-1/2"	36,000 lbs.

For Use With Heavy Duty Pole bands

Manufacturer	Link to Insulators	Size	Minimum Strength Rating
Hughes Bros.	3157	3/8"x3"x12"	36,000 lbs.
Joslyn	J26035 - 2	3/8"x3"x9-1/2"	36,000 lbs.

	Link to Guy		
Hughes Bros.	3157	3/8"x3"x12"	51,000 lbs.
Joslyn	J26037	1/2"x3"x12"	51,000 lbs.

dy - Bolt, eye, double arming

Applicable Specification: ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction."

Applicable Sizes 5/8 inch, 14 through 26 inch length
3/4 inch, 14 through 26 inch length

The following manufacturers have shown compliance with the applicable specifications:

Allied Bolt, Inc.
Hubbell (Chance)
Joslyn Manufacturing Company
Kortick Manufacturing Company
MacLean (Continental)

dz - Clip, Guy Wire

Manufacturer	5/16"	3/8"	7/16"	1/2"
Hubbell (Chance)	6453	6454	6455	6456
MacLean (Continental)	U4953	U4954	U4955	U4956

ea - Insulator and Stud, line post, ceramic
(Non-ANSI Class)

DISTRIBUTION (RUS Minimum Requirements)

System voltage, kV:	12.5/7.2	12.5/7.2	24.9/14.4
Leakage, inches:	7-1/2	10	15
Cantilever strength (pounds):	1875	1875	1875
Flashover, dry, kV:	65	70	95
Flashover, wet, kV:	40	50	65
Gamma Insulators Corp.			
7" Stud	-	-	-
1-3/4" Stud	4315PX-70	4320PX-70	4327PX-70
IUSA			
No Stud	P-2025	P-2025	-
Lapp			
7" Stud	4415P	4420P	4427P
1-3/4" Stud	4315P	4320P	4327P
Newell Porcelain			
7" Stud	-	43570-7040	47101-7040
1-3/4" Stud	-	43570-7010	47101-7010
Porcelain Products (Knox)			
7" Stud	5115-6510	5120-6510	5127-6510
1-3/4" Stud	5115-6500	5120-6500	5127-6500

ea - Insulator and Stud, line post, ceramic
(ANSI Class)

DISTRIBUTION or TRANSMISSION

System voltage, kV:	12.5/7.2	12.5/7.2	24.9/14.4
Leakage, inches:	7-1/2	10	15
Cantilever strength (pounds):	1875	1875	1875
Flashover, dry, kV:	65	70	95
Flashover, wet, kV:	40	50	65
ANSI Class:	57-2	57-3	57-4
System voltage, kV:	22	34.5	46
Gamma Insulators Corp.			
7" Stud	-	-	-
1-3/4" Stud	9335X-70	9345X-70	-
ICB			
7" Stud	-	-	-
1-3/4" Stud	ICB 57-2	ICB 57-3	-
Lapp			
7" Stud	9435	9445	9455
1-3/4" Stud	9335	9345	9355
Newell-PSN			
7" Stud	37620-7040	41640-7040	41650-7040
1-3/4" Stud	37620-7010	41640-7010	41650-7010
Porcelain Products (Knox)			
7" Stud	5135-6512	5145-6512	-
1-3/4" Stud	5135-6502	5145-6502	-

ea - Insulator, line post, ceramic
(ANSI Class)

ANSI Class:	57-1	57-2	57-3	57-4
Eprecsa USA, LLC	13PD	22PD	33PD	-

ea - Insulators, line post, ceramic, horizontal
Transmission

Manufacturer	34.5 kV	69 kV	115 kV
Lapp	F-4745	F-4788	F-70147
Locke	-	LS025l3	LS050l3
Newell-PSN	43740-7700	43790-7700 47043-7700	-
Victor Insulators, Inc.	62356	62359	-

ea - Insulator, line post, ceramic
(non-ANSI Class)

Manufacturer	Conditions
Victor Insulators, Inc. 2120 (12.5/7.2 kV) 2127 (24.9/14.4 kV) 62055 (22 kV) 62056 (34.5 kV)	To obtain experience.

Conditional List
ea(3)
September 30, 2020

ea - Insulators, line post, composite, horizontal
Transmission

Polymer for Wood and Fiberglass Transmission Poles (clamp end fittings and rigid curved base or bendable curved base for use for round poles)				
Voltage:	34.5 kV	46 kV	69 kV	
ANSI Class:	51-34	51-35	51-36	
Rated SCL (lbs.):	2400	2400	2400	
Rod diameter (inches):				
Manufacturer				**Conditions**
Hubbell	80S0460100	-	80S0690100	To obtain experience.
K-Line Insulators	KL46SHG12	KL69SHPG12	KL69SHP1G	

Polymer for Wood and Fiberglass Transmission Poles (clamp end fittings and rigid curved base or bendable curved base for use for round poles)				
Voltage:	115 kV	138 kV	138 kV	
ANSI Class:	250-54	250-60	250-66	
Rated SCL (lbs.):	2650	2300	2000	
Rod diameter (inches):	2-1/2	2-1/2	2-1/2	
Manufacturer				**Conditions**
				To obtain experience.

Notes:
1. Flat base for use with flat surface poles
2. Universal base for flat as well as curved poles
3. Two hole blade end fitting available.

Conditional List
ea(3.1)
September 30, 2020

ea - Insulators, line post, composite, horizontal
Transmission

Polymer for Steel and Concrete Transmission Poles (with flat base or curved base for centrifugally spun concrete poles)						
Voltage:	34.5 kV and 46 kV	69 kV	115 kV	138 kV	138 kV	
ANSI Class:	51-36	250-41	250-60	250-66	250-75	
Rated SCL (lbs.):	2400	3300	2650	2300	2000	
Rod diameter (inches):		2-1/2	2-1/2	2-1/2	2-1/2	
Manufacturer						**Conditions**
						To obtain experience.

Polymer for Steel and Concrete Transmission Poles (with flat base or curved base for centrifugally spun concrete poles)				
Voltage:	115 kV	138 kV	138 kV	
ANSI Class:	250-60	250-66	250-75	
Rated SCL (lbs.):	4500	3900	3500	
Rod diameter (inches):	3.0	3.0	3.0	
Manufacturer				**Conditions**

* Notes:
1. Flat base for use with flat surface poles
2. Universal base for flat as well as curved poles
3. Two hole blade end fitting available.

Conditional List
ea(4)
September 30, 2020

ea - Insulator, line post, composite

Manufacturer	ANSI Class	Conditions
Advanced Rubber Products		
		To obtain experience.
ARP-LPCN-15SK	51-1C	
ARP-LPFN-15SK	51-1F	
ARP-LPFN-25SK	51-2F	
ARP-LPFN-35SK	51-3F	
ARP-LPFN-46SK	51-4F	
Hendrix Molded Products		
		To obtain experience.
HPI-LP-9C	51-1C	
HPI-LP-9F	51-1F	
HPI-LP-11C	51-2C	
HPI-LP-11F	51-2F	
HPI-LP-14FS/FA	51-4F	
HPI-LP-16F	51-4F	
Hubbell Power Systems		
		To obtain experience.
80S0150F09 (15kV, without Stud)		
80S0250F09 (25kV, without Stud)		
80S0280F09 (35kV, without Stud)		
K-Line Insulators		
		To obtain experience.
KL 15STFL (12.5/7.2 kV, with 7” Stud)		
KL 15STFS (12.5/7.2 kV, with 1-3/4” Stud)		
KL 28STFL (24.9/14.4 kV, with 7” Stud)		
KL 28STFS (24.9/14.4 kV, with 1-3/4 Stud)		
KL 35STFL (with 7” Stud)	51-3F	
KL 35STFS (with 1-3/4” Stud)	51-3F	
KL 46STFL (with 7” Stud)	51-4F	
KL 46STFS (with 1-3/4” Stud)	51-4F	
KL 46SHG (34.5 kV)		
KL 28SKG109 (24.9/14.4kV)	51-32	
EMC Pacific PTY LTD		
		To obtain experience.
LPI36-1100 PHCEP (15kV/ 25 kV/ 35kV, with 7” or 1-3/4” Stud)		

Conditional List
ea(4.1)
March 25, 2026

ea - Insulator, line post, composite

Manufacturer	ANSI Class	Conditions
GAMMA - Corona		
		To obtain experience.
PL015	51-1F	
PL028	51-2F	
PL035	51-3F	
PL045	51-4F	
Hendrix		
		To obtain experience.
HPI-CLP-15	51-12 & 22	
HPI-CLP-17	51-13 & 23	
HPI-CLP-20	51-14 & 24	
MacLean Power Systems		
		To obtain experience.
H0 Series	varies	
H7 Series	varies	
Preformed Line Products		
		To obtain experience.
IP-51-1C	51-1C	
IP-51-1 F	51-1F	
IP-51-2C	51-2C	
IP-51-2F	51-2F	
IP-51-4F	51-4F	
Newell (Gamma-Corona)		
		To obtain experience.
NCLP0151F (PL015)	51-1F	
NCLP0282F (PL028)	51-2F	
NCLP0353F (PL035)	51-3F	
NCLP0464F (PL045)	51-4F	

eb - Bracket, Pole Top
For Post type Insulators

DISTRIBUTION

Hubbell (Anderson) (14.4 or 7.2 kV)	84324-2000
Hubbell (Chance) (14.4 or 7.2 kV)	1B4
Joslyn (Flagg) (14.4 or 7.2 kV)	P526
Lapp (Line Ware) (14.4 or 7.2 kV)	304043
Line Hardware (14.4 or 7.2 kV)	PTIB-375B
MacLean (Continental) (14.4 or 7.2 kV)	PTB-55-8
M.D. Henry Company, Inc. (14.4 or 7.2 kV)	PT-8R

TRANSMISSION

Hubbell (Chance)	1B4
Joslyn (Flagg)	P532
Lapp (Line Ware)	304044
MacLean (Continental)	PTB-66H

ec - Bracket, Offset Neutral

Hubbell (Chance)	C206-0004
Joslyn	J2352

ed - Support, overhead ground wire

Applicable Specifications: "RUS Specifications for Overhead Ground Wire Support Brackets," T-2

Pole top diameter, inches	6-8	8-10	10-12
Hubbell (Chance)	-	5432	5432
Hughes Brothers	-	2859-12	2859-14
Joslyn	-	J6394	J6395
Kortick	K3580	K3581	K3582
MacLean (Continental)	UC1238	UC1239	UC1240

ef - Bolt, clevis

Applicable Specifications: "RUS Specifications for Clevis Bolts," DT-7

	Dia. (Inches)	8”	10”	12”	14”
Hubbell (Chance)	5/8	15808	15810	15812	15814
	3/4	15828	15830	15832	15834
Joslyn	5/8	J7808	J7810	J7812	J7814

eg - Plate, crossarm reinforcing

TRANSMISSION

For 5-5/8" x 7-3/8" crossarm

Manufacturer	Catalog Number
Hubbell (Chance)	4047
Hughes Brothers	1113.88
MacLean (Continental)	U3838
Brooks Manufacturing Co.	REA Type 01 NP REA Type 02 NP REA Type 03 NP REA Type 04 NP REA Type 05 NP REA Type 05M NP REA Type 14 NP REA Type 22 NP
DIS-TRAN Wood Products, LLC	REA Type 01EP REA Type 02EP REA Type 03EP REA Type 04EP REA Type 05EP REA Type 05MEP REA Type 12EP REA Type 14EP REA Type 16EP REA Type 21EP REA Type 22EP REA Type 31EP REA Type 32EP REA Type 41EP REA Type 42EP

eh - Hook, ball

Manufacturer	Catalog Number
Joslyn (Flagg)	13400
Hubbell (Anderson)	HB-30
Lapp	7055
Lindsey	3310
Line Hardware	BH-30
MacLean (Bethea)	BH-5

ei - Clamps, suspension with socket eye

ACSR with Straight or Formed Armor Rods

	AWG			kcmil					
	1/0 & 2/0	3/0	4/0	266.8	336.4	477	556.5	795	954
				Iron or Steel Clamps					
Hubbell (Anderson)	MS-82-S	--	MS-104-S	MS-104-S	--	--	--	--	--
Hubbell (Chance)	FGW4S	--	--	--	--	--	--	--	--
Lapp	305743S	--	--	--	--	--	--	--	--
MacLean (Bethea)	FS-83-S	--	--	--	--	--	--	--	--

ACSR with Straight or Formed Armor Rods

	AWG		kcmil					
	1/0 & 2/0	3/0 & 4/0	266.8	336.4	477	556.5	795	954
			Aluminum Alloy Clamp					
C & R	CRSC-1S	CRSC-2S	CRSC-3S	CRSC-3S	--	--	--	--
Dulmison	--	HSU	HSU	HSU	HSU	HSU	HSU	HSU
Hubbell (Anderson)	HAS-85-S	HAS-104-S	HAS-104-S	HAS-118-S	HAS-139-S	HAS-147-S	HAS-182-S	HAS-182-S
Lapp	306029S	306030S	306030S	306031S	306032S	--	--	--
*Preformed	--	AGS	AGS	AGS	AGS	AGS	AGS	AGS
MacLean (Bethea)	LS-1-S	LS-2-S	LS-2-S	LS-3-S	LS-4-S	LS-6-S	LS-7-S	LS-8-S

*Clevis type available.

Conditional List
ei(1)
July 2009

ei - Clamps, suspension with socket eye - cushioned

Condition: To obtain experience

ACSR with Straight or Formed Armor Rods

	kcmil					
	266.8	336.4	477	556.5	795	954
*Preformed	CGS-1100	CGS-1102	CGS-1105	CGS-1106	CGS-1110	CGS-1112

*Order with socket-eye fitting.

ei - Clamps, suspension with socket eye - cushioned

For use with **High Temperature Conductors**

Manufacturer	Conditions
Preformed Line Products (PLP) Thermolign Suspension To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS

NOTE: These clamps are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

ej - Clamps, deadend with socket eye

ACSR

	AWG	kcmil					
	2/0 to 4/0	266.8	336.4	477	556.5	795	954
Iron or Steel Clamps (requires armor tape or liner)							
Hubbell (Anderson)	-	80445-2000	80445-2000	-	-	-	-
Aluminum Alloy Clamps (do not require armor tape or liner)							
Anderson/Hubbell	SD-57-S	SD-70-S	SD-70-S	SD-86-S	SD-86S	--	--
C & R	CR-10-60S	CR-20-60S	CR-20-60S	--	--	--	--
Lapp	305757S	305758S	305759S	305760S	--	--	--
MacLean (Bethea)	ADE-21-S	ADE-22-S	ADE-23-S	ADE-24-S	ADE-24-S	ADE-2526-S	ADE-2526-S

NOTE: When used with clevis-type insulators for large conductors on distribution lines, order clamp with clevis eye.

ej - Clamps, dead-end with socket eye

For use with **High Temperature Conductors**

Manufacturer	Conditions
Preformed Line Products (PLP) Thermolign Dead-end To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
AFL Compression Dead-end To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS

NOTES:

1. When used with clevis-type insulators for large conductors on distribution lines, order clamp with clevis eye.
2. These clamps are acceptable when installed using tools and dies in accordance with the conductor’s manufacturer's recommendations.

ek - Locknuts

MF Type

For Bolt Diam., in.:	3/8	1/2	5/8	3/4	7/8
Allied Bolt, Inc.	22016	22009	22012	22013	22014
Hubbell (Chance)	3510	3511	3512	3513	3514
Hughes Brothers	MF30	MF50	MF60	MF70	--
Joslyn	J8581	J8582	J8583	J8584	J8584-1/2
Kortick	K1065	K1066	K1067	K1068	--
Line Hardware	SLN38	SLN-12	SLN58	SLN34	SLN78
MacLean (Continental)	U4920	U4921	U4922	U4923	U4924

el - Sectionalizer

Manufacturer	Type
Eaton	GH (with crossarm mounting bracket KA27G)

el - Sectionalizer

Manufacturer	Conditions
Eaton	
Sectionalizer, three-phase Type GN3	To obtain experience.
Sectionalizer with125 kV BIL accessory Type GH, 15 kV, single phase	1. To obtain experience. 2. For use on single-phase taps of 24.9/14.4 kV multi- grounded wye systems.
*Sectionalizer, three-phase Type GN3E14.4 kV, 200 amp max.	To obtain experience.
*Sectionalizer, three-phase Types GV and GVC 14.4 kV, 400 amp. max.	To obtain experience.
*Sectionalizer, three-phase Types GW and GWC 34.5 kV, 400 amp. max.	To obtain experience.
General Electric	
Sectionalizer, single-phase cutout-type - 15 kV and 25 kV Model 9F41F	To obtain experience.
Hubbell	
Sectionalizer, Single-Phase Type CRS Single-Phase, Cutout Type 15 kV, 95 kV BIL 200 amp max. 27 kV, 125 kV BIL 200 amp max. 38 kV, 150 kV BIL 200 amp max.	To obtain experience.
Sectionalizer, Single-Phase Type PRS Single-phase, Cutout Type with and without loadbreak accessory 15 kV, 110 kV BIL 300 amp max. cont. 27 kV, 125 kV BIL 300 amp max. cont. 38 kV, 150 kV BIL 300 amp max. cont. 38 kV, 170 kV BIL 300 amp max. cont.	To obtain experience.
Joslyn	
Sectionalizer, three-phase, 15 kV, 400 and 600 amperes 25 kV, 600 amperes Model VBM with VT or RS control	To obtain experience.

*NOTE: Ratings greater than 100 ampere for 12.5/7.2 kV application and greater than 200 ampere for 24.9/14.4 kV application are acceptable only with ground trip device.

NOTE: Cutout type sectionalizers may also be used with cutout frames listed on pages af-1 and ax-1. Consult manufacturer for application.

em - Brace, crossarm, special (angle alley arm)

DISTRIBUTION

15" span, 14" drop; 1-1/2" x 3/16"

Kortick	K1978
MacLean (Continental)	U5514

TRANSMISSION

	30” Span x 20” Drop	42” Span x 27” Drop
Hubbell (Chance)	-	6999
Hughes Brothers	AS-2309-B	AS-2309-A
Kortick	K1975	K1976
MacLean (Continental)	U5509	U5510

eq - Narrow Profile Brackets and Special Arm Assemblies

METAL BRACKETS

Manufacturer	Conditions
Dixie	
Deadend bracket assembly D21142 for 12.5/7.2 kV Deadend bracket assembly D21144 for 24.9/14.4 kV	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected.
Hubbell (Anderson)	
Standoff bracket, COB-E-180-TGL	Same as above.
Hubbell (Chance)	
Single post insulator brackets C206-0209 for 12.5/7.2 kV construction only C206-0010 for 24.9/14.4 kV construction Deadend bracket assembly, C206-0179 Deadend bracket assembly, C206-0211 for 24.9/14.4 kV construction	Same as above.
Joslyn (Flagg)	
Standoff bracket, PA619B	Same as above.
MacLean (Continental)	
Standoff bracket IACB-18-5	Same as above.

eq - Narrow Profile Brackets and Special Arm Assemblies

METAL BRACKETS

Manufacturer	Conditions
Joslyn	
Single post insulator brackets 24840.1, for 12.5/7.2 kV construction only 24840.2, for 24.9/14.4 kV construction	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected.
MacLean (Bethea)	
Single post insulator bracket, HBF-10-9-GC Standoff bracket VIB3-18-GC	Same as above.
M.D. Henry Company, Inc.	
Single post insulator bracket, SAB-3-18-GC	Same as above.

Conditional List
eq(2)
October 2009

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC
For 12.5/7.2 kV

Manufacturer	Catalog Number	Conditions
Aluma-Form		
Single Phase	F1CA-MV-x18*	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.
Hubbell (Chance)		
Two-phase pin bracket	2SBM36VV4	Same as above.
Standoff insulator	1SBM13H1	
Deadend arm	DEM36SP	
MacLean (Continental)		
Two-phase pin bracket	G2MDA x 36DV2	Same as above.
Two-phase angle bracket	G2MDA X 36AX1	
Standoff insulator	G1MDA x 12AS1	
Standoff insulator	G1MDA x 18AS1	
Deadend arm	GDAS-36E	
Suspension bracket	G1MDA x 18AE	
MacLean (Joslyn)		
Standoff bracket	G1MDA x 18AT	Same as above.

* x = “A” for angled, 15 degrees or “H” for horizontal

Conditional List
eq(2.1)
June 20, 2025

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC
For 12.5/7.2 kV

Manufacturer	Catalog Number	Conditions
M.D. Henry Company, Inc.	TPIV-1.5-36 TPIV-1.5-36-1.375 SPSS-1.5-13 SPSS-1.5-18	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.
Hughes Brothers		
Two-phase angle bracket	761-36-8	Same as above.
Two-phase pin bracket	813-36	
Standoff insulator	560-13	
Standoff insulator	560-18	
Suspension bracket	615-18	
Deadend arm	540-36	
Standoff bracket	892-18	
Fiberglass Line Hardware		
	FLH Series FLHR Series	Same as above.

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC
For 24.9/14.4 kV

Manufacturer	Catalog Number	Conditions
Aluma-Form		
Single Phase	F1CA-MV-x18*	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.
Hubbell (Chance)		
Two-phase pin bracket	2SBM44VV4	
Standoff insulator	1SBM19V4	
Deadend arm	DEM48SP	
MacLean (Continental)		
Two-phase pin bracket	G2MDA x 44DV3	Same as above.
Two-phase pin bracket	G2HDA x 48DV3	
Standoff insulator	G1MDA x 18DV3	
Standoff insulator	G1MDA x 19DV3	
Standoff insulator	G1MDA x 20DV3	
Standoff bracket	G1MDA x 18AT	
Deadend arm	GDAS-48E	
M.D. Henry Company, Inc.	TPIV-1.5-44-1.375	Same as above.
	TPIV-1.5-48-1.375	
	TPIV-2-48-1.375	
	SPSV-1.5-18-1.375	
	SPSV-1.5-19-1.375	
	SPSV-1.5-20-1.375	
	SPSV-2-20-1.375	
	SP3CA-1.5-18	

* x = “A” for angled, 15 degrees or “H” for horizontal

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC
For 24.9/14.4 kV

Manufacturer	Conditions
Hughes Brothers Deadend arm, 540-48 Standoff insulator, 880-20 Two-phase pin bracket, 883-48 Standoff insulator, 870-19 Two-phase pin bracket, 862-44 Standoff bracket, 892-18	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.

eq - Narrow Profile Brackets and Special Arm Assemblies

WOOD ARM ASSEMBLIES

Manufacturer	Conditions
Aluma-Form	
Arm assembly, 12.5/7.2 kV XA-3812 Arm assembly, 24.9/14.4 kV XA-4214	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used as deadend structures.
Hughes Brothers	
Deadend arm, 2890-J complete with braces and attaching hardware, fittings and bolts	1. To obtain experience. 2. For use only in scenic areas and locations right-of-way is limited. 3. Not to be used where conductor galloping may be expected.

eq - Narrow Profile Brackets and Special Arm Assemblies

COMBINATION INSULATORS AND BRACKETS

Manufacturer	Conditions
Salisbury Horizontal Post 12.5/7.2 kV, 9561 24.9/14.5 kV, 9562	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.

er - Wire Guard, Plastic

See Drawing K4.1G

Manufacturer	Type orCatalog Number
Hubbell (Chance)	PFG
Hubbell (Fargo)	GM-936
Preformed Line Products (Tree Guard)	PTG

es - Splice Cover, Plastic

(For use over compression type service connections in place of tape)

Manufacturer	Type
Hubbell (Anderson)	Type SEC
Kearney/Eaton	Type 601
Plastic Engineering & Sales Co.	Wire Splice Cover
3M	PST Series 8420
Virginia Plastics	Type VP

Splice Cover and Moisture Seal for Secondary Cable Connections
(See Drawings G312 and UM5)

Manufacturer	Type
TE Connectivity - Energy	Sealing & Dielectric Compound
Plymouth/Bishop	10 Plyseal
3M	Scotch Brand #2200

Bolted Connector Cover

(For use over bolted type service connections in place of tape)

Manufacturer	Type
Hubbell (Anderson)	PTC
Hubbell (Fargo)	GA-9000 B Series

eu - Extension Link
(Fiberglass)
(Distribution)

Manufacturer	Strength	Catalog Number
Dulmison	11,000 lbs.	HSB-1-12*
	15,000 lbs.	HSB-2X-12
Joslyn (Flagg)	11,000 lbs.	150-12EE
	15,000 lbs.	150-12EE
Hubbell (Anderson)	10,000 lbs.	GSB1-9*
	15,000 lbs.	GSB2-12
	16,000 lbs.	GS16012EE
K-Line	15,000 lbs.	KL Series
MacLean (Continental)	11,000 lbs.	GEE11-12*
	15,000 lbs.	GEE15-12

*For use with 6" suspension insulators.

ex - Splice, formed type

Manufacturer	Conditions
Preformed Line Products	
Splice for ACSR FTS full tension splice	To obtain experience.
Splice for AWAC	For repair only.
LS-0185 for 4-4/3	To obtain experience.
LS-0188 for 2-4/3 LS-0191 for 1/0-4/3	For repair only where alumoweld strands are not broken.

fc - Capacitors, Shunt
12470/7200 Volts

Manufacturer	Size	1 Bushing	2 Bushing	3 Bushing
ABB	100 kvar	A10009	A10010	
	150 kvar	A15009	A15010	
	200 kvar	A20009	A20010	
	300 kvar	A30009	A30010	
	400 kvar	A40009	A40010	
Eaton	50 kvar	CEP120B6	CEP120A6	
	100 kvar	CEP131B6	CEP131A6	
	150 kvar	CEP132B6	CEP132A6	
	200 kvar	CEP140B6	CEP140A6	
	300 kvar	CEP160B6	CEP160A6	
	400 kvar	CEP170B6	CEP170A6	
	500 kvar	CEP180B6	CEP180A6	
General Electric Film/Foil Type	25 kvar	52L226RC	52L206RC	
	50 kvar	51L226RC	51L206RC	
	100 kvar	54L226RC	54L206RC	
	150 kvar	54L526RC	54L506RC	
	200 kvar	58L126RC	58L106RC	
	300 kvar	59L226RC	59L206RC	59L611RC

24900/14400 Volts

Manufacturer	Size	1 Bushing	2 Bushing	3 Bushing
ABB	100 kvar	A10031	A10032	
	150 kvar	A15031	A15032	
	200 kvar	A20041	A20042	
	300 kvar	A30031	A30032	
	400 kvar	A40031	A40032	
Eaton	50 kvar	CEP123B9		
	100 kvar	CEP130B9		
	150 kvar	CEP139B9		
	200 kvar	CEP143B9		
	300 kvar	CEP163B9		
	400 kvar	CEP173B9		
	500 kvar	CEP183B9		
General Electric Film/Foil Type	50 kvar	51L252RC		
	100 kvar	54L252RC		
	150 kvar	54L552RC		
	200 kvar	58L154RC		
	300 kvar	59L154RC		
	400 kvar	98L154RC		

fd – Hangers, Capacitor

Crossarm Mounting

	1 unit	2 units	3 or 4 units
ABB	85B397G01	791C644G01	791C644G02
Eaton	CH1A1	CH2A2	CH4A1
General Electric	39F41G2	39F53	39F80G1

Pole Mounting

	Single Phase	Three Phase	
		In Line	Cluster
ABB	AL30R (3 units) AL60R (6 units)	(1 Ø units) AL30R AL60R AL90R (3 Ø units) AL13W AL23W AL33W AL43W AL53W	 (3 units) (6 units) (9 units) (1 unit) (2 units) (3 units) (4 units) (5 units)
Aluma-Form	CR-3* thru CR-6*	CR-3/4*	3-CR-3/4*
General Electric	39F41G1 (1 unit) 39F83G1 (3 units)	39F86G1	
Hubbell Power Systems Inc.	CCR-1* Thru CCR-6*	CCR-3/4*	CCR-9/12*
MacLean Power Systems	-	MCR-3 MCR-3/4 MCR-6	

* Available with oil switch mounting bracket.

fg - Crossarm Saddle

(3-3/4" x 4" with 1-1/4" x 1/4" flange)

Manufacturer	Catalog Number
Lapp	10369

fi - Connectors, hot line

Over Armor Rods

Manufacturer	Catalog Number or Series (Al to Al)	Catalog Number or Series (Al to Cu)
Blackburn	PGH	-
Hubbell (Anderson)	AC Series	AC-GP-Series
Hubbell (Fargo)	GA-100 Series	GA-100C Series

fj – Bracket, extension

(For use in mounting circuit reclosers or sectionalizers)

See Drawing VM3-10A

	Through Bolt Type	Band Type
Aluma-Form	TBRSM-1, TB2M1-9*	RSM-1
Dixie	D-2359-M	-
Joslyn	J2357	-
MacLean Power Systems	MTB2M1-9	-

*For mounting double lug reclosers.

fk – Bracket, circuit recloser or sectionalizer

(For cluster mounting of three circuit reclosers on pole)

	Cluster Mount	Rack Mount
Aluma-Form	RSM-3, 6M3-9*	3SPR-66, 3SPR-84
MacLean Power Systems	-	M3SPR-66
Turner	695-3	-

*Suitable for 14.4 and heavy duty 7.2 kV.

fl – Rack, primary metering

(For cluster mounting of primary metering equipment on pole)

Aluma-Form	PMM Series
Barfield Manufacturing Co.	BAPMM6
Turner	3CT-PT
MacLean Power Systems	MPMM-6

fm - Extension Bracket for Mounting Apparatus
(Arrester, Cutouts and Potheads for Distribution Pole Mounting)

Manufacturer	Application Voltage	Single Phase	Three Phase
Aluma-Form, Inc.	12.5/7.2 kV	1HCA-18 Series 1HCA-C-18	R3CA-48 F3CA-MV-H3012 series F3CA-MV-A3012 series
	24.9/14.4 kV	WBMA-1	R3CSA-48 F3CA-MV-H4017 series F3CA-MV-A4017 series
Barfield Mfg. Co.	12.5/7.2 kV	BAC 1256	-
	24.9/14.4 kV	BAC 1710	-
	12.5/7.2 kV	BACA 126 (double mounting)	-
	24.9/14.4 kV	BACA 1710 (double mounting)	-
Dixie	12.5/7.2 kV	D-1580	D27211-G
	24.9/14.4 kV	D-1583	-
Hubbell (Anderson)	12.5/7.2 kV	COB-E-120-TGL	-
	24.9/14.4 kV	ACOB-E-180	-
		COB-E-180-TGL	-
Hubbell (Chance)	24.9/14.4 kV	C653-1038	C653-1056
Hubbell Power Systems, Inc.		1SBMxxTD Series	-
		1SBMxxAM Series	-
		1SBMxxC Series	-
		1SBMxxAMT Series	-
		1SBMxxCT Series	-
		1SBMxxCL Series	-
		1SBMxxSGL Series	-
	12.5/7.2kV	C1HCAC	-
	12.5/7.2kV	C1HCA	-
	24.9/14.4kV	C1HCAC18	-
	24.9/14.4kV	C1HCA18	-
Hughes Brothers	12.5/7.2 kV 24.9/14.4 kV	892-18	670-40
Line Hardware	12.5/7.2 kV	CA-12-3GL	-
MacLean (Bethea)	12.5/7.2 kV	VIB3-18-R1-GC-C	-
		VIB3-12F-GC	-
	24.9/14.4 kV	VIB3-18-GC	-

Note: Above brackets are not suitable for supporting or deadending distribution line conductors.
(See items “eq” for narrow profile bracket and special arm assemblies)

fm - Extension Bracket for Mounting Apparatus
(Arrester, Cutouts and Potheads for Distribution Pole Mounting)

Manufacturer	Application Voltage	Single Phase	Three Phase
MacLean (Continental)	12.5/7.2 kV 24.9/14.4 kV	IACB-12-5LGE IACB-18-5LGE	G3MA013012DD G3MA014017DD
MacLean Power Systems	12.5/7.2 kV	M1HCA-C-18	MR3CA-48
M.D. Henry Company, Inc.	24.9/14.4 kV	SAB-3-18-GC	-
Fiberglass Line Hardware	12.5/7.2 kV 24.9/14.4 kV	FLHR Series FLHR Series	FLH3 Series FLH3 Series

Note: Above brackets are not suitable for supporting or deadending distribution line conductors.
(See items “eq” for narrow profile bracket and special arm assemblies)

fn - Extension Bracket for Mounting Cutouts

Refer to item fm

fo - Bracket, Transformer Secondary, Insulated

Manufacturer	Bracket Without Insulator	Bracket With 2-1/4" Diameter Spool Insulator	Bracket With 3-1/8" Diameter Spool
Hubbell (Chance)	-	9113S	9114S
Joslyn	-	J6765-A	J6765
MacLean (Continental)	U865	U865/208	U865/205

fp - Oval Eye Ball
(30,000 lbs; to be used with 52-3 and 52-5 insulators)

Manufacturer	No.

(No accepted items at this time)

fq - Laminated Upswept Arms

Applicable Specification: RUS Specification DT-5B
Applicable Drawing: RUS Drawing TUS-1

Manufacturer	Conditions
Hughes Brothers Types: C-4080A (5-1/8" width) C-4080B (5-1/8" width) C-4113A (3-1/8" width) C-4113B (3-1/8" width)	1. To obtain experience. 2. For use only in scenic and urban areas where right- of-way is limited.

fs - Pole Bearing Plate

Manufacturer	Catalog Number
Hubbell (Chance)	C1100954

fs - Pole Bearing Plate

Manufacturer	Conditions
Joslyn (Flagg) P325B-122	Same as above.
MacLean (Continental) PB-80-7	Same as above.

ft - Y-Clevis Ball

Manufacturer	Catalog Number
Joslyn	BT 3030
Preformed Line Products	BYC-30

fu - Swinging angle bracket

(TRANSMISSION)

Applicable Specification: T-8

Swinging angle bracket with hardware and fittings

Manufacturer	2' - 0"	3' - 6"	Type #1	Type #2
Brooks	64233A	64233B	X	
Hughes Brothers	2848	2848	X	X

fv - Guying Attachments
Transmission

Pole Eye Plates*

25,000 lbs. @ 90°/36,000 lbs. @ 45°

Manufacturer	Single Eye		Double Eye - 7/8" Bolts
	3/4" Bolts	7/8" Bolts	
Joslyn (Flagg)	PX37D	-	PX42
MacLean (Continental)	EPR-66S-12	-	-

*Capacity of pole eye plate

fv - Guy Attachments, Pole Bands Attachments, Pole Bands With Through Bolts for Transmission Lines

Medium Duty Pole Bands

25,000 lbs @ 90^{o}/36,000 lbs @ 45^{o}*

Manufacturer	Pole Band and Associated Hardware**	Conditions
Hughes Bros.	3108.x-2718.55	To obtain experience.
Joslyn	J25968. x GL	To obtain experience.

Heavy Duty Pole Bands

36,000 lbs. @90^{o} /51,000 lbs. @ 45^{o}*

Manufacturer	Pole Band and Associated Hardware**	Conditions
Hughes Bros.	3107.x-2718.55	To obtain experience.

* For a guy lead greater than 1/1, capacity of pole band should be derated.

** Associated hardware includes through bolt, band connecting bolts, nuts, grounding clip and lag screws (if any). Connecting links (Item du (1)) of the required strength should be ordered separately from the same manufacturer.

ga - Watthour and Watthour-Demand Meters
1ø, 2 and 3 wire or 2/3 wire 120/240 volts

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer	Type of Base	Watthour Meter Type	Mechanical Demand Watthour Type	Thermal Demand Watthour Type	Number of Terminals
1	2	3	4	5	6
Elster	Bottom Con.	-	-	-	-
	Socket	AB1	-	-	4
General Electric	Bottom Con.	I50A	IM50A	-	4
	Socket	I70S	IM70S	-	4
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MS	BMS-2S	TMS	4
Schlumberger	Bottom Con.	J5SA	J5DSA	-	-
	Socket	J5S*	J5DS	-	4

Transformer Rated Types

Elster	Bottom Con.	-	-	-	-
	Socket	AB1	-	-	5 or 6
General Electric	Bottom Con.	I50A	IM50A	-	5 or 6
	Socket	I70S	IM70S	-	5 or 6
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MS	BMS	TMS	5 or 6
Schlumberger	Bottom Con.	J5SA	J5DSA	-	-
	Socket	J5S	J5DS	-	5 or 6

* Type J4ES for Class 320

ga - Watthour and Watthour-Demand Meters
Polyphase 2 element - 3 wire, 240 volts - Delta and 120/208 Volts Network

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con.	-	-	-	-
	Socket	ABS-5	-	-	-
General Electric	Bottom Con.	V62A	VM62A	-	5
	Socket	V62S	VM62S	-	-
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MT012S or 13S	BMT-12S or 13S	TMT-12S	5 or 8
Schlumberger	Bottom Con.	SL2A	SL2DA	-	5 or 8
	Socket	SL2S	SL2DS	-	-
		SL12S	SL12DS		

Transformer Rated Types

Elster	Bottom Con.	ABA-2	-	-	-
	Socket	ABS-2	-	-	8
General Electric	Bottom Con.	V63A	VM63A	-	8
	Socket	V63S	VM63S	-	-
Landis & Gyr	Bottom Con.	MT-5A	BMT-5A	TMT-5A	8
	Socket	MT-5S	BMT-5S	TMT-5S	8
Schlumberger	Bottom Con.	SL3A	SL3DA	-	-
	Socket	SL3S	SL4DS	-	8

ga - Watthour and Watthour-Demand Meters
Polyphase 2 element - 4 wire Delta - 120/240 volts

(Classes 100 or 200)

Self-Contained Types

Manufacturer	Type of Base	Watthour Meter Type	Mechanical Demand Watthour Type	Thermal Demand Watthour Type	Number of Terminals
1	2	3	4	5	6
Elster	Bottom Con.	ABA-7	-	-	7 or 8
	Socket	ABS-7	-	-	-
General Electric	Bottom Con.	V66A	VM66A	-	7
	Socket	V66S	VM66S	-	-
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MT-15S	BMT-15S	TMT-15S	7
Schlumberger	Bottom Con.	SL6A	SL6DA	-	-
	Socket	SL6S	SL6DS	-	7 or 8

ga - Watthour and Watthour-Demand Meters
Polyphase - 2-1/2 element - 4 wire wye - (120/208) (277/480) volt

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con.	ABA-8	-	-	-
	Socket	ABS-8	-	-	-
General Electric	Bottom Con.	V65A	VM65A	-	7
	Socket	V65S	VM65S	-	-
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MT-14S	BMT-14S	TMT-14S	7
Schlumberger	Bottom Con.	SL5A	SL5DA	-	-
	Socket	SL5S	SL5DS	-	7 or 8

Transformer Rated Types

Elster	Bottom Con.	ABA-8	-	-	-
	Socket	ABS-8	-	-	13
General Electric	Bottom Con.	V65A	VM65A	-	7 or 13
	Socket	V65S	VM65S	-	-
Landis & Gyr	Bottom Con.	MT-6A	BMT-6A	TMT-6A	10
	Socket	MT-7S or 6S	BMT-7S or 6S	TMT-7S or 6S	7 or 13
Schlumberger	Bottom Con.	SL5A	SL5DA	-	-
	Socket	SL5S	SL5DS	-	13

ga - Watthour and watthour-Demand Meters

Polyphase - 3 element - 4 wire wye - (120/208) (277/480) volt

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con.	ABA-3	-	-	-
	Socket	ABS-3	-	-	7 or 8
General Electric	Bottom Con.	V64A	VM64A	-	-
	Socket	V64S	VM64S	-	7 or 8
Landis & Gyr	Bottom Con.	-	-	-	-
	Socket	MT-16S	BMT-16S	-	7
Sangamo	Bottom Con.	S4A	S4DA	-	-
	Socket	S4S	S4DS	-	7 or 8

Transformer Rated Types

Elster	Bottom Con.	ABA-3	-	-	-
	Socket	ABS-3	-	-	-
General Electric	Bottom Con.	V64A	VM64A	-	-
	Socket	V64S	VM64S	-	13
Landis & Gyr	Bottom Con.	MT-9A	BMT-9A	-	12
	Socket	MT-9S or 10S	BMT-9S or 10S	-	13
Sangamo	Bottom Con.	SL4A	SL4DA	-	-
	Socket	SL4S	SL4DS	-	13

ga - Meters, Min/Max Indicating

Ammeters Indicating

Manufacturer	Type	Description
Biddle	50,000 Series	Thermal, Max Pointer
Demico	AD121R	Digital min/max ampere demand meter
ED Electric	Max-I-Meter(all models)	Thermal Ammeter
Schlumberger	ADS	Thermal Ammeter

Voltmeter, Min/Max

Manufacturer	Type	Description
Bitronics	VMAMC1	Digital Demand min/max voltmeter
Demico	AV121R	Digital min/max voltmeter
Reid and Rochon Associates	LVM-100	Digital Demand min/max voltmeter

ga - Watthour and Watthour-Demand Meters

Manufacturer	Conditions
Landis & Gyr	
Special base, 3 wire, 1 ø watthour meter, Type MS-K, Class 400 watthour and mechanical demand Type BMS-K watthour and thermal demand Type TMS-2K	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies.
Socket base, 3 wire, 1 ø watthour meter, Type MS-E, Class 300	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by local regulatory bodies.

Conditional List
ga(2)
February 2010

ga - Watthour and Watthour-Demand Meters
Solid State Registers

Manufacturer	Conditions
Electro Industries/GaugeTech	
NEXUS 1262 Form 9S, Class 20 NEXUS 1272 Form 9S, Class 20	To obtain experience.
Elster	
Solid State Polyphase Watthour meter, Alpha line, A1, A and S type bases (all forms) Class 20 and 200, 120, 240, 277, and 480 V	To obtain experience.
GE	
kV Vector Meter Form 10A, 36A, 45A, 48A, 3S, 9S, 36S, 45S, 56S; Class 20; 120 V to 480V or 57V to 120V Form 13A, 16A; Class 150; 120V to 480 V Form 2S, 12S, 16S; Class 200 or 320; 120V to 480V	To obtain experience.
Sensus	
Socket base, single-phase watthour meters Form 1s, 12s, 2s, Class 200 @ 120, and 240 Volts Form 2s Class 320 @ 240 Volts Form 3s & 4s Class 20 @ 120, and 240 Volts	To obtain experience.
Socket base, poly-phase watthour meters Form 9s Class 20 @ 120-480 Volts Form 16s Class 200 @ 120-480 Volts	To obtain experience.
Itron Inc.	
SENTINEL Forms 9S, 10A, 45A, 45S, 46A, 46S, 48A, 66S Class 20 Form 16A Class 150 Forms 2S, 12S, 16S Classes 200 and 320	To obtain experience.

ga - Watthour and Watthour-Demand Meters
Solid State Registers

Manufacturer	Conditions
Landis+Gyr	
Solid State Watthour Meter Type DDS2, Form 5S, 6S, 8S, 9S, 10S, Class 20.	To obtain experience.
FOCUS	
Form 1S, Class 100	
Form 25S, Class 200	
Form 2S, Class 200TA30 and 200TA50	
Form 2SE, Class 320TA30 and 320TA50	
Form 2K, Class 4800/600	
Form 3S, 4S, Class 10 and 20	
Altimus Solid State Meter	
Form 1S, Class 100	
Form 25S, Class 200	
Form 2S, Class 200TA30 and 200TA50	
Form 2SE, Class 320TA30 and 320TA50	
Form 2K, Class 480/600	
Form 3S, 4S, Class 10 and 20	
S4 Polyphase Solid State Meter	
Form 5S/45S, 6S/36S, 9S/8S, Class 20	
Form 12S, 16S, Class 200	
Power Measurement	
ION 8300	
Form 9S, 35S, 36S Class 20	To obtain experience.
ION 8400	
Form 9S, 35S, 36S, 39S, 76S Class 20	To obtain experience.
ION 8500	
Form 9S, 35S, 36S, 39S, 76S Class 20	To obtain experience.
Schlumberger	
CENTRON	To obtain experience.
Form 2S, Class 200.	
Solid State or Mechanical Register.	
FULCRUM SQ400	To obtain experience.
Form 5A, 6A, 9A, 5S, 6S, 9S, 10S, Class 20	
FULCRUM SL300 Series	To obtain experience.
Form 5A, 6A, 8A, 9A, 5S, 6S, 8S, 9S, 10S, 12S, 14S, 15S, 16S, Class 20 and 200.	
QUANTUM Q200 Series	To obtain experience.
Form 5A, 6A, 8A, 9A, 5S, 6S, 8S, 9S, 10S, 26S, Class 20 and 200.	
QUANTUM Q300 Series	To obtain experience.
Form 6A, 9A, 6S, 9S, 10S, Class 10 and 20.	
VECTRON SVX	To obtain experience.
Form 5A, 6A, 8A, 10A(9A), 5S, 6S, 9S(8S), 12S, 16S(14S, 15S), 26S, Class 20 and 200.	

ga - Watthour and Watthour-Demand Meters
Solid State Registers

Manufacturer	Conditions
Transdata, Inc. MARK-V EMS Form 5S, 5A, 6S, 6A, 8S, 8A, 9S, 9A Class20	To obtain experience.

gb - Meter Sockets

Manufacturer	Type or Catalog Number: Ring	Type or Catalog Number: Ringless	No. Jaws	Rating Amps.
ABB	#S		4, 5, 6	100
	STS		5, 6	200/400** 1ø 3w
	STS-2		8	200/400** 3ø 3w
	STS-3		13	200/400** 3ø 4w Y or Delta
	STS-7		8	200/400** 3ø 4w Delta
	STS-8		8 or 13	200/400** 3ø 4w Y
		STA-2		200/400 3ø 3w
		STA-3		200/400 3ø 4W Y or Delta
		STA-7		200/400 3ø 4w Delta
		STA		200/400 1ø 3w
# Anchor	1000 Series (1003-1006)	1000 Series (1003-1006)	4, 5	100
	1100 Series (1100-1109)	1100 Series (1100-1109)	4, 5, 7	150
	1200 Series (1201-1209)	1200 Series (1201-1209)	4, 5	200
		1200/1300 Series (1275-1300)	4, 5, 7	200
	1600 Series (1600-1661)	1600 Series (1600-1661)	4, 5	320
	1500 Series (1500-1526)	1500 Series (1500-1526)	4, 5	100/125 per sta.
	1500 Series (1530-1536)	1500 Series (1530-1536)	4, 5	150 per sta.
	1500 Series (1540-1546)	1500 Series (1540-1546)	4, 5	200 per sta.
	1400 Series (1405-1473)	1400 Series (1405-1473)	4, 5, 6, 7, 8, 13	20/100
Murray	SJ Series* (Single)	RJ Series* (Single)	4, 5, 6	100
	SN Series* (Single)	RN Series* (Single)	4, 5, 6	100
	SS Series* (Single)	RS Series* (Single)	4, 5, 6	200
		RH Series* (Single)	5, 7	200 HD

#Available with UL label
*UL label

gb - Meter Sockets

Manufacturer	Type or Catalog Number: Ring	Type or Catalog Number: Ringless	No. Jaws	Rating Amps.
Durham	R-RS512	RS502#	4 or 5	150
	R-RS502	RS512#		
		H-4300 Series#	4, 5, 7	320
		H-5300 Series#		
		H-7300 Series#		
	RS101-RS111#	RS101-RS111#	4 or 5	100
	2R1121-6R1131#	2R1121-6R1131#		
	2R1421-6R1431#	2R1421-6R1431#		
	RS202#	RS202#	4 or 5	200
	RS212, RS213#	RS212, RS213#	4 or 5	200
	RS220-RS233#	RS220-RS233#		
	2R2332-6R2392#	2R2332-6R2392#		
Eaton Electrical	R-RS512-CH	RS502-CH #	4 or 5	150
	R-RS502-CH	RS512-CH#		
		H-4300-CH Series#	4, 5, 7	320
		H-5300-CH Series#		
		H-7300-CH Series#		
	RS101-RS111-CH #	RS101-RS111-CH #	4 or 5	100
	2R1121-6R1131-CH#	2R1121-6R1131-CH #		
	2R1421-6R1431-CH #	2R1421-6R1431-CH #		
	RS202-CH #	RS202-CH #	4 or 5	200
	RS212-CH, RS213-CH #	RS212-CH, RS213-CH #	4 or 5	200
	RS220-RS233-CH #	RS220-RS233-CH #		
	2R2332-6R2392-CH #	2R2332- 6R2392-CH #		
Dyna-Tech	Overhead			
	1100-C - 1107-C	1000-C - 1007-C	4 & 5	100
	1300-C - 1307-C	1200-C - 1207-C	4 & 5	100
	2100-CH-2107-CH	2000-CH-2007-CH	4 & 5	200
	2300-CH-2307-CH	2200-CH-2207-CH	4 & 5	200
	Underground			
		2590-CHU-2597-CHU	4 & 5	200
		2790-CHU-2797-CHU	4 & 5	200
		2090-CHU-2097-CHU	4 & 5	200
		2290-CHU-2297-CHU	4 & 5	200
General Switch	42100 Series*		4, 5, 6	100

*UL Label
#Available with UL label

gb - Meter Sockets

Manufacturer	Type or Catalog Number: Ring	Type or Catalog Number: Ringless	No. Jaws	Bypass	Rating Amps.	Main Breaker
Landis & Gyr	Overhead					
	AS Series	AS Series	4, 5, 6		100-200	
		A2 thru A6	4, 5		100-200	
		Series (Multiple Mounting)				
		CQ#	4, 5, 7		200	
		HQ#	4, 5, 7		200 HD	
		HQ-T	6, 7, 8, 13		20	
	Underground					
		RSU#	4, 5, 6		200	
		CQ-U#	4, 5, 7		200	
		HQ-U#	4, 5, 7		200	
Milbank	Overhead					
		S7462, 3,4,5,6				
		S4950-RL-200	4		200	200
		S3950-RL-100	4		100	100
		U4216-RXL	4	Bypass	200	
		U5786-X-K3-K2-BL	4 or 5	HD LVR	320 (400 max) (HD)	
		U7362*, 3,4,5,6	4 or 5		100	
		U7487-XL-TG-KK	4 or 5	Horn	125	
	S7486 Series	R7486 Series*	4 or 5		100	
	S7262 Series	U7262 Series*	4 or 5		150	
	S7021 Series	U7021 Series*	4 or 5		200	
	S9550 Series	U9550 Series*	4 or 5		200 (HD)	
	S9700 Series	U9700 Series*	7		200 (HD)	
		U9801-RRL	4 or 5	HD LVR	200	
	Underground					
		U4216-RXL	4	Bypass	200	
		U7487-XL-TG-KK	4 or 5	Horn	125	
		U5786-X-K3-K2-BL	4 or 5	HD LVR	320 (400 max) (HD)	
	S8086-XL	U8086-XL*	4 or 5		100	
	S8084-XL	U8084-XL*	4 or 5		150	
	S7040-XL	U7040-XL*	4 or 5		200	
	S9551-XL	U9551-XL*	4 or 5		200 (HD)	
	S9701-XL	U9701-XL*	7		200 (HD)	
		U9801-RRL	4 or 5	HD LVR	200	

Available with UL label
*UL label

gb - Meter Sockets

Manufacturer	Type or Catalog Number: Ring	Ringless	No. Jaws	Bypass	Rating Amps.	Main Breaker
Milbank						
	Underground Pedestal					
	MPAP-200-MB-78		4		200	200
	MPAPD-200-MB-78 (double sided)		4		200	200
Superior	Overhead					
		501	4, 5		100	
	314*	414*	4, 5		150	
	314*	414*	4, 5		200	
		452 Series	4, 5		150 per sta.	
	382 Series	482 Series*	4, 5		200 per sta.	
		492 Series	7		200 3ø 4w Y or Delta per sta.	
		RLK Series*	5, 7		200 3ø 4W Y or Delta 600 V	
	Underground					
Superior	314*	414*	4, 5		100	
		414*	4, 5		150	
		414	7		200 3ø 4w Y or Delta	
		"RLPK" Series	5, 7		200 3ø 4w Y or Delta 600 V	
		BRL 1915	4, 5		150 per sta.	

#Available with UL label
* UL label
** Transformer rating in first figure; maximum loading shown by second figure

gb - Meter sockets

Manufacturer	Conditions
Durham	
M-400 ampere 4 or 5 jaws for use with Class 10 meters	To obtain experience.
Landis & Gyr	
Meter mounting device 400 ampere, Type K-4# for use with Type MS-K, 1 ø Duncan meters	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies.
Socket type HQ-4S 4 jaws rated for Class 300 service	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by regulatory bodies.
Milbank	
Type S1079-F, 4 jaws rated for Class 320 service	To obtain experience.

#Available with UL label.

gj - Crossarm Assemblies and Arm Spacers

Distribution

Wood crossarm assembly complete with braces and attaching hardware, fittings and bolts

Crossarm Assembly

Manufacturer	Crossarm Size	Catalog No.
Brooks	3-1/2” x 4-1/2” x 8'-0"	3103-A8
	3-3/4” x 5-3/4” x 8'-0"	3103-C8
	3-3/4” x 7-3/4” x 8'-0"	3203-A8
	3-3/4” x 7-3/4” x 10'-0"	3203-A10
Hughes Brothers	3-1/2” x 4-1/2” x 8'-0"	2890A
	3-3/4” x 5-3/4” x 8'-0"	2890B
	3-3/4” x 7-3/4” x 8'-0"	2892-A
	3-3/4” x 7-3/4” x 10'-0"	2892-B
Pennington	3-1/2” x 4-1/2” x 8'-0"	C500B
	3-3/4” x 5-3/4” x 8'-0"	C500F
	3-3/4” x 7-3/4” x 8'-0"	C500M

Twin Arm Spacer*

To be used with standard hardware, 3-5/8" x 4-5/8" x 8’-0” crossarm, and 28" wood braces

Line Hardware CAS-455

*Restricted to applications where the conductor's maximum design tension is less than 1250 lbs. and to conductor sizes 1/0 ACSR and below.

gj - Crossarm Assemblies

Braceless, wood

Manufacturer	Dimensions	Conditions
Aluma-Form		
HD-DEA-86-EB-REA	4-1/4” x 5-1/2” x 8’-0”	To obtain experience.
HD-2-DEA-86-EB-REA	5-3/8” x 5-1/2” x 8’-0”	
HD-DEA-108-EB-REA	4-1/4” x 5-1/2” x 10’-0”	
HD-2-DEA-108-EB-REA	5-3/8” x 5-1/2” x 10’-0”	
Hughes Brothers		
3377-A7.5	3-1/2” x 7-1/2” x 8’-0”	To obtain experience.
3377-A8.5	3-1/2” x 8-1/2” x 8’-0”	
3377-A9.5	3-1/2” x 9-1/2” x 8’-0”	

gj - Crossarm Assemblies

Braceless, fiberglass

Aluma-Form		
FDA20-96	3-5/8” x 4 5/8” x 8’	To obtain experience.
FDA20-120	3-5/8” x 4 5/8” x 10’	
FDA25-96	3-5/8” x 4 5/8” x 8’	
FDA25-120	3-5/8” x 4 5/8” x 10’	
FDA30-96	3-5/8” x 4 5/8” x 8’	
FDA30-9120	3-5/8” x 4 5/8” x 10’	
Geotek (PUPI)		
DA2000096	3-5/8” x 4-5/8” x 8’-0”	To obtain experience.
DA2000120	3-5/8” x 4-5/8” x 10’-0”	
DA2500096	3-5/8” x 4-5/8” x 8’-0”	
DA2500120	3-5/8” x 4-5/8” x 10’-0”	
DA3000096	3-5/8” x 4-5/8” x 8’-0”	
DA3000120	3-5/8” x 4-5/8” x 10’-0	
DA4000096	4” x 6” x 8’-0”	
DA4000120	4” x 6” x 10’-0”	
DA4400096	4” x 6” x 8’-0”	
DA4400120	4” X 6” X 10’-0”	
MacLean Power Systems		
PZ08LD	4” x 6” x 8’ – 0”	To obtain experience.
PZ10LD	4” x 6” x 10’ – 0”	
PY08SD	4” x 6” x 8’ – 0”	
PY10SD	4” x 6” x 10’ – 0”	
PW08LD	3-5/8” x 4-5/8” x 8’ – 0”	
PW10LD	3-5/8” x 4-5/8” x 10’ – 0”	
Powertrusion		
PSD082A1FRUS	4” x 6” x 8’-0”	To obtain experience.
PSD102A1FRUS	4” x 6” x 10’-0”	
PHD082A1FRUS	4” x 6” x 8’-0”	
PHD102A1FRUS	4” x 6” x 10’-0”	
Shakespeare		
IDB096	4" x 6" x 8'-0"	To obtain experience.
XDB096	4" x 7-1/2" x 8'-0"	
HDB096	3-1/2" x 4-1/2" x 8'-0"	
IDB120	4" x 6" x 10'-0"	
XDB120	4" x 7-1/2" x 10'-0"	
TDB096	3-1/2” x 4-1/2” x 8’-0”	
HDB120	3-1/2” x 4-1/2” x 10’-0”	
TDB120	3-1/2” x 4-1/2” x 10’-0”	

gj - Crossarm Assemblies

Braceless, fiberglass

Manufacturer	Description	Conditions
DIS-TRAN Wood Products, LLC		
CDL Series, CDM Series, CDH Series	8-foot and 10-foot	To Obtain experience.
Creative Pultrusions, Inc.		To obtain experience
SD409600K	4"x6"x 8'	
SD401200K	4"x6"x 10'	
SD609600K	3-5/8"x4-5/8"x 8'	
SD601200K	3-5/8"x4-5/8"x 10'	
SD800960K	3-5/8"x4-5/8"x 8'	
SD801200K	3-5/8"x4-5/8"x 10'	

Conditional List
gj(3)
May 21, 2020

gj - Crossarm Assemblies
Composite

Manufacturer	Description	Conditions
Hubbell Power Systems		
CDA25G060D2000	4-5/8" X 3-5/8" X 5'-0"	To obtain experience
CDA25G096D2000	4-5/8" X 3-5/8" X 8'-0"	To obtain experience
CDA25G096D4000	4-5/8" X 3-5/8" X 8'-0"	To obtain experience
CDA25G120D2000	4-5/8" X 3-5/8" X 10'-0"	To obtain experience
CDA25G120D4000	4-5/8" X 3-5/8" X 10'-0"	To obtain experience
CDA25G144D2000	4-5/8" X 3-5/8" X 12'-0"	To obtain experience
CDA25G144D4000	4-5/8" X 3-5/8" X 12'-0"	To obtain experience

go – Fault Indicator, overhead

Manufacturer	Type
Smart Grid Solutions	FI-5A

gw - Crossarm Assembly for H-Frame Construction

Applicable Specification: RUS Specification T-7, Revision dated November 1962
Applicable Drawing: TH-11B Series (161 kV maximum)
No braces (TH-11B)
Two vee braces on outside (TH-11BVO)
Two vee braces on inside (TH-11BVI)
Four vee braces (TH-11BV4)

3-5/8" x 9-3/8" x 33' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.

Catalog Nos. or Drawing Nos.

	TH-11B	TH-11BVO	TH-11BVI	TH-11BV4
	Items	Items	Items	Items
(Assemblies)	gw	gw and vo	gw and vi	gw and vv
Brooks (1, 2)	6411	6411-1	6411-2	6411-3
DIS-TRAN Wood Products, LLC (2,3)	D3011	D3011VO	D3011VI	D3011V4
Hughes Brothers (1, 2)	C3316-B	C3316-B	C3316-B	C3316-B
Pennington (1, 2)	CCC11B72	CCC11B72-VO	CCC11B72-VI	CCC11B72-V4

1 - Fixed spacer fitting sizes as required
2 - Adjustable spacers are available

gw - Crossarm Assembly for H-Frame construction (Double Arm) 230 kV (Small Angle)

Applicable Specification: RUS Specification T-8, Drawing: TH-231B

Assembly complete with attaching hardware, fittings, bolts and braces.

Crossarm 3-5/8" x 9-3/8"

Manufacturer	Catalog Number
Brooks (1, 2)	64231
DIS-TRAN Wood Products, LLC (2,3)	D3231
Hughes Brothers (1, 2)	C-3338-B
Pennington (1, 2)	CCC231B82

Crossarm 5-1/8" x 7-1/2"

Brooks (1, 2)	64231L
Hughes Brothers (1, 2)	C-3338-BL
Pennington (1, 2)	CCC231BT

1 - Fixed spacer fitting sizes as required.
2 - Adjustable spacers are available.

gy - Crossarm Assembly for H-Frame Construction
(Double Arm)

Applicable Specification: RUS Specification T-7, Revision dated November 29, 1962

Applicable Drawing: TH-10 Series
No braces (TH-10)
Two vee braces on outside (TH-10VO)
Two vee braces on inside (TH-10VI)
Four vee braces (TH-10V4)

3-5/8" x 9-3/8" x 32' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
(Assemblies)	Items gy	Items gy and vo	Items gy and vi	Items gy and vv
Brooks (1, 2)	6410	6410-1	6410-2	6410-3
DIS-TRAN Wood Products, LLC (2,3)	D3010	D3010VO	D3010VI	D3010V4
Hughes Brothers (1, 2)	C-3316-A	C3316-A	C-3316-A	C-3316-A
Pennington (1, 2)	CCC1071	CCC1071-VO	CCC1071-VI	CCC1071-V4
Niedermeyer-Martin (1)	N-6710	N-6711	N-6712	N-6713

1 - Fixed spacer fitting sizes as required

2 - Adjustable spacers are available

Conditional
gy(1)
August 2014

gy - Crossarm Assembly for H-Frame Construction
(Double Arm)

Applicable Specification: RUS Specification T-7, Revision dated November 29, 1962

Applicable Drawing: TH-10 Series
No braces (TH-10)
Two vee braces on outside (TH-10VO)
Two vee braces on inside (TH-10VI)
Four vee braces (TH-10V4)

3-5/8" x 9-3/8" x 32' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
(Assemblies):	Items gy	Items gy and vo	Items gy and vi	Items gy and vv
PUPI (1,2)	-	TX3020VO	-	TX3020V4
(conditions):		(To obtain experience)		(To obtain experience)

1 - Fixed spacer fitting sizes as required
2 - Adjustable spacers are available

4" x 6" x 32' fiberglass crossarm assembly complete with attaching hardware, fittings, bolts and 3-5/8" x 4-5/8" fiberglass braces.

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
(Assemblies):	Items gy	Items gy and vo	Items gy and vi	Items gy and vv
PUPI (1,2)	TX4020	TX4020VO	TX4020VI	TX4020V4
(conditions):		(To obtain experience)		(To obtain experience)

1 - Fixed spacer fitting sizes as required
2 - Adjustable spacers are available

gy - Crossarm Assembly for H-Frame Construction (Double Arm) 230 kV (Tangent)

Applicable Specification: RUS Specification T-8

Applicable Drawing: TH-230

Assembly complete with attaching hardware, fittings, bolts and braces.

Crossarm 3-5/8" x 9-3/8"

Manufacturer	Catalog No.
Brooks (1, 2)	64230
DIS-TRAN Wood Products, LLC (2,3)	D3230
Hughes Brothers (1, 2)	C-3338-A
Pennington (1, 2)	CCC23081
Niedermeyer-Martin (1)	N-6720

Crossarm 5-1/8" x 7-1/2"

Brooks (1, 2)	64230L
Hughes Brothers (1, 2)	C-3338-AL
Pennington (1, 2)	CCC230T

1 - Fixed spacer fitting sizes as required.

2 - Adjustable spacers are available.

gz - Crossarm Assembly for Wishbone Construction "Z" Type (Single Arm)

Applicable Specification: RUS Specification T-5

Applicable Drawings: RUS Drawing TSZ-1

3-5/8' x 5-5/8" wood crossarm assembly complete with brace and attaching hardware, fittings, and bolts

The following manufacturers have shown compliance with the applicable specifications for this assembly:

Manufacturer	Catalog Nos. or Drawing Nos.
Brooks	64Z1
Hughes Brothers	C-3162-A and C-3162.10

gz - Crossarm Assembly for Wishbone Construction, "Z" Type (Double Arm)

Applicable Specification: RUS Specification T-5

Applicable Drawings: RUS Drawings TSZ-2

3-5/8" x 5-5/8" wood crossarm assembly complete with brace and attaching hardware, fittings and bolts

The following manufacturers have shown compliance with the applicable specifications for this assembly:

Manufacturer	Catalog Nos. or Drawing Nos.
Brooks (2)	64Z2
Hughes Brothers	C-3162-B and C-3162.10

(2) Adjustable spacers are available.

rp – Wildlife Guards

Manufacturer

Central Moloney, Inc.
- 70380330 Shedmount Guard - Standard Solid
- 70380333 Shedmount Guard - FlamaGuard Solid
- 70380486 Shedmount Guard - Standard Meshed
- 70380489 Shedmount Guard - FlamaGuard Meshed
- 70380340 Mini Shedmount Guard - Standard Solid
- 70380341 Mini Shedmount Guard - FlamaGuard Solid
- 70380499 Mini Shedmount Guard - Standard Meshed
- 70380464 Mini Shedmount Guard - FlamaGuard Meshed
- 70380463 Recloser Guard - Standard Solid
- 70380459 Recloser Guard - FlamaGuard Solid
- 70380483 Recloser Guard - Standard Meshed
- 70380496 Recloser Guard - FlamaGuard Meshed
- 70380343 Shedlock Guard
- 70380349 Arrestor Bracket Cap (AB Cap)
- 70380359 Arrestor Bracket Cap (AB Cap) FlamaGuard
- 70380461 MegaGuard
- 70380457 MegaGuard FlamaGuard
- 70380473 Shedmount TI - Standard Solid
- 70381422 Shedmount TI - Standard Meshed
- 70380479 Shedmount TI - FlamaGuard Solid
- 70381428 Shedmount TI - FlamaGuard Meshed
- 70380436 Handwheel Guard
- 70380438 Handwheel Guard - FlamaGuard

Hubbell Power Systems
- “Greenjacket®” series

Chris Kaye (Critter Guard)
- 201 - "L" Bracket
- 202 – Roller
- 203 - Wheel

Hendrix Wire & Cable
- BG-9 Bushing Cover

Hendrix (Eco Electrical Systems, Inc.)
- EICG-1 Insulator/Conductor Cover
- EICG-1-WLPT Insulator/Conductor Cover
- EICG-1-20 Insulator/Conductor Cover
- EICG-1-32 Insulator/Conductor Cover

rp – Wildlife Guards

Manufacturer

*Kaddas Enterprises Inc.
- KE1039 Short Line Insulator Protector
- KE1045A Birdguard
- KE1049 Birdguard
- KE1053 Arrester cap
- KE1064 Bushing cover
- KE1066 Arrester cap
- KE1068 Cutout Switch Cover
- KE1077 Bushing cover
- KE1077 Rev A Transformer Bushing Cover
- KE1079 Rev B Load Break Cutout Cover
- KE1113 Dead-End Shoe Cover
- KE1165 Low Profile Birdguard
- KE1166-01 Line Protector Horizontal
- KE1182-03 Rev B Dead End Cover
- KE1198 Low Profile Line Protector, Clamp/Vise Top
- KE1203 Cutout Cover
- KE1501 Bushing Terminal Cover

Power Line Sentry, LLC
- Line Covers (for C or J-neck insulators)
  - CCSTT, single top tie conductor cover
  - CCDTT, double top tie conductor cover
  - CCDST, double side tie conductor cover

Preformed Line Products
- RPC-0800 RAPTOR PROTECTOR™ (black)
- RPC-0801 RAPTOR PROTECTOR™ (grey)

NOTES: *Specified by manufacturer as being flame-retardant

rp – Wildlife Guards

Manufacturer

Tripp (Eco Electrical Systems, Inc.)
- ECC-1 Cutout Cover
- ECC-2-27-150BIL-S&C-Version 10 Cutout Cover
- ECC-3-27-150BIL-S&C-Version 9 Cutout Cover
- ECC-4-27-125BIL-S&C-Kearney HX Cutout Cover
- ECC-5-ABB-LBU Cutout Cover

TE Connectivity - Energy
- BCAC Bushing Connection Animal Covers
- BCIC Bus Connection Insulating Covers
- BISG Bus Insulator Squirrel Guard
- MVLC Medium Voltage Line Cover (5-25kV)

Universal Thermography, Inc.
- TGB-50007 Bushing Cover
- TGB-65010 Bushing Cover
- TGB-82512 Bushing Cover

W. H. Salisbury & Co.
- 21116 Bushing Cover
- 21317 Tri-Port Bushing Cover
- BC512 Cone Bushing Cover
- 38-2SC Stinger Cover 3/8” IDx2’
- 38-12SC Stinger Cover 3/8” IDx12’
- 38-18SC Stinger Cover 3/8” IDx18’
- 38-50SC Stinger Cover 3/8” IDx50’
- 38-100SC Stinger Cover 3/8” IDx100’
- 58-12SC Stinger Cover 5/8” IDx12’
- 58-50SC Stinger Cover 5/8” IDx50’
- 58-100SC Stinger Cover 5/8” IDx100’
- 34-12SC Stinger Cover 3/4” IDx12’
- 34-25SC Stinger Cover 3/4” IDx25’

Utility Solutions, Inc.
- USVS Series*

rp – Wildlife Guards

Manufacturer

Reliaguard®*
- C0-10005
- LA-13002
- TC-14001
- PI-12002
- RCK-12001K
- RK-11001K
- RK-11002K
- RK-11021 K
- DE-16001
- PI-12001
- PD- 04015F
- PD-0522F
- BC-15001
- BC-15002
- BB-20045-R
- BB-25045-R
- BB-40045-R
- BB-45045-R
- RW-30100
- RW-36036
- RW-36048
- EEL-02503750-50-Y
- EEL-03750500-50-Y
- EEL-05000750-50-Y
- EEL-07501000-50-Y
- EEL-10001250-50-Y
- EEL-12501500-50-Y
- EEL-15001750-25-Y
- EEL-17502000-25-Y

Midsun Group, Inc.
- E/Flex Barrier*
- E/Anti-Nesting Barrier*
- E/Silicone Wildlife Covers**

rp – Wildlife Guards

Manufacturer	
Celeco®	Wildlife Guards for Bushings and polymer Arresters (WLP) (up to 25kV)
Power Grid Pros	The C.O.P. Transformer Protector* (Wildlife Guard for Bushings and polymer Arresters (WLP) (up to 35kV))
Hendrix Wire & Cable	HPP-24
Preformed Line Products	SDS-005
Power Line Sentry	CT-D02, Universal Cutout Cover

sb - Switch, disconnect (single-pole, hook operated station class)

NEMA standard switches for station or line structure use where single-pole switching is permissible

Manufacturer	Type	Voltage Ratings	System Voltages Line to Line
ABB	HPL	15 thru 69 kV	12.5 thru 69 kV
Bridges	EH	15 thru 69 kV	12.5 thru 69 kV
	EHL(L)	15 thru 34.5 kV	12.5 thru 34.5 kV
Cleaveland/Price	LCO-C	15 thru 69 kV	12.5 thru 69 kV
Eaton	D73P**(PL)	15.5, 25.8, 38kV	12.5 thru 35.5kV
G & W Electric	B-2M	15 thru 69 kV	12.5 thru 69 kV
	EV(PL)	15 thru 34.5 kV	12.5 thru 34.5 kV
Hubbell (Chance)	M3(PL)	15 thru 27 kV	12.5 thru 24.9 kV
Johnson	HPT	15 thru 69 kV	12.5 thru 69 kV
Joslyn (Hi-Voltage)	HU	15 thru 34.5 kV	12.5 thru 34.5 kV
	HI	15 thru 34.5 kV	12.5 thru 34.5 kV
Kearney/Eaton	M-72(PL)	15 thru 69 kV	12.5 thru 69 kV
	H-72	15 thru 34.5 kV	12.5 thru 34.5 kV
MEMCO	STV	15 thru 69 kV	12.5 thru 69 kV
	STU	15 thru 69 kV	12.5 thru 69 kV
Morgan	DHS(PL)	15 thru 69 kV	12.5 thru 69 kV
Royal	BT	15 thru 69 kV	12.5 thru 69 kV
Switchgear	BLT(PL)	15 and 23 kV	12.5 thru 24.9 kV
S & C*	LBD(PL)	15 thru 34.5 kV	12.5 thru 34.5 kV
	Alduti (L)	15 and 25 kV	12.5 thru 24.9 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available for voltages 34.5 kV and below. Consult switch manufacturer concerning loop switching applications at higher voltages.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.
**Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

sb - Switch, disconnect (single-pole, hook-operated station class)

NEMA standard switches for station or line
structure use where single-pole switching is permissible

Manufacturer	Type	Voltage Ratings	System Voltages Line-to-Line
Seeco	BT	34.5 thru 69 kV	34.5 thru 69 kV
Siemens-Allis	HA	15 thru 69 kV	12.5 thru 69 kV
	HS(PL)	15 and 25 kV	12.5 thru 24.9 kV
Southern States	PBO	15 thru 69 kV	12.5 thru 69 kV
	*PBN	15 thru 23 kV	12.5, 13.2, 24.9 kV
USCO	HH(PL)	15 thru 69 kV	12.5 thru 69 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

* With steel base only.

(PL) Means hooks for portable load interrupters are available for voltages 34.5 kV and below. Consult switch manufacturer concerning loop switching applications at higher voltages.

sb – Switch, disconnect (single-pole, hook operated distribution class)*

For distribution line use where power class insulation is not required and single-phase switching is permissible.

(Not suitable for substation use)

Manufacturer	Type	Voltage Rating	System Voltage Line-to-Line
Eaton	D73P***(PL)	15.5, 25.8, 38kV	12.5 thru 35.5kV
G & W Electric Company	EV(PL)	15 kV	12.5 kV
Hubbell (Chance)	M3(PL)	15 and 27 kV	12.5 thru 24.9 kV
	M3C	15 and 27 kV	12.5 thru 24.9 kV
Kearney/Eaton	D-73(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Morgan	DHS(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
Royal Switchgear	BLT (PL)	7.5 thru 34.5 kV	7.5 thru 34.5 kV
	BILT (PL)	7.5 thru 34.5 kV	7.5 thru 34.5 kV
	BISL(PL)	15 thru 25 kV	15 thru 25 kV
S & C**	LBD(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Siemens-Allis	HD(PL)	15 and 25 kV	12.5 thru 24.9 kV
Siemens Energy, Inc.	LER (L)(PL)	15 and 25 kV	12.5 thru 24.9 kV
	SER (L)(PL)	15, 25, and 38 kV	12.5 thru 34.5 kV

NOTE: Switches on this page must be furnished with four bolts for double crossarm mounting.

(L) Means solid material load interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available.

(LV) Means vacuum interrupters are available and accepted.

*Steel bases only.

**Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.
***Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

sb - Switch, hookstick
(line tension switches)

Manufacturer	Type	Voltage Ratings	System Voltages Line to Line	Conditions
Aluma-Form, Inc.	HDS-600A	15 kV thru 34.5 kV	12.5 kV thru 34.5 kV	To obtain experience.
	HDS-900A	15 kV thru 34.5 kV	12.5 kV thru 34.5 kV	To obtain experience.
TE Connectivity - Energy	AMPACT (ILD-II)	15 kV	12.5/7.2 kV	To obtain experience.
Bridges	127	15 kV	12.5/7.2 kV	To obtain experience.
Hubbell (Chance)	ALTD06200R	15 kV	12.5/7.2 kV	To obtain experience.
Royal Switchgear	IL6B-H *(available with silicone polymer insulators as catalog number IL6NP)*	15 kV	12.5/7.2 kV	To obtain experience.

NOTE: All switches listed on this page have hooks for portable load interrupters.

sc - Regulators, Voltage
12.5/7.2 kV
13.2/7.62 kV

Applicable Specification: "RUS Specification for Substation Regulators," S-2

Type	Size	Description
	ABB	
UTS, UTT	167-1000 kVA	(S) Three phase step type
	Eaton	
VR-32	19.1 - 833 kVA	(SL)Single phase - step type
AB	50 amp.	(L) Single-phase - step type (Auto-Booster)
	General Electric	
VR-1	38.1 - 509 kVA	(SL) Single-phase - step type
MLT	500 - 1000 kVA	(S) Three-phase - step type
VML-32	500 - 833 kVA	(S) Single-phase - Vacuum step type
VMLT-32	1200 - 2800 kVA	(S) Three-phase - vacuum step type
	Siemens-Allis	
JFR	38.1 - 667 kVA	(SL) Single-phase - step type

(L) Indicates line use
(S) Indicates substation use

sc - Regulators, Voltage
24.9/14.4 kV

Type	Size	Description
	Eaton	
VR-32	72 - 833 kVA	(SL) Single phase - step type
AB.	50 amp	(L) Single phase - step type (Auto-Booster)
	General Electric	
VR-1	72 - 576 kVA	(SL) Single phase - step type
VML-32	500 - 833 kVA	(S) Single phase - vacuum step type
VMLT-32	1200 - 4666 kVA	(S) Three phase - vacuum step type
	Siemens-Allis	
JFR	72 - 833	(SL) Single phase - step type

(L) Indicates line use
(S) Indicates substation use

sc - Regulators, Voltage

Manufacturer	Conditions
General Electric	
Three-phase, step-type substation regulator Type TMLT-32 (13.2/7.62 kV)	To obtain experience.
Howard Industries, Inc.	
Single-phase, 32 step, line/substation, 50, 75, 100, 150, 219, 328, 438, 546, and 656 ampere, 7.62 kV, Type SVR-1	To obtain experience.
Single-phase, 32 step, line/substation, 50, 100, 150, 200, 231, 300, 400, 463, and 578 ampere, 14.4 kV, Type SVR-1	
Siemens-Allis	
Three-phase, step-type substation regulator Type SFR (13.2/7.62 kV)	To obtain experience.

sd - Current Transformers
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
ABB	CSF/CMS CMF CLC/CLE	KOR-11 KON-11 KOT-11	ICT-150 KOR-l5 KOT-l5	ICT-200 KOR-20 -	ICT-350 - -
Arteche	IRH-1 IRH-5 IRH-7 IRH-10 IRH-12	CRE-17 CRB-17 ME-015 MK-15 MI-015 KM-15 KCB-17	CRF-24 CRE-24 ME-025 MK-25 MI-025 KM-25 KCB-24	CRF-36 CRF-36 (extended range) CRK-36 CE-034 ME-036 MK-36 KM-36	CRH-72 CRK-72 CE-069
G.E.C. Durham Industries (Astra)	AA&TA AB AD&AC	- - -	- - -	- - -	- - -
Electromagnetic Industries (Square D)		CO3-110	CO3-150	CO3-200	lK-350
General Electric	JCR-0 JCW-0 JAK-0 JAD-0	JKW-5 JCK-5 - -	JKW-6 JKW-150 KG-150 -	JKW-7 JKW-200 KG-200 -	JKW-350 KG-350 -
Kuhlman Electric		BB-15-971 BB-15-972	BB-25-973 BB-25-974	BB-34-975 BB-34-976	COF-350 -
Arteche	-	CRE-17 CRB-17	CRF-24 CRE-24	CRF-36 CRF-36 (extended range)	- -
Ritz Instrument Transformers, Inc.	DCBW DCCW DCAB	GIFU 15-01; 0.3 B0.1-1.8 GIFU 15-01; 0.3 B0.1-0.5	GIFU 25-01; 0.3 B0.1-0.9 GIFU 25-01; 0.3 B0.1-2.0	GIFS 36-55; 0.3 B0.1-0.9 GIF 36-69; 0.3 B0.1-2.0	GIF 72.5-68; 0.3 B0.1-2.0
Schlumberger	R6S R6SA R6M R6L	- - - -	- - - -	- - - -	- - - -

NOTE: The transformer types listed above are accepted in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

sd - Current Transformers
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
Instrument Transformer Equipment Corp (ITEC)		HRP-931 HRP-981 HRP-980	HRP-933 HRP-983 HRP-984	HRP-930 HRP-984	
				CTO-200	CTO-350
		CVTO-110	CVTO-150	CVTO-200	CVTO-350
Pfiffner					JOF 72

NOTE: The transformer types listed above are accepted in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

sd - Current Transformers
Outdoor Type

Manufacturer	Conditions
Electromagnetic Ind. (Square D) Type UMCT, 0.6 kV Type UCT, 0.6 kV Type IK 4-350-69, 69 kV (cycloaliphatic resin bushings)	To obtain experience.

se - Voltage Transformers
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
ABB	PPM	VOG-II	LPT-I50	LPT-200	LPT-350
	-	VOY-II	VOG-I5	VOG-20	-
	-	VOZ-II	VOZ-I5	VOZ-20	-
Arteche		VRL-17	URJ-24	VRS-36	URU-72
		URL-17	VRJ-24	URS-36	VRU-72
		URJ-17	URN-24	ME-036	
		VRJ-17	VRN-24	MK-36	
		ME-015	ME-025	KM-36	
		MK-15	MK-25		
		MI-015	MI-025		
		KM-15	KM-25		
		KCB-17	KCB-24		
Electromagnetic Industries (Square D)		PO5-110	PO5-150	PO5-200	U3-350-69
General Electric	JVA-0	JVW-5	JVW-6	JVW-7	ET-350
	JVP-0	JVW-110	-	-	JVT-350
	-	-	JVT-150	JVT-200	-
Kuhlman Electric	-	PTT-110-977	-	-	POF-350
Ritz Instrument Transformers, Inc.	DVE-6	VZF 15-20; 2 Bushing 0.3WXYZ	VZF 25-10; 2 Bushing 0.3WXYZ	VZF 36-10; 2 Bushing 0.3WXY	VEF 72-03; 1 Bushing 0.3WXYZ
	DVF-6	VZF 15-10; 2 Bushing 0.3WXY VEF 15-10; 1 Bushing 0.3WXY VEF 15-20; 1 Bushing 0.3WXYZ	VEF 25-10; 1 Bushing 0.3WXYZ	VEF 36-10; 1 Bushing 0.3WXY	
Schlumberger	T5R	-	-	-	-
	T6R	-	-	-	-
	T7R	-	-	-	-

NOTE: The transformer types listed above are acceptable in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

se - Voltage Transformers
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
Instrument Transformer Equipment Corp (ITEC)			SVTO-150	SVTO-200	
		CVTO-110	CVTO-150	VTO-200 CVTO-200	VTO-350 CVTO-350 PST-350
Pfiffner					EOF 72

NOTE: The transformer types listed above are acceptable in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

se - Voltage Transformers
Outdoor Types

Manufacturer	Conditions
G.E.C. Durham Industries (Astra)	
Type DB, 0.6 kV	To obtain experience.
Type DA, 0.6 kV	
Type DF, 0.6 kV	
Electromagnetic Industries (Square D)	
Type U-450, 0.6 kV	To obtain experience.
Type U-4-350-69, 69 kV (cycloaliphatic resin bushings)	

sj - Switches, oil circuit recloser by-pass

Manufacturer	15 kV For use on12.5/7.2 kV systems	27 kV For use on 24.9/14.4 kV systems	27 kV* For use on 34.5/19.9 kV systems	Current Rating Amperes
Eaton	D73P**-BE***	D73P**-BE***	D73P**-BE***	600, 900
Hubbell (Chance)	M3-R BP3 BPF	M3-R BP3 BPF	M3-R BP3 BPF	600 600, 900 600
Kearney/Eaton	D73RB	D73RB		600
Siemens Industry Inc.	B-2	B-2	B-2	600

*Not For Use In Substations
**Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.
***Option BE means switch is equipped with bypass studs and REA 4 bolt back strap.

sk - Switch, regulator by-pass - disconnect
For outdoor use

Manufacturer	15 kV for use on 12.5/7.2 kV Systems	27 kV for use on 24.9/14.4 kV Systems	Current Rating Amperes
Eaton	D73P3**	D73P3**	600, 900
Hubbell Power Systems, Inc.	BPR	BPR	600
Kearney/Eaton	HB-65	HB-65	600
S & C Electric*	XL	XL	600
Siemens-Allis	HR	HR	600
Siemens Industry Inc.	B-2	B-2	600
Southern States	BR	BR	400,600

NOTE: All switches should be furnished with NEMA standard insulators and with 110 kV BIL rating (15 kV systems) or 150 BIL ratings (25 kV systems) for station use.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.
**Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

sk - Switch, regulator by-pass - disconnect
For outdoor use

Manufacturer	Conditions
Eaton Type B, 15 kV, 400 amperes, 110 kV BIL for station use, 95 kV BIL for line use.	To obtain experience.

NOTE: All switches should be furnished with NEMA standard insulators and with 110 kV BIL rating for station use.

sl - Switch, Combination Power Fuse and Disconnect

(Used with an additional disconnect switch to by-pass oil circuit reclosers at substations)

Manufacturer	15 kV for use on 12.5/7.2 kV systems	27 kV for use on 24.9/14.4 kV systems
Joslyn (Hi-Voltage)	RFH	-
Kearney/Eaton	MHX	MHX
S & C Electric*	SMD/LBD XS/LBD	SMD/LBD -
Southern States	SF	-

NOTE: All switches and cutouts should be furnished with NEMA standard insulators.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

sr - Steel Conductor for Substation Grounding, Copper-Clad or Galvanized

(See av-2 for copper grounding conductor)

Manufacturer	Type	Sizes
AFL Copperclad	copper-clad steel (dead soft annealed)	7 No. 6 AWG 7 No. 5 AWG 7 No. 4 AWG 19 No. 9 AWG 19 No. 8 AWG 19 No. 6 AWG 19 No. 5 AWG
Copperweld Bimetallics, LLC*	Dead Soft Annealed (DSA) Copperweld Conductors	7 no 8 AWG 2/0 (19x0860” & 7x1379”) 7 no 7 AWG 7 no 6 AWG 7 no 5 AWG 7 no 4 AWG 4/0 (19x1055”) 19 no 9 AWG 19 no 8 AWG 19 no 7 AWG 19 no 6 AWG 19 no 5 AWG

NOTES:

* Theft deterrent versions, both poly-jacketed and camouflaged are acceptable.

1. Minimum 40% conductivity
2. 7-strand conductors can be supplied in 19-strand configuration and vice-versa.
3. Conductors chosen must be able to carry the required short duration fault current and must be selected based on IEEE Standard 80.
4. When used in soil with resistivity of 25 ohm-meters (2500 ohms per cubic centimeter) or less cathodic protection must be incorporated into the grounding design.

sr - Steel Conductor for Substation Grounding, Copper-Clad or Galvanized

(See av-2 for copper grounding conductor)

Manufacturer	Conditions
Indiana Steel & Wire Steel Strand, BB Grade, Class C galvanized 5/8" (19 wire) 1/2" (7 wire) 9/16" (7 wire) 7/16" (7 wire)	1. To obtain experience. 2. When used in soil with resistivity of 25 ohm-meters (2500 ohms per centimeter cube) or less, cathodic protection must be incorporated into the grounding design.

NOTES:

1. Minimum 40% conductivity
2. 7-strand conductors can be supplied in 19-strand configuration and vice-versa.
3. Conductors chosen must be able to carry the required short duration fault current and must be selected based on IEEE Standard 80.

sr - Conductor for Substation Grounding, alternative conductor

Manufacturer	Conditions
ConduGround CG-7/16” CG-1” CG-1-1/2” CThor55Lb GAP55Lb GAP25Lb	To obtain experience.

vx - Cross Brace assembly, 3-3/8" x 5-3/8"
with hardware and fittings (Dwg. TM-110, RUS Specification T-7)

Manufacturer	Catalog No.
Brooks	
Item 1-vx	6685-1
Item 2-vx	6685-2
DIS-TRAN Wood Products, LLC	
Item 1-vx	D2110B
Hughes Brothers	
Item 1-vx	1042-1
Item 2-vx	1042-2
Niedermeyer-Martin	
Item 1-vx	N-6714-1
Item 2-vx	N-6714-2
Pennington	
Item 1-vx	CCC-67-1
Item 2-vx	CCC-67-2

Cross Brace assembly, 3-5/8" x 7-1/2" Min.
with hardware and fittings (Dwg. TM-110, RUS Specification T-8)

Manufacturer	Catalog No.
Brooks	6695
DIS-TRAN Wood Products, LLC	D2110C
Hughes Brothers	2061A
Niedermeyer-Martin	N6721
Pennington	CCC69

vx - Cross Brace assembly, 3-3/8" x 5-3/8"
with hardware and fittings (Dwg. TM-110, RUS Specification T-7)

Manufacturer	Catalog No.	Conditions
PUPI		
Item 1-vx	XBR3020-1	To obtain experience.
Item 2-vx	XBR3020-2	

Cross Brace assembly, 3-5/8" x 7-1/2" Min.
with hardware and fittings (Dwg. TM-110, RUS Specification T-8)

Manufacturer	Catalog No.	Conditions

PART II

Underground Distribution Equipment

U ae - Surge Arresters, Distribution for Underground System Pole Risers (Lightning Arresters)

SiC Type

Manufacturer	Type	Accepted Ratings - kV	Duty	Manufacturer's Classification	Housing
ABB	GLV	9, 10	Normal	Distribution	
	LVBB	18	Normal	Distribution	
General Electric	Alugard	9, 10, 18	Heavy	Distribution	

NOTE: The arresters listed on this page may be used singly or in parallel, but must be applied in accordance with paragraph VI.A., in RUS Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

U ae - Arresters, Surge

(Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

ELBOW ARRESTERS

Manufacturer	Type	Ratings, kV	Type	Interface
Eaton	M.O.V.E.	9/10	MOV	15 kV
	M.O.V.E.	18	MOV	25 kV
	VariGAP	9/10	(1)	15 kV
	VariGAP	18	(1)	25 kV
	Posi-Break M.O.V.E.	3-21	MOV	25 kV
	VariGAP Posi-Break M.O.V.E.	9-15	MOV	25 kV
Elastimold ESNA	167 ESA-10	10	MOV	15 kV
	273 ESA-18	18	MOV	25 kV
Hubbell	215ELA-10	10	MOV	15kV
	225ELA-18	18	MOV	25kV
Joslyn	ZE	10	MOV	15 kV
		18	MOV	25 kV

(1) MOV Type (Internally Gapped)

U ae - Arresters, Surge

(Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

PARKING STAND ARRESTERS

Manufacturer	Type	Ratings, kV	Type	Interface
Eaton	MOV PSA	9/10	MOV	15 kV
	MOV PSA	18	MOV	25 kV
	MOV VariGAP PSA	9/10	(1)	15 kV
	MOV VariGAP PSA	18	(1)	25 kV
Elastimold ESNA	167 PSA-10	10	MOV	15 kV
	273 PSA-18	18	MOV	25 kV
Hubbell	215PLA-10	10	MOV	15kV
	225PLA-18	18	MOV	25kV

(1) MOV Type (Internally Gapped)

U ae - Arresters, Surge

(Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

BUSHING ARRESTERS

Manufacturer	Type	Ratings, kV	Type	Interface
Elastimold ESNA	167 BSA-10	10	MOV	15 kV
	273 BSA-18	18	MOV	25 kV

(1) MOV Type (Internally Gapped)

Conditional List
U ae(2)
July 2009

U ae - Arresters, Surge
(For Underground System Pole Risers)

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type

Manufacturer	Type	Accepted Ratings - kV	Duty	Manufacturer' Classification	Housing
ABB	HMX	9,10,18	Heavy		
	RMX	9,10,18		Intermediate *	
	XPR	9,10,18,27	Heavy	Distribution	Polymer
Eaton	CPS AZR VariSTAR	9,10,18,27	Heavy	Distribution	Porcelain
	URS UltraSIL VariSTAR	9,10,18,27	Heavy	Distribution	Polymer
General Electric	Tranquell ** U.D. II	9,10,18,27	Normal	Distribution	Porcelain
	Tranquell	9,10,18,27	Normal	Intermediate	Porcelain
Hubbell (Ohio Brass)	DynaVar-PVR	9,10,18,27	Heavy	Riser Pole	Polymer
Joslyn	ZRP	9,10,18,27	Heavy	Distribution	Polymer

*Has intermediate class arrester characteristics but does not have intermediate class venting capability.
**A non-fragmenting U.D. II Arrester is available for 9 & 10 kV designs at higher cost when specified.

U ae - Arresters, Surge
(For Underground System Pole Risers)

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type (Internally Gapped)

Manufacturer	Type	Accepted Ratings - kV	Duty	Manufacturer's Classification	Housing
Eaton	URT Evolution	9,10,18,27	Heavy	Distribution	Polymer

U an - Transformers, Distribution
Pad-Mounted, Dead-Front

(For underground application)

Manufacturer	Single-Phase 5 - 167 kVA	Three-Phase 30 - 2500 kVA
ABB	"Mini-Pak U-5"	Type MTR (75-1500 kVA) "Plazapad-U5" (2000-2500 kVA)
Central Moloney	"REA-LP"	“Three Phase Pad Mount REA”
Eaton*	"REA Shrubline”	"REA Terra-Tran"
ERMCO, INC.	"Low-Profile"	“E-PAD”
General Electric	-	"Compad IV - REA"
H. K. Porter (Delta-Star)	"Low Profile U 5-R"	"Porter U5-R3"
Magnetron S.A.S.	Pad Mount 5-167 kVA	-
Howard	"Hi Pad REA"	"Hi Pad 3 REA"
Kuhlman	"Lo-Pak ELR"	"K-PAK-3 REA"
CG Power Systems USA, Inc.	"Turf-Hugger-R"	"Turf-Hugger-R"
United (KAEC)	"Pad-Mount" 15-100 kVA (1) “Pad-Mount" 25 & 50 kVA (2)	-
VanTran	"Mini-Pad U5" (1)	"VanTran III-U5"

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

NOTES

All acceptances are based on RUS Specification U-5, “Specifications for Pad-Mounted Transformers (Single and Three Phase).”

All single-phase and three-phase transformers above accepted for the following voltages (kV) unless otherwise noted: 12.47/7.2; 13.2/7.6; 24.9/14.4; and 24.9/14.4 x 12.47/7.2 dual voltage

(1) Accepted for 12.47/7.2 kV and 13.2/ 7.62 kV only.

(2) Accepted for 24.9/14.4 kV only.

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

Not all kVA sizes in above kVA ranges are available from all listed manufacturers.

Some of the above single-phase and three-phase transformers are available with internal under oil surge arresters. The availability and type of arresters vary with each manufacturer. The following types of under-oil arresters are acceptable: “UMX”, “Tranquell” and “AZU.”

U an - Transformers, Distribution
Pad-Mounted, Dead-Front

(For underground application)

Manufacturer	Single-Phase 5 - 167 kVA	Three-Phase 30 - 2500 kVA
RYMEL SAS	Single-Phase Pad-Mounted	Three-Phase Pad-Mounted

*Optional natural ester less flammable fluid filled designs are available
* Available with Internal Fault Detector (IFD).

NOTES

All acceptances are based on RUS Specification U-5, “Specifications for Pad-Mounted Transformers (Single and Three Phase).”

All single-phase and three-phase transformers above accepted for the following voltages (kV) unless otherwise noted: 12.47/7.2; 13.2/7.6; 24.9/14.4; and 24.9/14.4 x 12.47/7.2 dual voltage

(1) Accepted for 12.47/7.2 kV and 13.2/ 7.62 kV only.

(2) Accepted for 24.9/14.4 kV only.

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

Not all kVA sizes in above kVA ranges are available from all listed manufacturers.

Some of the above single-phase and three-phase transformers are available with internal under oil surge arresters. The availability and type of arresters vary with each manufacturer. The following types of under-oil arresters are acceptable: “UMX”, “Tranquell” and “AZU.”

U an - Transformers, Distribution
Pad-Mounted, Dead-Front

(For unit residential underground application)
(Single-phase, 7.2 kV and 7.6 kV)

Manufacturer	5 - 25 kVA Only
ABB	"Micro-Pak U-5"
Central Moloney	"REA-Mini-LP"
Eaton*	"Ranch Runner"
ERMCO, INC.	"REA-MicroTrim"
Howard	"Spacesaver Pad"
RYMEL SAS	Single Phase Pad-Mounted

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

*Optional natural ester less flammable fluid filled designs are available
* Available with Internal Fault Detector (IFD).

NOTES

All acceptances are based on RUS Specification U-5, “Specifications for Pad-Mounted Transformers (Single and Three Phase).”

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

U an - Transformers, Distribution
Pad-Mounted, Dead-Front

(For underground application)

Conditions for Acceptance: To Obtain Experience

Manufacturer	Type
ABB	"Mini-Pak U-5" - Single-phase with composite fiberglass enclosure "Mini Three Phase" (MTP) 30 - 225 kVA
Cam Tran	"Cam Tran" - Three-phase, 12.47/7.2 and 13.2/7.6 kV; 30-2500 kVA
Carte	Three-phase, 24.9/14.4 kV, 30 - 2,500 kVA
Eaton*	Single-phase, self-protected with "Magnex" interrupter Single-phase, self-protected with "AZU" MOV heavy-duty, under-oil arrester
General Electric	"Compad -IV-REA" - Three-phase, 75-750 kVA All above with amorphous metal cores
GE-Prolec	Mini Padmount, Single-phase, 10-167 kVA Three-phase, 12.47/7.2 kV, 45-2,500 kVA Three-phase, 24.9/14.4 kV, 45-2,500 kVA
Square D	Class 7230 REA - Three-phase, 75-2500 kVA 12.47/7.2 kV and 13.2/7.62 kV
Van Tran	"Mini-Pad U5" - 5-167 kVA, 24.9/14.4 kV
Power Partners	Single-phase 5-167 kVA

*Optional EnvirotempTM FR3TM fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

NOTES

All acceptances are based on RUS Specification U-5, "Specifications for Pad-Mounted Transformers (Single and Three Phase)."

All single-phase and three-phase transformers above conditionally accepted for the following voltages (kV) unless otherwise noted: 12.47/7.2; 13.2/7.6; 24.9/14.4; and 24.9/14.4 x 12.47/7.2 dual voltage

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

Not all kVA sizes are available from all listed manufacturers.

U ax - Cutout and Arrester, Combination for Underground System Pole Risers

Nominal System Voltage	For 12.5/7.2 kV		For 13.2/7.6 kV	For 24.9/14.4 kV
Cutout Maximum Voltage Rating	7.8 kV	15 kV	15 kV	27 kV
Application	1ø Risers	3ø Risers	1ø and 3ø Risers	1ø and 3ø Risers
Cutout Current Rating	100 amps	100 amps	100 amps	100 amps
Manufacturer	Catalog Numbers			
ABB	7.8LBU-II/10 LV	15LBU-II/10 LV	15LBU-II/10 LV	24.9LBU-II/18 LV
Eaton	AFS300B Series	AFS300C Series	AFS300C Series	AFS300D Series
General Electric	9F80	9F80	9F80	9F80
Hubbell (Chance)	C7 Series	C7 Series	C7 Series	C7 Series
Southern States	CA Series	CA Series	CA Series	CA Series

NOTE: The units listed on this page may be used with single arresters or arresters in parallel, but must be applied in accordance with paragraph VI.A. in RUS Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

Cutouts used on underground riser poles should be loadbreak type or have hooks for portable load interrupters.

Either normal duty or heavy duty distribution class arresters listed on page ae-1 are acceptable for use with these combination units.

U ax - Cutout and Arrester

Combination for Underground System Pole Risers

Metal Oxide Type Arresters

Nominal System Voltage	For 12.5Y/7.2 kV		For 13.2Y/7.6 kV	For 24.9Y/14.4 kV	Conditions
Cutout Maximum Voltage Rating	7.8 kV	15 kV	15 kV	27 kV	
Application	1ø Risers	3ø Risers	1ø and 3ø Risers	1ø and 3ø Risers	
Cutout Current Rating	100 amps	100 amps	100 amps	100 amps	
Manufacturer	Catalog Numbers				
Eaton	L4A1P1A00-ECOA(9kV)	L9C1P1A00-ECOA(9kV)	L9C1P1A00-ECOA(9kV)	L9D1P1A00-EGOA	To obtain experience
	L4A1P1A00-EDOA(10kV)	L9C1P1A00-EDOA(10kV)	L9C1P1A00-EDOA(10kV)	-	To obtain experience.

Note 1: Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with RUS Bulletin 61-3, "Underground Rural Distribution."

Note 2: Cutouts used on underground riser poles should be loadbreak type or have hooks for portable load interrupters.

U be - Reclosers, pad-mounted

Manufacturer	Conditions
Eaton Single phase, vacuum interrupter, Type PV4H Maximum voltage 14.4 kV for 12.5 and 13.2/7.62 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

U be - Reclosers, vacuum interruption with solid dielectric

Manufacturer	Conditions
G & W Electric Company Three phase, electronic, VIPER Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14/4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.

2. Reclosers are not acceptable with load current, bushing CT battery chargers.

U cg - Switch, air, three-pole, group-operated for pole-mounted cable risers (Factory Preassembled)

Manufacturer	Mounting	Vertical Break Type	Vertical Break kV	Side Break Type	Side Break kV
ABB	Vertical	LB3-VR(L)	15	-	
Hubbell (Chance)	Vertical	-		D7(L)	15-27
	Horizontal	-		D7(L)	15-27
Kearney/Eaton	Horizontal	SB_R(L)	15-35	-	
S & C*	Vertical	-		Alduti(L)	15-25
	Horizontal	-		Alduti(L)	15-25

(L) Means gas or solid material full-load interrupters are accepted and available.

*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

NOTE: Switches with factory-assembled crossarm type bases must have nonconducting crossarm type bases, nonconducting braces, and insulated interphase and control rods.

U cg - Switch, Air, Three-Pole, Group Operated

Manufacturer	Conditions
Hubbell (Chance) Type AR side-break, horizontal and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15, 25 , and 34.5 kV (grounded wye)	To obtain experience.
S & C* Omni-Rupter (L), side break horizontal and vertical mounting with non-conducting crossarm type base and insulated interphase and control rods, 15 kV and 25 kV	To obtain experience.

(L) Means full-load interrupter accepted and available.

*Available with porcelain insulators. Available with Cypoxy insulators through 34.5 kV on request.

U fw - Secondary Tap Connector

Manufacturer	Type or Catalog No.
TE Connectivity - Energy	Compression Connectors CRSM-CT-34/10-150 CRSM-CT-53/13-200 CRSM-CT-84/20-250 Standard Split Bolt CRSM-CT-53/13-200

U fz – Transformer Connector Block, Insulated
Multiple Cable Connectors

Watertight – For use in all locations

Manufacturer	Connection Type	Catalog Number
Blackburn	Lug	SCU, with lugs and sleeves
Burndy	Lug	Stud Mole with sealing sleeve
Polaris	Set Screw	IPLWB, SLWB, SSWB, SLOWB
Utilco	Set Screw	PTF-SS, Watertight insulated transformer connector block

Non-Watertight - For use in above grade locations only

AFL	Lug	Interchange 1
		ABBD Series (Disconnectable) Use with A9 insulating boots
Alcon	Set Screw	VBTT Series with double sealing sleeve
Blackburn	Set Screw	TSB-J58C (Permanent)
	Set Screw	TSB-D58C (Disconnectable)
Burndy	Set Screw	K-D Series (Disconnectable)
		K-DF Series (Permanent)
Durham Company	Set Screw	UB Series
	Set Screw	9112212 250 Splice-n-Tap
	Lug	UT Series
Connector Mfg. Co.	Set Screw	Uni-Joint Bar Connectors, (Series RLS, NSM-C, NDS-C, NSC, ZS-C, ZSU-C, RLUS) (Permanent)
	Set Screw	Uni-Joint Bar Connectors, (Series RLSS, NSSM-C, NSSC, ZQC, ZQU-C, RLUSS) (Disconnectable)
ESP	Lug	Types SUR and RDSR(Removable)
		(With Types LA and AL-lugs and Sleeve kits)
	Set Screw	Type UPSO-I (Permanent)
		Type UPM-I (Disconnectable)
Homac	Lug	DF Series
	Lug	FTU 125 Series(Disconnectable) with flood seal sleeve kit
	Set Screw	ABD, ABK, ABS, ABW, CLRTR, CSW, CSS, LRT, RAU, EZC, Z series; ZBK with SB covers; ZVW with boot
Hubbell (Fargo)	Bolted	GUC Series
	Set Screw	GUS-460S Series
MacLean (Reliable)	Set Screw	15912-REA (Disconnectable)
Penn Union	Lug	Type DBAT (Permanent)
	Lug	Type DBAT-LH (Disconnectable)
		Use with Series DBTB, DBTBF and DBTH lug and Sleeves kits
Polaris	Set Screw	PLTZ-CC, PSMTLCC, PSMTLSC
	Set Screw	PTLZ-CC, PSMTLCC, PSMTLSC
	Set Screw	IPCTLZ, IPCTLEZ, PSMTLECC
	Set Screw	PSMTLESC, PTLZSC, PTLZCC, IPPT
Preformed	Set Screw	SC-C series (Permanent)
	Set Screw	CSC-Q-C Series, SC-Q-C series (Disconnectable)
Utilco	Set Screw	PTF-IN (Permanent)
	Set Screw	PTF-CJNU, PSS Series (Disconnectable)
Vector Connectors Corp.	Set Screw	TQL Series (Disconnectable) (with insulating boot)

Note: Additional insulation may be required with some of the above-listed secondary terminal blocks due to the irregularity of mating surfaces between various secondary studs being supplied by the transformer manufacturers.

U gc - Shield, cable riser

Manufacturer	Dia. (Inches)	Length (Feet)
	Galvanized Steel	
Almat Metal Limited	2 1/4	8
Electrical Materials	2 - 3 - 4 - 5*	5*
Hubbell (Chance)	2 - 3 - 31/2	5 - 9
Joslyn	2 - 3 - 31/2*	5 - 8*
Midland-Ross (Kindorf Snapduct)	2 1/2 - 3 1/2 - 5 (14 ga. galv. steel)	2 1/2 - 5 - 10
	Plastic and Fiberglass	
Applied Extrusion Technologies (plastic) (Power Mold, I, II, III)	2 - 3 - 4 - 5 - 6*	5 - 8 - 10*
Carlon	2 - 3 - 4 - 5 - 6*	l0*
Charles Industries	2 – 3 – 4 – 5**	5 and 10**
Custom Plastics	2 - 3 - 4 - 5*	5 - 10*
Electrical Materials (plastic)	1 - 2 - 3 - 4 - 5- 6*	5 - 8 - 10*
Joslyn (plastic)	2*	10*

(Order by size and length)

*All sizes available with back plate.

	Full Round**	
Smith Fiberglass Products (standard wall)	2 - 3 - 4 - 5	30

**Full round riser shield is to be mounted directly to the surface of the pole with no standoffs.

U gk - Terminations, Indoor

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog No.
	PREMOLDED
Eaton	Fasterm Stress Cone (15 & 25 kV)
Elastimold (ESNA)	Style 35-MSC (15, 25 & 35 kV)
Hubbell (Chardon)	Termi-Matic, Type A or G (15, 25 & 35 kV)
	HEAT SHRINK
DSG-Canusa	CT Series (15kV, 25kV, 35kV)
G&W	ESTS15_PLA (15 kV) ESTS25_PLA (25 kV)
Hellermann	MVTS15_PLA (15 kV) MVTS25_PLA (25 kV)
TE Connectivity - Energy	HVT (15, 25 & 35 kV)
	COLD SHRINK
3M	QT III Series (15 kV) Quick Term II Series (25 & 35 kV)
DSG Canusa	TITAN-Z Series (15, 25 kV) TITAN Series (35 kV)
Joslyn	JIPT Series (15, 25 kV) JPT Series (25 kV)
TE Connectivity - Energy	TFT Series (15, 25, 35 kV)
	INSULATED WRAP
Plymouth/Bishop	Stress-Wrap (15, 25 & 35 kV)

U gk - Terminations, outdoor
(with mounting hardware) *

PREMOLDED

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

Manufacturer	Catalog Number
Eaton	Fasterm Series (15 & 25 kV)
Elastimold (ESNA)	Style 16-THG (15 and 25 kV) (for bare concentric neutral cable) Style 35-MT (35 kV) (for bare concentric neutral cable) Style PCT-1 (15 kV) (for jacketed cable) Style PCT-2 (25 kV) (for jacketed cable)
Hubbell (Chardon)	Termi-Matic, Type G (15, 25 and 35 kV)

*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).
NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gk - Terminations, outdoor
(with mounting hardware) *

HEAT SHRINK

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

Manufacturer	Catalog Number
DSG-Canusa	CT Series (15kV, 25kV, 35kV)
G&W	ESTS15_PLO (15 kV) ESTS25_PLO (25 kV)
Hellermann	MVTS15_PLO (15 kV) MVTS25_PLO (25 kV)
Plymouth/Bishop	SWO Kit (15, 25 and 35 kV)
TE Connectivity - Energy	HVT (15, 25 and 35 kV)

*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).
NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gk - Terminations, outdoor
(with mounting hardware) *

COLD SHRINK

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

Manufacturer	Catalog Number
DSG-Canusa	TITAN-Z Series (15, 25 kV) TITAN Series (35 kV)
Joslyn	JPT Series (15, 25, 35 kV)
TE Connectivity - Energy	TFT Series (15, 25, 35 kV)
3M	QT III Series (15, 25, & 35 kV)
Prysmian	PCT Series (15, 25, 35 kV)

*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).
NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gk - Terminations, outdoor
(with mounting hardware) *

PORCELAIN

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

Manufacturer	Catalog Number
G & W	"Eliminator" 15 kV, E 25 kV, E 35 kV, E
Joslyn	"Easy-On II" (15, 25 and 35 kV)

*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).
NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gn - Enclosures, equipment

Applicable Specifications: "RUS Specifications for Equipment Enclosures," U-4

Manufacturer	Catalog No.
Durham	AT-42 Series (dead-front) AT-54 Series (dead-front)
Elliott	EPM-PTS (dead-front)
Hoffman Enclosures, Inc.	UJ Series
Hubbell	P134, P234, P358, P378
American Padmount Systems	APS Series (dead-front)
Maysteel	EL100 (dead-front)
Nordic	ND-28 and ND-33

NOTE:

1. The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.

2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

U gn - Enclosures, Equipment

Sectionalizing Enclosures

Manufacturer	Catalog No.
Aluma-Form	ENC Series
Brooks Utility Products Group	Single Phase 750-7437-001, 750-7437-002, 750-7437-003, 750-7437-004 Three Phase 750-7438-001, 750-7438-002, 750-7438-003, 750-7438-004, 750-7438-005, 750-7438-006, 750-7438-007
Eaton	SecTER Series I and II (Single-Phase and Three-Phase)*
Durham	AM Series
Highline Products	FSC-29 Single Phase FSC-32 Single Phase FSC-33 Single Phase FSC-55 Three Phase FSC-62 Three Phase FSC-65 Three Phase FSC-69 Three Phase FSC-71 Three Phase FSC-79 Three Phase FSC-85 Three Phase
Maysteel	CW200 Series CW300 Series
Nordic	ND Series
Power Design Inc.	Type CJP series, single-phase and three-phase, 15 and 25 kV
Rough Rider Industries	Series RUF93
Shallbetter	SPMS Series (dead-front)

NOTES:

1. The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

* Also available as a Cleer SecTER cabinet with the Cleer, 600 amp load break connector assemblies installed for both 15 kV and 25 kV systems.

U go - Fault Indicator
(For Construction Unit UM 6-4)

Manufacturer	Type
Eaton	S.T.A.R. CR, DR, ER, MR, TPR
Edison Control Corporation	Series EC100 (single phase) Series EC300 (three phase) (Available with mounting kit KT5002)
E. O. Schweitzer	AutoRANGER AR-OH
Fisher Pierce	Series 1514 (current reset, single-phase Series 1515 (current reset, three-phase) Series 1541 (time reset, single-phase Series 1543 (time reset, three-phase Series 1547 (adaptive trip)
Horstmann GmbH	FCI-LT Series Time Reset 29-6214 29-6215 Current Reset 29-6114 29-6115 Navigator LoadTracker (LT) 41-2001
Smart Grid Solutions	FI-3C

Note: Fault indicators that require the drilling or cutting to the enclosure for mounting are not acceptable.

U gp - Connector Blocks and Splices, Secondary

Watertight - For Use In All Locations

Manufacturer	Connection Type	Catalog Number
Alcon	Set Screw	VPB Series
Blackburn	Lug	Series UP (with lugs and sleeves)
	Set Screw	Series USB (1000 amp bus with sleeves)
Burndy	Lug	URD Mole
Connector Mfg. Co.	Compression	Utilug Sure Seal Splice Kits, Series SSK, SSKL
	Set Screw	Uni-Joint Sure Seal Series SSBC
	Set Screw	Secondary Connector ULS2-350
ESP	Lug	Type UC (8 AWG - 500 kcmil) (with LA lug and sleeve)
	Set Screw	Type UPP
Homac	Connector Blocks:	
	Lug	FS-95 Series with flood seal sleeve kit (8AWG - 350 kcmil)
	Lug	FS-125 Series with flood seal sleeve kit (350 - 500 kcmil)
	Set Screw	SHC Series
	Set Screw	RAB Series
	Splices:	
	Compression	RRK Series (#2AWG - 350 kcmil)
	Set Screw	UH11L
	Set Screw	USK Series
	Set Screw	MTB Series
Hubbell (Fargo)	Set Screw	GU-600 Series
Kearney/Eaton	Compression	HCR
	Compression	HAR
MacLean (Reliable)	Set Screw	15903-15908, 15910 with sleeve kit (4 AWG - 350 kcmil) 15911 with sleeve kit (500 - 750 kcmil)
Penn Union	Lug	DBA Series with DBTB, DBTBF and DBTH Series lug and sleeve kits
Preformed	Set Screw	HT Kit Series
TE Connectivity - Energy	Set Screw	GILS-4/0
Utilco	Set Screw	Safety Sub Splice - USPA-350SS
	Set Screw	Safety Sub Tap Connector - PED-350SS

U gp - Secondary Connector Blocks and Splices, Insulated

Non-Watertight - For Use In Above-Grade Pedestals Only

Manufacturer	Connection Type	Catalog Number
Blackburn	Set Screw	Type PSB-C
Connector Mfg. Co.	Set Screw	Uni-Joint Series NCA
ESP	Set Screw	UPC Series
Homac	Set Screw Set Screw	CLR-350 Series PVAB Series
Hubbell (Fargo)	Set Screw	GUS-460 Series
Polaris	Set Screw	IPLC
Ilsco (Utilco)	Set Screw	PED-350CP Series PED-500CP Series
Vector Connectors Corp.	Set Screw	PC Series

U gq - Boot or sleeve, insulated*

Manufacturer	Catalog Number
Blackburn	MPC9 MPC15
Electrical Materials	100-B (For pad-mounted transformer spade terminals)

*Use restricted to 120/208 volt 500 kVA transformers and larger not equipped with threaded studs.

U gu - Pedestal, Power
(Above-Grade)
Refer to Construction Drawing UK5

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Inside Dimensions Inches	Height Inches	Catalog No.
API	6 x 6	32	API 6 x 6
	9 x 10	25-1/2	API 9 x 10
	10 x 11	34	API 10 x 11
	10 x 11	12-1/4	API 10 x FM
	10 x 11	72	API 10 x 11XL
	10 x 14	22-1/2	API 10 x 14
	10 x 14	26-1/2	API 10 x 14 WB
	16 x 28	38	API 16 x28
	13 Dia.	25	API 176
Coil Sales			
(Charles Industries)	8.25 Dia	31-1/2	CPLP-8
	8.25 Dia	31-1/2	CPLP-8I(Integral Stake)
	10.75 Dia	31-1/2	CPLP-10
	10.75 Dia	31-1/2	CPLP-10I(Integral Stake)
Electrimold	14.5 x 19.5	31.5	EFSO-111630
Highline Products	14 X 9	31	FSP140931AA
	15.5 X 15.5	30	FSP151530AA
	15.5 X 15.5	36	FSP151536AA
	14 X 9	36	FSP140936AA
	9 X 9	31	FSP090931AA
Hubbell Power Systems, Inc.	10 x 15	30	SP101530
	10 x 15	36	SP101536
	11 x 21	30	SP112130
	11 x 21	36	SP112136
MacLean (Reliable)	8 x 8	38	UP 8HLP
	8 x 8	46	UP 8HP
	10-1/2 x 10-1/2	26	UP 10HLP
	16-1/2 x 10-1/2	36	UP 1016HLP
	10-1/2 x 10-1/2	42	UP 10HP

U gu - Pedestal, Power
(Above-Grade)
Refer to Construction Drawing UK5

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Inside Dimensions Inches	Height Inches	Catalog No.
API	12 x 16	40	API 12 X 16
Nordic Fiberglass, Inc.	15 x 15	30	PSP-151530
	9 X 13	30	PSP-91330
	9 x 13	36	PSP-91336
	10 X 15	38	PSPF-101538
	15 x 15	38	PSPS-101538-MG-X
	15 x 15	44	PSPS-101544-MG-X
	8 x 8	44	PR-50, PR-55
	9 x 14	30	PR-149 (stake)
	9 x 14	30	PR-150 (stakeless)
	9 x 14	30	PRMC 150 (low profile)
	9 x 14	24	PRMC-160
	9 x 14	30	PRMC-170 (high profile)
	9 x 14	36	PRMC-190
	21 x 21	15	PHH-212115
	16 x 19	12	PHH-161912
	10 x 18	30	PSPX-101830-MG
	15 x 23	15	PHH-152315-MG
PenCell Plastics, Inc.	10-1/2 X13-1/2	24-1/2	AG-14 (low profile)
	10-1/2 X13-1/2	30-1/2	AG-14 (high profile)
	11X14	37	AG-15
	13X17.5	30.5	AG-18
	10-3/4X14-1/4	34	AG-20
	7-1/2 round	38	AG-8820-EWB
	17 x 30	34	AG-1730-EWB
Shallbetter	7.5 x 10.25	39	SUTP Series
Utility Fiberglass	27 x 16	40	PPFP-2700
Vertex	8 x 14	30	SP 814

*Furnished with stake.
**Pole mounted

U gu - Power Pedestal
(Below-Grade)
Refer to Drawing UK6

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Catalog No.
Armorcast	Polymer concrete frame and cover with fiberglass reinforced polyester skirting 6001 Series. P600XXXXA Rotocast Series, molded polyethylene with penta-head bolt
Associated Plastics	Molded polyethylene with galvanized steel or plastic cover Catalog Nos. 1730-1, 3; 1324-1, 3
Blackburn	Molded polyethylene with galvanized steel cover and ground lug. Catalog No. SDR-2PG
Burndy	Molded polyethylene with galvanized steel cover. Catalog No. URD20G23
Carson	Molded polyethylene with plastic cover Catalog No. 1324-12B and 1730-12B H910, HLW1212, H1118, H1324, H1730, H1730, H2436, H3048, HH3060
CDR Systems (Homac)	Fiber reinforced polymer concrete - PA Series with penta-head bolts
Christy Concrete	Polyester reinforced plastic - Series FL8TRCBOX, FL9TRCBOX, FL30TRCBOX, FL36TRCBOX, SYN1118TBOX, SYN1212TBOX, SYN1324TBOX, SYN1730TBOX, SYN2436TBOX, SYN3048TBOX, and SYN3660TBOX
Dexol	HDPE, DX-101, DX-102 ABS, DX-101HD, DX-102HD
Electrimold	Polymer concrete ring and cover with fiberglass reinforced skirting ECAB series. Boxes EPBTH,EPBA series
Highline Products	FHH Series, Fiberglass CHA Series, Fiberglass polymer concrete hybrid

U gu - Power Pedestal
(Below-Grade)
Refer to Drawings UK6

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Catalog No.
Hubbell (Fargo)	HDPE, B-100R Series ABS, B-200R Series HL51
American Padmount Systems	Fiberglass secondary pedestal FSP31139, FSP301515
Newbasis	Fiber reinforced polymer concrete box, ring and cover – PCA Series Fiber reinforced polymer box with polymer concrete ring and cover – FCA Series
PenCell	PE Series-High Density Polyethylene (HDPE) base;lid available in HDPE, fiberglass, aluminum, or stainless steel; PEM Series with modular construction, DT Series – heavy duty HDPE for vehicular traffic
Quazite	Power Pedestal – PV, Boxes - PX/PE Series, PR/LR Series, PC, PG, LG Series
Synertech Moulded Products	S1212, S1118, S1324, S1730, S2436, S3048 and S3660
Thermodynamics	PP91, PP92, PP94, PP96, PP97, PP98, PP03, PPV91, TEVC132415ASY, TEVC121612ASY, and TEVC122016ASY series
API	API MOD20, and API MOD20-FM Rotationally Molded LLDPE

U gv - Stake, Power Pedestal
Refer to Construction Drawing UK5

Manufacturer	Length Inches	Catalog No. For Power Pedestal Only	Catalog No. For Joint Pedestal
Hubbell (Fargo)	42-60-72-78	UP-530S Series	UP-530J Series
MacLean (Reliable)	72-78-84	DM Series	DM Series

U hb - Cable Accessories

(When ordering specify conductor size, type whether copper or aluminum and insulation diameter)

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems.)

200 Ampere Continuous Current Rating

Manufacturer	Catalog No.
Eaton	15 kV, used with loadbreak connectors LPC 215 protective cap LBI215 bushing well insert 2637869C01M rotatable two-way bushing well insert 2604231B01 bushing well plug 25 kV, used with loadbreak connectors LPC 225 protective cap LB1225 bushing well insert LB1225L (long) bushing well insert 2637881C01M rotatable two-way bushing well insert 2604231B01 bushing well plug 35 kV, used with loadbreak connectors 2637592B03M protective cap
Hubbell	15 kV, used with loadbreak connectors 215BI bushing well insert 215IC insulating cap 215FTI feed-thru insert 25 kV, used with loadbreak connectors 225BI bushing well insert 228IC insulating cap 228FTI feed-thru insert

U hb - Cable Accessories
(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems.)

200 Ampere Continuous Current Rating

Manufacturer	Catalog Number
Elastimold (ESNA)	15 kV, used with loadbreak connectors Style 1601-CL cable lead Style 1602A3R feed thru insert Style 1601-A3R bushing plug Style 160-DR insulating cap 25 kV, used with loadbreak connectors Style 2701-A2 bushing plug Style 270-DR deadend receptacle 35 kV, used with loadbreak connectors Style 3701A-3 bushing plug* Style 370DR(G) insulating cap
TE Connectivity – Energy	15 kV, used with loadbreak connectors ELB-15-210 series without jacket seal ELB-15-210-ES series with jacket seal 25 kV, used with loadbreak connectors ELB-25-210 series without jacket seal ELB-25-210-ES series with jacket seal 25 kV, used with loadbreak connectors (without test point) ELB-25-200 series without jacket seal ELB-25-200-ES series with jacket seal 15 kV, used with loadbreak connectors (without test point) ELB-15-200 series without jacket seal ELB-15-200-ES series with jacket seal

U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
Hubbell	15 kV, used with non-loadbreak connectors 615 Series 25 kV, used with non-loadbreak connectors 625 Series
Eaton	15 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System DBA615 Bushing Adapter 25 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System DBA625 Bushing Adapter 35 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System Optional 200 A. loadbreak tap No. 2637449C
Elastimold (ESNA)	15 kV, used with non-loadbreak connectors 600, 650 Series 25 kV, used with non-loadbreak connectors K600, K650 Series 35 kV, used with non-loadbreak connectors 750LR Series

U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
3M	15 kV, Deadbreak termination connectors 5815 Series Modular Splicing System
TE Connectivity – Energy	15 kV Deadbreak termination connectors ELB-15-600without test point ELB-15-600 with test point 25 kV Deadbreak termination connectors ELB-28-600without test point ELB-28-600 with test point 35 kV Deadbreak termination connectors ELB-35-600without test point ELB-35-600 with test point

U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
Richards Manufacturing Co.	15kV, Deadbreak Elbow LC Series System
	15kV, Deadbreak Elbow/ Cold Shrinkable Cable Entrance CSH Series | Cold Shrink Hammerhead System
	15kV, Deadbreak Elbow w/integral 15kV 200A Loadbreak Tap Plug R800 Series System
	15kV, Deadbreak Elbow w/integral 15kV 200A Loadbreak Tap Plug and Cold Shrinkable Cable Entrance CS8 Series | Cold Shrink R800 System
	25kV, Deadbreak Elbow LC Series System
	25kV, Deadbreak Elbow w/ Cold Shrinkable Cable Entrance CSH Series | Cold Shrink Hammerhead System
	25kV, Deadbreak Elbow w/integral 25kV 200A Loadbreak Tap Plug R800 Series System
	25kV, Deadbreak Elbow w/integral 25kV 200A Loadbreak Tap Plug and Cold Shrinkable Cable Entrance CS8 Series | Cold Shrink R800 System

U hb - Cable Accessories

(When ordering specify insulation diameter)

Concentric Neutral Clamps (Bonding)

Manufacturer	Conditions
Harco URD cable clamp	1. To obtain experience. 2. Only for bonding of anodes or other metals to the neutrals of existing cable installations. 3. Not to be used to connect neutral to grounding electrodes.

U hc - Cable Supports
15 and 25 kV

Manufacturer	Catalog Number	Grip Dia. Range (inches)
Aluma-Form	CS-800 Series	0.75 to 2.0
Economy Cable Grip	SPJ087-U	0.87 to 1.00
	SPJ100-U	1.00 to 1.12
	SPJ113-U	1.12 to 1.25
	SPC125-S-U	1.25 to 1.50
Hubbell (Fargo)	GJ-854	0.718 to 0.919
	GJ-855	0.920 to 1.12
	GJ-856	1.12 to 1.50
Kellums	022-16-011	0.81 to 0.94
	022-16-012	0.87 to 1.00
	022-16-013	0.94 to 1.06
	022-16-014	1.00 to 1.18
	022-16-015	1.06 to 1.25
	022-01-018	1.25 to 1.50
Lewis	A-U-SW-18	0.75 to 1.25
	U-1.12	1.12 to 1.62
MacLean Power Systems	MCS-820	0.75 to 3.0
Slater	FCSD 14	0.82 to 0.95
	FCSD 15	0.88 to 1.00
	FCSD 16	0.95 to 1.06
	FCSD 17	1.01 to 1.19
	FCSD 18	1.07 to 1.26
	FC125-U	1.25 to 1.50
Woodhead	35032 (SC075-U)	0.75 to 0.99
	35033 (SC100-U	1.00 to 1.24
	35034 (SC125-U)	1.25 to 1.49

U hd – Brackets, pothead mounting, and Brackets, combination pothead and arrester mounting

Manufacturer	Single Phase	Three Phase
Aluma-Form	TB-EMB-1-2PA	TB-EMB-1-6PA
MacLean Power Systems	-	MTB-EMB-1-6-PA

U he – Padmounted Switchgear

12.5/7.2 kV

Manufacturer	Catalog Number
ABB	UTE, PAD-PAK pad-mounted switching device, single and three-phase, 300 amp
	*ME Fused Series, single and three-phase pad mounted
Durham	AFSP Series, single-and three phase
Federal Pacific	FTDF-P Series, single and three-phase one and two fused taps, pad-mounted
Elliott	Type EPMR, single and three-phase, pad-mounted
Howard Industries	Switch-Pad pad-mounted switching and fusing cabinet, single and three-phase
Shallbetter	SPMD Series, single and three-phase, pad-mounted SPMC Series, 200 ampere single-pole switching

*Furnished with current limiting fuses.

NOTES:
1. Enclosures on this page must comply with the dead-front requirements of RUS Spec. U-4.

2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

3. Single-pole switching of three-phase underground circuits may cause ferro resonance.

U he – Padmounted Switchgear

24.9/14.4 kV

Manufacturer	Catalog Number
ABB	UTE, PAD-PAK pad-mounted switching device, single and three-phase, 200 amp
	ME Fused Series, single and three phase, pad- mounted
Durham	AFSP Series, single-and three phase
Elliott	Type EPMR, single- and three-phase, pad-mounted
Howard Industries	Switch-Pad pad-mounted switching and fusing cabinet, single and three-phase
Shallbetter	SPMD Series, single and three-phase, pad-mounted

NOTES:
1. Enclosures on this page must comply with the dead-front requirements of RUS Specification U-4.

2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

U he – Padmounted Switchgear

(200 and 600 amp)

Manufacturer	Catalog Number
Eaton	Type VFI*, single-phase and three phase, padmounted fault interrupters, 15-35 kV Type R-VAC*, three-phase vacuum switchgear, 15-25 kV
	*Eaton Envirotemp FR3 dielectric fluid is available as an option
Elastimold	Type MVS, single-phase and three phase, 200 and 600 amp, 15-38 kV Type MVI, single-phase and three phase, 200 and 600 amp, 15-38 kV
Elliott	Type EPMR, Single and three-phase, pad-mounted, 25 kV
ERMCO, INC.	Type FusePad, single-phase, 200 and 600 amp, 15-35 kV Type ECO-PAD, three-phase, 200 and 600 amp, 15-35 kV
Federal Pacific	Type PSI-PSI/II Series, 15 kV, 25 kV, 600 amp., three-phase switching, and 200 amp., single-phase switching. (When ordering, add suffix B-4) Type PSE Series, 15 kV, 25 kV, 600 amp switch, 200 amp fuse
G & W Electric Company	Type PVI series, single-phase and three-phase, 200 amp and 600 amp, 15 kV and 25 kV Trident type solid dielectric switches, single-phase and three-phase, 200A, 630A, and 800A, 15 kV through 35 kV
Hubbell (Chance)	Type LVS (pad-mounted) single-phase and three-phase, vacuum switching equipment, fused or unfused, 200 or 600 amp, 15-25 kV Type AIS padmounted, air insulated switchgear, fused or unfused, 200 or 600 amp, 15 kV or 25 kV

Notes:

1. Enclosures on this page must comply with the deadfront requirements of RUS Spec. U-4.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

U he – Padmounted Switchgear

(200 and 600 amp)

Manufacturer	Catalog Number
Kearney/Eaton	Series VP - submersible, single-phase and three-phase, vacuum switching, 200 or 600 amp, 15 and 25 kV, with or without VACOP remote operator
ABB	MES 100 Series, pad-mounted single phase and three phase switching
Scott Engineering	Type SPM-REA, 15 kV, 25 kV, 600 amp., three-phase switching, and 200 amp., single-phase switching
S & C	Mark III, Model PMH (with option G-7), 15-25 kV, 600 amp., three-phase switching and 200 amp., single-pole switching Model PME-15-25 kV, Fully enclosed live parts at all times, three-phase switching and 200 amp single pole switching
Trayer	800 Series, pad mounted three-phase vacuum switching equipment, 200 and 600 amp, 15-25 kV with or without fusing 501 submersible vacuum fuse 15-25 kV enclosure, deadfront 200 or 600 amp., 15-25 kV Type SSA (submersible, fused and unfused) 200 and 600 amp., 15-25 kV

Notes:

1. Enclosures on this page must comply with the deadfront requirements of RUS Spec. U-4.

2. The enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

U hf - Jacketed Cable Restoration Kits

(For resealing concentric neutral wires after installation of splices in jacketed underground cable)

(When ordering, specify diameter of cable over jacket)

Manufacturer	Conditions
Elastimold	
PCS-1 Power Cable Seal	To obtain experience.
Homac	
CNC Series Concentric Neutral Cover	To obtain experience.
Joslyn	
Shrinklite JRS Series	To obtain experience
TE Connectivity - Energy	
WCSM (Tubing Type) MWTM (Tubing Type) CRSM (Wraparound Type)	To obtain experience.
3M	
HSJ Series (Heat Shrink) SJ Series (Cold Shrink)	To obtain experience.

U hf - Terminator Sealing Kits
(For resealing concentric neutral wires after installation of elbows or outdoor terminations on jacketed underground cable.)

(When ordering, specify diameter of cable over jacket.)

Manufacturer	Conditions
Eaton JS200 Elastic Seal	To obtain experience.
Elastimold 200 ECS Elbow Cable Shield, Cold Shrink	To obtain experience.
Homac CNC Series Concentric Neutral Cover	To obtain experience.
TE Connectivity - Energy ESA, Heat Shrink	To obtain experience.
3M 8450 Series, Cold Shrink	To obtain experience.

U hf - Jacketed Cable Grounding Kits
(For connecting a grounding lead wire to the concentric neutral wires and resealing the jacket)

(When ordering, specify diameter of cable over jacket)

Manufacturer	Conditions
CANUSA-EMI Model CFGK-REA Cable Grounding Kit	To obtain experience.
TE Connectivity - Energy Model JGK Cable Grounding Kit	To obtain experience.
3M Model 2252 Cable Grounding Kit	To obtain experience.

U hj - Bracket, combination arrester, cutout and pothead mounting

Applicable Drawing: UA1, UA2, UA3

Manufacturer	Single Phase	Three-Phase
Aluma-Form	1HCA-18-1PB Series	-

U hp - Terminations, Elbow
(rated for switching on three-phase systems)

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
Eaton	15 kV, Loadbreak SBT IV LE215T Series with test point LE215 Series without test point LEJ215T Series with integrated jacket seal; with test point LEJ215 Series with integrated jacket seal; without test point Note: LE215, LE215T manufactured in U.S.A. and Taiwan. 25 kV, Loadbreak SBT LE225T Series with test point LE225 Series without test point LEJ225T Series with integrated jacket seal; with test point LEJ225 Series with integrated jacket seal; without test point
Thomas & Betts (Elastimold)	15 kV loadbreak Style 161 LR Series, without voltage test point Style 162 LR Series, with voltage test point Style 161LRJS Series, without voltage test point, with integral jacket seal Style 162LRJS Series, with voltage test point, with integral jacket seal 25 kV loadbreak Style 261 LR Series, without voltage test point Style 262 LR Series, with voltage test point Style 261LRJS Series, without voltage test point, with integral jacket seal Style 262LRJS Series, with voltage test point, with integral jacket seal 35 kV loadbreak Style 375LR Series, without voltage test point Style 376LR Series, with voltage test point
Hubbell	15 kV, Loadbreak 215LE--, without test point 215LE--T, with test point 215LEJ--, integral seal without test point 215LEJ--T, integral seal with test point 25 kV, Loadbreak 228LE--, without test point 228LE--T, with test point 228LEJ--, integral seal without test point 228LEJ--T, integral seal with test point 35 kV, Loadbreak 236LE--, without test point 236LE--T, with test point
Richards Manufacturing Co.	15 kV, Loadbreak Style 21LBN Series, without voltage test point Style 21LBT Series, with voltage test point

U hq - Terminations, Multipoint

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems)

Manufacturer	Catalog Number
Eaton	15 kV 2-way, 3-way, 4-way bushings Series LJ215C---B (with bracket) Series LJ215C---U (with U-Straps) Series LJ215C--- (junction only) 25 kV 2-way, 3-way, 4-way bushings Series LJ225C---B (with bracket) Series LJ225C---U (with U-Straps) Series LJ225C--- (junction only)
Elastimold (ESNA)	15 kV 2-way bushing, 163J2 3-way bushing, 163J3 4-way bushing, 163J4 25 kV 2-way bushing, 271J2 3-way bushing, 271J3 4-way bushing, 271J4 35 kV 2-way bushing, 373J2 3-way bushing, 373J3 4-way bushing, 373J4
G&W Electric	15kV JB xxx 15U JB xxx 15P, with parking stands 25kV JB xxx 25U JB xxx 25P, with parking stands 35kV JB xxx 35U JB xxx 35P, with parking stands
Hubbell Power Systems	15 kV 2-way bushing 215J2X 3-way bushing 215J3X 4-way bushing 215J4X 25 kV 2-way bushing 228J2X 3-way bushing 228J3X 4-way bushing 228J4X

U hq - Terminations, Feed-Through and Parking Bushings

Manufacturer	Catalog Number
Eaton	15 kV Grounded Standoff Bushing, GSB215 Horizontal Portable Feed-through, LPF215H Vertical Portable Feed-through, LPF215V Universal Portable Feed-through, LPF215U 25 kV Grounded Standoff Bushing, GSB225 Horizontal Portable Feed-through, LPF225H Vertical Portable Feed-through, LPF225V Universal Portable Feed-through, LPF225U
Elastimold (ESNA)	35 kV Feed-thru, 373FT Parking Bushing, 371SOP
Hubbell	15 kV 215FT feed-thru 215SB standoff bushing 25 kV 228FT feed-thru 228SB standoff bushing 228GB grounded bushing

U hq - Terminations, Multipoint

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
Eaton	15 kV, 25 kV Cleer load break connector assembly Series LCN2DLJ615A, LCN2DLJ625A 25 kV 2-way, 3-way, and 4-way bushings Series DJ625A_ (with mounting bracket) Series DJ625A_B_ (without mounting bracket) 35 kV 2-way, 3-way, 4-way bushings Series DJ635---B (with bracket) Series DJ635---U (with U-Straps) Series DJ635--- (junction only)
Elastimold (ESNA)	15 kV 2-way bushing, 650J2 or 675J2 3-way bushing, 650J3 or 675J3 4-way bushing, 650J4 or 675J4 25 kV 2-way bushing, K650J2 or K675J2 3-way bushing, K650J3 or K675J3 4-way bushing, K650J4 or K675J4

U hr - Secondary tap or splice cover, submersible

Manufacturer	Type or Catalog No.
Blackburn	Type WDBS (#2 through #4/0), Type DBS (250 kcmil through 1000 kcmil)
Connector Mfg. Co.	Utilug Sure Seal
DSG-Canusa	CSS Cold Shrink Splice Kits
Elastimold (ESNA)	Style 86
ESP	TSC Series
Homac	FSS Series
Joslyn	Shrinktite JCLS Series
Kearney/Eaton	Aqua-Seal Kit
Preformed	HT Series
Plymouth/Bishop	Splice-Wrap
TE Connectivity - Energy	Rayvolve RVS Series
3M	PST Series 8420

Heat Shrink Tubing (with sealant throughout)

Manufacturer	Type or Catalog No.
TE Connectivity - Energy	Black heat-shrink tubing WCSM cable sleeves
CANUSA-EMI	CFW
ESP	HSH
Panduit	Heat shrink insulating cover and tubing
Sigmaform Corporation	Sigmaform heat-shrinkable products
3M	ITCSN tubular cable sleeve

U hv - Cable, Underground
15 kV, 25 kV, 35 kV Cable

Applicable Specification: 7 CFR Part 1728.204

Conductor (15 kV): Copper or Aluminum - #2 AWG through 1000 kcmil
Conductor (25 kV): Copper or Aluminum - #1 AWG through 1000 kcmil
Conductor (35 kV): Copper or Aluminum – 1/0 through 1000 kcmil

Insulation: Tree-retardant Crosslinked Polyethylene (XLP-TR)
(1) indicates Union Carbide 4202 XLP-TR
(2) indicates BP H119Y XLP-TR
(3) indicates BP H118Y XLP-TR
(4) indicates LG XL8080 TR

Ethylene Propylene Rubber (EPR)
(E) indicates EPR

Neutral: Copper Concentric Neutral
Jacket: High Molecular Weight Polyethylene

Manufacturer	Insulation(s)	Flat Strap Neutral Available
Conductores Monterrey, S.A. de C.V.	1, E	No
Condumex	1, E	No
General Cable	1, 3, E	Yes
Gaon Cable Co., Ltd.	4, E	No
Marmon Utility LLC (Hendrix)	1, 2, 3, E	No
Marmon Utility LLC (Kerite)	E	Yes
Nexans Canada	1, E	No
Nexans Italia	E	No
Okonite	1, E	Yes

U hv - Cable, Underground
15 kV, 25 kV, 35 kV Cable

Applicable Specification: 7 CFR Part 1728.204

Conductor (15 kV): Copper or Aluminum - #2 AWG through 1000 kcmil
Conductor (25 kV): Copper or Aluminum - #1 AWG through 1000 kcmil
Conductor (35 kV): Copper or Aluminum – 1/0 through 1000 kcmil

Insulation: Tree-retardant Crosslinked Polyethylene (XLP-TR)
(1) indicates Union Carbide 4202 XLP-TR
(2) indicates BP H119Y XLP-TR
(3) indicates BP H118Y XLP-TR
(4) indicates LG XL8080 TR

Ethylene Propylene Rubber (EPR)
(E) inidicates EPR

Neutral: Copper Concentric Neutral
Jacket: High Molecular Weight Polyethylene

Manufacturer	Insulation(s)	Flat Strap Neutral Available
Phelps Dodge	1, 3, E	Yes
Prysmian	1, E	Yes
Rome	1, E	Yes
Southwire	1, E	Yes
Synergy Cables	1, E	No

U hv - Cable, Underground

600 Volt Cable

Applicable Specification: RUS Specification U-2
Conductor: Copper, #4 AWG and larger; Aluminum, #2 AWG and larger
Insulation: Cross-Linked polyethylene (XLPE)

Manufacturer	Type Conductor
Alcan	Aluminum
Centelsa	Aluminum
Conductorres Monterrey, S.A. de C.V.	Copper or Aluminum
Condumex	Copper or Aluminum
Encore Wire Corporation	Aluminum
Essex	Copper
General Cable	Copper or Aluminum
Nexans Canada	Aluminum
Okonite	Copper or Aluminum
Phelps Dodge	Copper or Aluminum
Prysmian	Copper or Aluminum
Rome Cable	Copper or Aluminum
Service Wire Company	Copper
Southwire	Copper or Aluminum

NOTE: The manufacturers shown above have indicated that their 600 volt cable is suitable for use on 480 volt corner grounded delta circuits.

The above cable may be supplied with UL label for Type USE.

U hv - Cable, Underground

600 Volt Multi-Conductor Cable

Applicable Specification: RUS Specification U-2
Conductor: Copper, #4 AWG and larger; Aluminum, #2 AWG and larger

Insulation: Cross-Linked polyethylene (XLPE)
Cable Configuration: 3 Insulated Conductors Triplexed

Manufacturer	Type Conductor
Alcan	Aluminum
Conductores Monterrey, S.A. de C.V.	Copper or Aluminum
Condumex	Copper or Aluminum
Encore Wire Corporation	Aluminum
General Cable	Copper or Aluminum
Nexans Canada	Aluminum
Okonite	Copper or Aluminum
Phelps Dodge	Copper or Aluminum
Prysmian	Copper or Aluminum
Rome Cable	Copper or Aluminum
Southwire	Copper or Aluminum

The above cable may be supplied with UL label for Type USE.

U hv - Cable, Underground

600 Volt Cable

(Alternative Cable Constructions)

Applicable Specification: RUS Specification U-2 (except as indicated below)

NOTE: Manufacturers listed below are accepted for alternatives A, B, C, D and/or E for the products listed on pages U hv-2 and U hv-3.

Alternative A: 8000 series aluminum alloy in accordance with ASTM B800 or B801.

Alternative B: Stranding in accordance with ASTM B786 for aluminum 1350 conductors or ASTM B787 for copper conductors.

Alternative C: Abuse resistant (ruggedized) (single or two layer) insulation in accordance with ICEA S-81-570.

Alternative D: Self-healing

Alternative E: Stranding in accordance with ASTM B 901 for Compressed Round Stranded Aluminum Conductors Using Single Input Wire Construction

Manufacturer	Alternative

Conditional List
U hv(1)
June 24, 2025

U hv - Cable, Underground

15 kV, 25 kV and 35 kV Cable

(Alternative Insulation Compound)

Applicable Specification: 7 CFR Part 1728.204

Conductor (15 kV): Copper or Aluminum - #2 AWG through 1000 kcmil
Conductor (25 kV): Copper or Aluminum - #1 AWG through 1000 kcmil
Conductor (35 kV): Copper or Aluminum – 1/0 through 1000 kcmil

Alternative Insulation Compound: Tree-retardant Crosslinked Polyethylene (TR-XLPE)
(I) indicates Pirelli IE.7100 XLP-TR
(II) indicates AT Plastic PowerGuard 320TR
(III) indicates Union Carbide HFDB-4202
(IV) indicates Nova Borealis LE 4212
(V) indicates Dow HFDB 8202
(VI) indicates Dow Endurance™ HFDC 4202 EC
(VII) indicates LG XL 8080TR
(VIII) indicates Hanwha Wire and Cable Compound CLNA TR-8142EC

Ethylene Propylene Rubber (EPR)
(E) indicates EPR
(EAM) indicates General Cable EI-4000-LF

Neutral: Copper Concentric Neutral
Jacket: High Molecular Weight Polyethylene

Conditions: To obtain experience

Manufacturer	Insulation(s)	Flat Strap Neutral Available
General Cable Industries, Inc.	II, III, IV, V, VI, VII, EAM	Yes
Marmon Utility LLC (Hendrix)	III, IV	No
Nexans Canada	II, III, IV	No
Phelps Dodge	II, III, IV, V	Yes
Prysmian	I, IV	Yes
Southwire	III, IV, VI	Yes
LS Cable & System U.S.A., Inc.	IV, VI, VII, VIII, E	No
TELE-FONIKA Kable S.A.	IV	No

U hv - Cable, Underground

600 Volt Cable

(Alternative Cable Construction)

Applicable Specification: RUS Specification U-2 (except as indicated below)

NOTE: Manufacturers listed below are conditionally accepted for alternatives A, B, C, D and/or E for the products listed on pages U hv-2 and U hv-3.

Alternative A: 8000 series aluminum alloy in accordance with ASTM B800 or B801.

Alternative B: Stranding in accordance with ASTM B786 for aluminum 1350 conductors or ASTM B787 for copper conductors.

Alternative C: Abuse resistant (ruggedized) (single or two layer) insulation in accordance with ICEA S-81-570.

Alternative D: Self-healing

Alternative E: Stranding in accordance with ASTM B 901 for Compressed Round Stranded Aluminum Conductors Using Single Input Wire Construction

Condition: To obtain experience.

Manufacturer	Alternative
Alcan	A, C, E
Conductores Monterrey, S.A. de C.V.	C
Encore Wire Corporation	A, C
General Cable	A, C
Phelps Dodge	A, C
Prysmian	A, C, D
Nexans	C
Southwire	A, B, C, D, E

U hw - Safety signs

Applicable Specifications: RUS Drawings ANSI Z535

Manufacturer	Size (inches)	Danger Sign Catalog No.	Warning Sign Catalog No.	Caution Sign Catalog No.
Almetek	7 x 10	Trident D-100-0710	Trident W-100-0710	
	10 x 14	Trident D-100-1014	Trident W-100-1014	
	14 x 20	Trident D-100-1420	Trident W-100-1420	
Brady*	7 x 10	46133		46043
	10 x 14	46131		46041
Eastern Metal*	7 x 10	REA 12-1-710		REA 12-2-710
	10 x 14	REA 12-1-1014		REA 12-2 1014
	14 x 20	REA 12-1-1420		REA 12-2-1420
	20 x 28	REA 12-1-2028		REA 12-2-2028
Electromark*	7 x 10	REA-1-7x10-SV		REA-2-7x10-SV
	7 x 10	REA-1-7x10-AC		REA-2-7x10-AC
	10 x 14	REA-1-10x14-SV		REA-2-10x14-SV
	10 x 14	REA-1-10x14-AC		REA-2-10x14-AC
	14 x 20	REA-1-14x20-SV		REA-2-14x20-SV
	14 x 20	REA-1-14x20-AC		REA-2-14x20-AC
	20 x 28	REA-1-20x28-SV		REA-2-20x28-SV
	20 x 28	REA-1-20x28-AC		REA-2-20x28-AC
Lem	7 x 10	LSS-1400		LSS-1500
	10 x 14	LSS-1401		LSS-1501
	14 x 20	LSS-1402		LSS-1502
Lyle*	7 x 10	UM12-1-710		UM12-2-710
	10 x 14	UM12-1-1014		UM12-2-1014
	14 x 20	UM12-1-1420		UM12-2-1420
	20 x 28	UM12-1-2028		UM12-2-2028
May Advertising	7 x 10	MY710C		MY710B
	10 x 14	MY1014C		MY1014B
	14 x 20	MY1420C		MY1420B
	20 x 28	MY2028C		MY2028B
For pressure sensitive decal add "D" prefix				
Truck Sign Service*	7 x 10	TSD-710		TSC-710
	10 x 14	TSD-1014		TSC-1014
	14 x 20	TSD-1420		TSC-1420
	20 x 28	TSD-2028		TSC-2028

*Reflective signs also available.

The signs listed on this page are to be secured to equipment and transformer enclosures by means of an adhesive or by welding. Screws and rivets are not to be used.

U hx - Cable Route Marker

Manufacturer	Catalog Number
Surface Mounted	
Hubbell (Chance)	C554-0001
Above Grade	
Carsonite	REA-100
Electromark	REA-3-4x7-SV REA-3-4x7-AC REA-3-5x12-SV REA-3-5x12-AC
Flexstake	603, 604, 605, 606
Greenline	FLU-78 (Decal on one side) DSU-78 (Decal on both sides)
Hubbell (Chance)	C554-0183
J Miller Industries	JMI-375
Lyle	UM12-712
May Advertising (For pressure sensitive decal add "D" prefix to catalog number.)	MY45A, MY712A
Quantum	QM-375
Truck Sign Service	BCW-712
W. H. Brady	BL1 (Decal on one side) BL2 (Decal on both sides)

U hy - Splice, Underground, Permanent

(when ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
Eaton	15 kV and 25 kV EZ II straight and transition splice #3 through 4/0 35 kV 2603934B Series straight splice
Elastimold (ESNA)	15 kv Style 1500S, straight splice, through #1/0 Style 25-S, straight splice, 2/0 through 4/0 Style l5PCJ-1, straight splice, through 4/0 Style 25-Y, Y-splice 25 kV Style K-25-S, straight splice Style K-25-Y, Y-splice Style 25PCJ-1, straight splice, through 4/0 35 kV Style M-250-S, straight splice
DSG-Canusa	15 kV CJ 10 Series, heat shrinkable joints 25 kV CJ 10 Series, heat shrinkable joints 35kV CJ 10 Series, heat shrinkable joints
Hubbell (Chardon)	15 kV Straight Splice through #1/0, Model 9U16A-100 "Uni-Matic" Through #2/0, Model 9U06A 25 kV "Uni-Matic" Through #2/0, Model 9U06A
Prysmian	15 kV and 25 kV “Elaspeed” style EPJMe straight splice, #2 through 1000 kcmil
3M	(15, 25, 35 kV) 5400 Series Quick Splice/Quick Splice II/Quick Splice III, 15 kV 5411R cable repair splice 5411R/HSJ-I cable repair splice (for jacketed cable)

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
TE Connectivity - Energy	15 kV CSJU-1511 CSJU-S-1511 CSJA-1521 CSJA-1522 CSJA-1523 CSJA-1524 HVS 1510-R__ 200 Amp Splice kit CAS-15WJ-2, cold-applied splice 25 kV CSJU-2511 CSJU-S-2511 CSJA-2822 CSJA-2823 CSJA-2824 For Bare Concentric Neutral Cable: HVS-2510-REAX in-line joint HVS-2510E-R-REAX repair joint For Jacketed Cable: HVS-2510-JCN-REAX in-line joint HVS-2510E-RJ-REAX repair joint CAS-28WJ-2, cold-applied splice 35 kV CSJA-3523 CSJA-3524 CSJA-3525 For Bare Concentric Neutral Cable: HVS-3510E-REAX in-line joint For Jacketed Cable: HVS-3510E-JCN-REAX in-line joint CAS-35M, cold-applied in-line splice
Sigmaform	15 kV SSK Series (Heat Shrink)

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
Richards Manufacturing Co.	15, 25, and 35 kV SSC Series cold shrink

U hy - Splice, Underground, Separable

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
Elastimold (ESNA)	15 kV Style 151-SR, receptacle Style 151-SP, plug Style 150-DP, deadend plug Style 150-DR, deadend receptacle Sty1e l50-T, T-tap 25 kV Style K-151-SR, receptacle Style K-151-SP, plug Style K-150-DR, deadend receptacle Style K-150-T, T-tap

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
Eaton	15 kV 2604904B Series straight splice (MPS-600) 25 kV 2604905B Series straight splice (MPS-600)
Elastimold (ESNA)	15 kV Style 650-S, straight splice Style 15PCJ-2, straight splice, through 1250 kcmil Style 650-Y, Y-Splice 25 kV Style K650-S, straight splice Style K650-Y, Y-splice Style 25 PCJ-2, straight splice, through 1250 kcmil 35 kV Style M650S, straight splice

U ja – Equipment Flat Pad*

Manufacturer	Catalog Number
Armorcast	600 Series, Polymer Concrete P600XXXX Rotocast, LLDPE
Associated Plastics	API 4000 Series RPM
Carolina Dielectrics	Model 0502-1, Fiberglass, Size:40”x44”
CDR Systems (Homac)	PP Series, Fiber reinforced polymer concrete
Diversitech	FRC Series – Fiberglass reinforced concrete
Electri-Glass	Fiberglass LP-4145, 41" x 45"
Electrical Materials	Molded HMW Polyethylene Model 64-3BC, 42" x 41" x 4" Model 65-4BC, 52" x46"
Electrimold	EPPT
Highline Products	PBP Series, Polymer concrete hybrid HL-46B, Fiberglass, Size: approx. 42” X 42”
Formex	Mode1 TP-REA, Molded polyethylene
Heil Rotomold, Inc.	T Series, High density polyethylene
Highline	HL-46B, Fiberglass, Size: approx.42"x42"
Hubbell (Chance)	C107-0162 Fiberglass, Size: 40" x 44"
Major Frame-Crete	ETPP precast, cellular concrete, 42"x42"
Newbasis	Polymer pad – PP1P-4242
Nordic	TP Series, Fiberglass
Parking Bumper Company – a Division of Hog Slat, Inc.	7610, 7612, 7613, 7626PE, 7621
PenCell Plastics	TP-4220, TP-4224, TP-4227
Quality Rubber Company	34242 light-weight concrete
Quazite Corp.	Composolite - PH Series
RMI-D	Dwg. No. 730126-2, Molded polyethylene Size: 42" x 42"
Smith Cattleguard	Easi Set T. Series, Precast Reinforced Concrete
Thermodynamics	Poly-Pad, PR Series, Molded polyethylene YEPR031220, YEPR031226, compression molded polypropylene

*Order by catalog number and size.

U ja – Equipment Flat Pad*

Manufacturer	Catalog Number
Gillespie Precast	TEMA 00113600-PAD; 42” X 42” TEMA 00113800-PAD; 62” X 76”

*Order by catalog number and size.

U ja – Equipment Box Pad (Sleeve)*

Manufacturer	Catalog Number
Acura Fiberglass Corp.	Model AG 4532
Associated Plastics	Transformer pad and box assembly, API 4242 RPM Pad and 1730 Box Transformer Pads, API 16 and API 45
APS	FGBP Series, Fiber Glass
Blue Grass Vault Company	BG-PV-T, BG-PV-1, BG-PV-2
Concast	Fibercrete modular bases
Custom Composites	R Series Fiberglass
DiversiTech	FRC Series – Fiberglass reinforced concrete
D & L	Fiberglass
Electri-Glass, Inc.	BP-2000
Electrimold	EFBT,EFBS,EFBG Series
Fiberglas Fabricators	Transformer pad and sleeve assembly, FFBP series
Formex	Transformer pad and box assembly - TP-REA Series Pad, 1730-A Series Box
Highline	Box pad HL, FBP, FSG, AND FGS Series
American Padmount Systems	FGS Series Fiberglass ground sleeves and box pads
Maysteel	CW-GS-P Series
Mor-Tech Fab	Transformer pad ground sleeves
Nordic	GS Series Fiberglass (excluding GS-37-43-15-A) CBP-37-43-15-A
PenCell	Transformer pad and box assembly- TPS-20-PE Pad, PE-20GS Box
ProGlass, Inc.	TX, SR, S, and SG Series (All without optional lids)
Quality Fiberglass	QF Series
Synertech Moulded Products	S1212, S1118, S1324, S1730, S2436, S3048 and S3660
Thermodynamics	Poly Pad - VC series (VCC-P series covers available) Polyethylene

*Order by catalog number and size.

U jb - Splice Shield

Manufacturer	Catalog Number
Kellems	No. 014-03-1429

U sc - Regulators, voltage, pad-mounted for underground distribution

12.5/7.2 kV

Manufacturer	Conditions
Siemens-Allis	
Single-phase, step-type pad-mounted regulator Type PFR (76.2, 114.3 & 167 kVA)	To obtain experience.

U sd - Current Transformers
600 Volt

Direct Burial Type

Manufacturer	Type or Catalog No.
General Electric	JAL-O

Indoor Type for Pad-Mounted Transformers

Manufacturer	Type or Catalog No.
ABB	CMV
G.E.C. Durham Industries (Astra)	AP
General Electric	JAB-O
Schlumberger	R6P

U si - Anodes, Sacrificial
(Drawing M27)

Zinc Anodes*

	Pre-packaged With Connecting Wire			Bare Continuous Strip (Ribbon)	
	12 lbs.	30 lbs.	60 lbs.	5/8" x 7/8"	1/2" x 9/16"
Anode Systems	S-12 packaged	S-30 packaged	S-60 packaged	-	-
Cathodic Protection Services	12HII-4A	30HII-4A	60HII-4A		
Federated Metals	S-12 packaged	S-30 packaged	S-60 packaged	Regular Size Type II	Junior size
Harco	AZC12GJ	AZC30GJ	AZC60HJ		
Mesa	S-12 packaged	S-30 packaged	S-60 packaged	Regular Size	Junior size
Stuart	SZ-12	SZ-30	SZ-60		
	-----VIBROX packaged-----				

*When ordering, specify zinc anodes that meet ASTM B418-73 Type II Composition and RUS Specification DT-9, "RUS Specification for Zinc Sacrificial Anodes."

U si - Anodes, Sacrificial
(Drawings UM11-1, UM26, UM27, M2-7, M2-17)

Magnesium Anodes**

	Standard Potential				High Potential			
	17 lbs	20 lbs	32 lbs	50 lbs	17 lbs	20 lbs	32 lbs	48 lbs
Anode Systems	17 packaged	-	32 packaged	50 packaged	17 packaged	20 packaged	32 packaged	84 packaged
Cathodic Protection Services	AMH17A packaged	-	AMH32A packaged	AMH50A packaged	17D3 packaged	20D2 packaged	32D5 packaged	48D5 packaged
Federated Metals	17 packaged	-	32 packaged	50 packaged	-	-	-	-
Global Cathodic Protection	-	-	-	-	17D2	20D2	32D3	48D5
Harco	AMC17J	AMC20J	AMC32J	AMC50J	AMC17G	AMC20G	AMC32G	AMC48G
Kaiser Mag.	17 Vibra Pak	-	32 Vibra Pak	50 Vibra Pak	17 Electromag Vibra Pak	-	32 Electromag Vibra Pak	50 Electromag Vibra Pak
Mesa	17 packaged	-	32 packaged	50 packaged	17D Series	20D2	32D Series	48D5
Stuart	SM-17	-	SM-32	SM-50	SM-17H	-	SM-32H	SM-48H

**When ordering, specify magnesium anodes that meet RUS Specification DT-10, "RUS Specification for Magnesium Sacrificial Anodes."