Errata

NFPA 70®

National Electrical Code®

2026 Edition

Reference: 720.22(C)(1)
Errata No: 70-26-3

The Code-Making Panel 3 and National Electrical Code Correlating Committee notes the following error in the 2026 edition of *NFPA 70®*, *National Electrical Code®.*

1. Correct spelling error in section paragraph 720.22(C)(1) to read as follows:

720.22(C)(1) Wiring Methods. The limited-energy ~~ables~~ cables used in other spaces used for environmental air shall be limited to those cables specifically listed for use within an air-handling space or listed prefabricated cable assemblies of metallic manufactured wiring systems without nonmetallic sheath. Other types of cables, conductors, and raceways shall be permitted to be installed in electrical metallic tubing, flexible metallic tubing, intermediate metal conduit, rigid metal conduit without an overall nonmetallic covering, flexible metal conduit, or, where accessible, surface metal raceway or metal wireway with metal covers.

Issue Date: October 17, 2025

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION